

Conquest DICOM Server 1.4.15 CONFORMANCE STATEMENT and detailed software revision history

Revision 1; 19961103	As taken from the 'developers cut' distribution of MicroPACS
Revision 2; 19980703	Conquest additions; pre-release 1.3.1.
Revision 3; 19980713	Conquest additions; release 1.3.1
Revision 4; 19990415	Updated (mainly for RT), release 1.3.2
Revision 5; 19990527	Small software updates, birthday, sex, bolus, release 1.3.3
Revision 6; 20000131	NKI sops updated, new compression mode, mirroring, release 1.3.4
Revision 7; 20000316	Added operation as NT service, pre-release 1.3.5
Revision 8; 20000403	Unlimited servers/services, auto-login, self-test, sop choices, fixes for GE Hi-Speed, improved display, fixed hang concurrent C-ECHO's, final release 1.3.5
Revision 9; 20000701	Improved browser menu, other ODBC drivers, release 1.3.6
Revision 10; 20001129	Multithread UNC path fixes, edit ID, sendto, edit, release 1.3.7
Revision 11; 20010318	Hostname fix, runs 4 services, show incoming, release 1.3.8
Revision 12; 20010502	GUI additions database fixing; faster compression; fixed leaks, release 1.3.9
Revision 13; 20011109	better forward/export, extended DB/sop, zip, drag/drop, rel 1.3.10
Revision 14; 20020508	reliability and error handling fixes, UID configurable, dbrev 6
Revision 15; 20020613	StudyModality, db rev 7, find local missing pats, release 1.3.11
Revision 16; 20020822	FilenameSyntax for DICOM-Works; printing, release 1.3.12
Revision 17; 20021215	Various fixes. Non-ODBC driver; read-ahead thread; release 1.4.0
Revision 18; 20030303	Bug fix release 1.4.1
Revision 19; 20030710	Release 1.4.2, flexible compression and transfer fixes, db rev 11
Revision 20; 20030922	release 1.4.3, registry/administrator bug/doc; long filenames
Revision 21; 20040406	Release 1.4.4, mysql fix / large disks / db rev 13 / jpeg fixes / GUI uses MAG0.9 / system DSN
Revision 22; 20040426	Release 1.4.4a, mysql fix broke MS-access and SQL server, added DoubleBackSlashToDB (see 4.1.3)
Revision 23; 20040615	Release 1.4.5, built-in DbaseIII suitable for huge archives; better deletion tools; auto-move
Revision 24; 20040722	Release 1.4.6, Added FixKodak; Added "nj" compression; FixPhilips/FixKodak defaults 0 (!)
Revision 25; 20040805	Release 1.4.6a, Fix in move for single image
Revision 29; 20041129	Release 1.4.7, JPEG fix, bugreport button; split/merge, 'k' compress, uid list matching, AE with ~xx
Revision 30; 20050131	Release 1.4.8, Fixed delete, nightlymove, 4-server; hold failed forwards/copies; distribution compiles, initial linux release and initial web interface
Revision 31; 20050912	Release 1.4.9, Fixes in web and Linux, modality worklist
Revision 32; 20051024	Release 1.4.9a, Fix crashes due to no patch in controls.pas
Revision 33; 20060103	Release 1.4.10, VirtualServerFor, fixes leaks, linux, postgres
Revision 34; 20060328	Release 1.4.11, K-Pacs viewer, native MySQL, worklist fix, virtualserver fix, flexible filenamesyntax, WEBReadOnly, Fix forwarder retry logic
Revision 35; 20060708	Release 1.4.12alpha: bug fixes, db performance improved, and appendix 5-7
Revision 36; 20061222	Release 1.4.12: bug fixes in dbaseIII driver and in deleting, forwarding and grabbing, resizeable GUI
Revision 37; 20070127	Release 1.4.12b: importconverters, converter scripting, fixes in dbaseIII driver and web access, no nki compression in .dcm
Revision 38; 20070201	Release 1.4.12c: "storage" importconverter, fix ExportFilter and problem in most GUI commands

Revision 39; 20070305	Release 1.4.13alpha: "defer" exportconverter, stuff for k-pacs web viewer; manual split into user and technical part by radtraveller – this is the technical part
Revision 39; 20070707	Release 1.4.13beta: native mysql fixes, delayed converters, sqlite
Revision 40; 20070709	Release 1.4.13beta2: some last fixes
Revision 41; 20071116	Release 1.4.13: more fixes and parameters
Revision 42; 20080322	Release 1.4.14beta: uj compression; database changes; fixes
Revision 43; 20080902	Release 1.4.14: fixes, improved web pages; added query on 'Number of Patient Related Studies' items etc.
Revision 44; 20090412	Release 1.4.15alpha: 64 bits, postgres, jpg graphic, etc.
Revision 45; 20090929	Release 1.4.15: mostly bug fixes and a few scripting extensions

Contact, ConQuest DICOM server and many MicroPACS extensions

Lambert Zijp or Marcel van Herk; Radiotherapy department; The Netherlands Cancer Institute; Amsterdam, the Netherlands; Fax: +31-20-6691101 / Email: zijp@nki.nl or portal@nki.nl

Copyright (c) 2009 The Netherlands Cancer Institute.

Developed by Marcel van Herk and Lambert Zijp; the Netherlands Cancer Institute; RT Department

Server core based upon:

Copyright (c) 1995 Regents of the University of California. All rights reserved.

Developed by: Mark Oskin, mhoskin@ucdavis.edu; University of California, Davis Medical Center; Department of Radiology with a Solaris port done and maintained by: Terry Rosenbaum; Michigan State University; Department of Radiology.

Original MicroPACS developer (not active anymore)

Mark Oskin; UC Davis Medical Center; PACS Research and Development Lab.
(916)734-0308 / FAX (916)734-0316 / Email: mhoskin@ucdavis.edu

Administrative / Licensing Contact, original MicroPACS components

Richard L. Kennedy; UC Davis Medical Center
(916)734-7267 / FAX (916)734-0316 / Email: rlkennedy@ucdavis.edu

Redistribution and use in source and binary forms are permitted provided that the above copyright notice and this paragraph are duplicated in all such forms and that any documentation, advertising materials, and other materials related to such distribution and use acknowledge that the software was developed by the University of California, Davis and The Netherlands Cancer Institute, Amsterdam. The name of the University may not be used to endorse or promote products derived from this software without specific prior written permission. THIS SOFTWARE IS PROVIDED ``AS IS" AND WITHOUT ANY EXPRESS OR IMPLIED WARRANTIES, INCLUDING, WITHOUT LIMITATION, THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.

TABLE OF CONTENTS

SECTION 1 INTRODUCTION	4
SECTION A(2) CONFORMANCE STATEMENT	6
A.0 INTRODUCTION	6
A.1 IMPLEMENTATION MODEL	6
A.1.1 Application Data Flow Diagram	6
A.1.2 Functional Definition of AE's	6
A.1.3 Sequencing of Real - World Activities	7
A.2 AE SPECIFICATIONS	10
A.2.1 AE1 Specification	10
A.2.1.1 Association Establishment Policies	11
A.2.1.1 General	11
A.3 COMMUNICATION PROFILES	16
A.3.1 Supported Communication Stacks (parts 8,9)	16
A.3.2 OSI Stack	16
A.3.3 TCP/IP Stack	16
A.3.3.1 API	16
A.3.3.2 Physical Media Support	16
A.3.4 Point-to-Point Stack	16
A.4 EXTENSIONS / SPECIALIZATION / PRIVATIZATIONS	16
SECTION 3 DEFAULT QUERY/RETRIEVE INFORMATION MODEL DEFINATION	17
3.0 INTEROPERABILITY SCHEMA	17
3.0.1 PATIENT ROOT QUERY/RETRIEVE ENTITY RELATIONSHIP	17
3.0.2 STUDY ROOT QUERY/RETRIEVE ENTITY RELATIONSHIP	18
3.0.1 PATIENT/STUDY ONLY QUERY/RETRIEVE ENTITY RELATIONSHIP	18
3.1 ENTITY DESCRIPTIONS	18
3.2 PATIENT ROOT QUERY/RETRIEVE INFORMATION OBJECT DEFINATION	19
3.2.1 Patient Level Keys for Patient Root Query/Retrieve Information Model	19
3.2.2 Study Level Keys for Patient Root Query/Retrieve Information Model	19
3.2.3 Series Level Keys for Patient Root Query/Retrieve Information Model	19
3.2.4 Image Level Keys for Patient Root Query/Retrieve Information Model	20
3.3 STUDY ROOT QUERY/RETRIEVE INFORMATION OBJECT DEFINATION	20
3.3.1 Study Level Keys for Study Root Query/Retrieve Information Model	20
3.3.2 Study Level Keys for Study Root Query/Retrieve Information Model	21
3.3.2 Image Level Keys for Study Root Query/Retrieve Information Model	21
3.4 PATIENT/STUDY ONLY QUERY/RETRIEVE INFORMATION OBJECT DEFINATION	21
3.4.1 Patient Level Keys for Patient/Study Only Query/Retrieve Information Model	21
3.4.1 Study Level Keys for Patient/Study Only Query/Retrieve Information Model	21
3.3 STUDY ROOT QUERY/RETRIEVE INFORMATION OBJECT DEFINATION	22
3.3.1 Study Level Keys for Study Root Query/Retrieve Information Model	22
SECTION 4 FILES AND PRODUCT INTERACTION	23
APPENDIX 1: CONQUEST MODIFICATIONS TO MICROPACS.....	27

SECTION 1. INTRODUCTION

The MicroPACS is a Windows or Linux based PACS system that has, at its core, the UCDCM DICOM Network Transport libraries. This system has been combined with a complete user interface (Windows only), which also acts as installation program (written in Borland Delphi) to form the Conquest DICOM server. The Information Definition is designed to be field/run-time programmable. Below the DICOM interface is a database connectivity class that uses a stable built-in DBASEIII driver, talks to ODBC compatible data sources (Windows only), MySQL, or a built-in SQLite driver. This combination permits a PACS system with the following features:

- Complete DICOM Interface. Including SCP's for run-time programmable storage IOD's, and SCP for DICOM Queries and Retrieves.
- Programmable SQL Database tables. This user-programmable feature allows the MicroPACS to be custom tailored to a particular Clinical/Research area. For instance, in a CR setting, the PACS system can be programmed to allow users to query on kvp and ma or in a CT setting, the PACS can be programmed to allow queries on slice-distance.
- Communication to database is done via a built-in dBaseIII driver (default and advised for small archives of up to 100.000 images), ODBC (Windows only), SQLite, or native MySQL (Windows only). This allows de-coupling PACS and SQL technology. ODBC was tested with (Windows):
 - Microsoft Access
 - SQL server (most reliable and advised for serious use)
 - Some users have reported successful operation using Interbase and Oracle. Versions 1.4.5 and up have a small fix to work with MySQL – which seems suitable for up to 100.000 images (see the DoubleBackSlashToDB setting in dicom.ini). Oracle requires manual editing of the DICOM.SQL file, where the names of fields 'rows' and 'columns' are changed to, e.g., 'qrows' and 'qcolumns'.

Note: The built-in dBaseIII driver (Conquest addition) is not a full SQL server and poses limitations on query keys: only queries like 'key' = exact match; 'key*' = value starts with key; and '*key*' = value contains key, are supported, as well as date-range queries and multiple UID matching queries. Only common hierarchical queries are supported with fields that are listed in the single de-normalized table for the selected query level (see file DICOM.SQL). Regular queries passing PatientID, StudyUID, and/or SeriesUID will be (very) fast, even for huge archives. Other (image) queries in large archives (>1000.000 images) may be very slow. Server startup time for huge archives may be long due to in-memory index creation (about 1 minute per 1000.000 images). During indexing the server is read-only and only shows indexed images.

- (Conquest addition) Fast and safe (CRC checked) error free compression (>2x) of image data on disk. Do not use this option if you want to read the image files directly from disk yourselves using third party software.
- (Conquest addition) Easy installation of many servers on a single PC. Servers may run as service(s).
- (Conquest addition) A database browser and slice viewer (Windows only) integrated in the PACS system with options for: viewing the DICOM

information in a slice, creating BMP files (ideal for slides), sending selected images, printing, and database fix tools such as changing patient IDs, and deleting and anonymizing studies and series. Also tools to merge or split series. Drag and drop to load DICOM or HL7 files, directories, or a variety of zip files (you then need to place 7za.exe in the server directory).

- (Conquest addition) A simple query/move user interface (Windows only) for diagnostic purposes, to improve your knowledge of DICOM, and to grab missing data from another server.
- (Conquest addition) Fully integrated functionality in one user interface.
- (Conquest addition) Simple print server (Windows) - to default printer.
- (Conquest addition) Log files, which are daily zipped (Windows only). We use the TZipMaster VCL by Chris Vleghert and Eric W. Engler.
- (Conquest addition) Correct display of JPG and RLE compressed images in browser (Windows only).
- (Conquest addition) Flexible configuration of JPEG and NKI private compression with optional (de)compression of incoming, dropped, transmitted and archived files. The actual JPEG (de)compression is done using executables from the OFFIS DICOM toolkit (DCMTK version 3.5.3), developed by Kuratorium OFFIS e.V.. Since version 1.4.7, also a built-in decompression engine is included (Windows only) using the International JPEG group code, and JPEG compression had some fixes.
- (More conquest additions) Highly improved performance (e.g., using a read-ahead thread), and simple image forwarding/action capability.
- The archive is well suited as DICOM server for the DICOMWORKS viewer by Phillipe Puech.
- If the BDE is not installed, we use the MiTeC DBFTable component by MichaL MutL. For other data sources ADO is used (Windows only). Alternatively libmysql.dll may be used to access mysql directly (copy it from mysql server version 5.0.22 to the dicom server directory).
- Version 1.4.12 can use a native MySQL driver (based on Rangel Gustavo Reale's TMySQLDataset and Matthias Fichtner's mysql.pas) and includes a preliminary advanced series viewer based on EZDicom / K-Pacs (many thanks to Chris Rorden and Andreas Knopke). Fixes: strip group 2 information of any files sent, retry logic, worklist query.
- Version 1.4.12 improves database performance, has some important bug fixes (rare crashes, incomplete deletion and grabbing, and rare database corruption on dbaseIII). Further it has the possibility to forward multiple images on a single association, and improved documentation
- Version 1.4.12b and c add importconverters and bug fixes in dbaseIII driver and web access and do not allow .dcm with nki compression
- Version 1.4.13 has a web viewer based on K-PACS, SQLite is now included, and more import and export converter options were added such as delayed forwarding and preretrieval. Then small fixes were made in native mysql (also the driver is now included in the package), and several other aspects of the server, such as handling of compression errors, out of memory conditions, and others.
- Version 1.4.14 has a more web options (move, delete and viewers), more exportconverters and 'Number of Patient Related Studies' etc. query items

- Version 1.4.15alpha fixes small bugs; and adds QueryConverters, color jpeg decoding with built-in code, frame control, several command line options, an anonymization script, postgres support, and jpeg web export graphics
- Version 1.4.15 fixes more small bugs and adds more scripting options

SECTION A(2). CONFORMANCE STATEMENT


A.0 INTRODUCTION

This conformance statement (CS) details the MicroPACS compliance to DICOM v3.0. It covers all DICOM Service Class roles in this product:

- Various Storage Service Class (SCP) Roles
- Morphing Storage Service Class (SCU) Roles
- Patient Root Query & Retrieve (SCP) Roles
- Study Root Query & Retrieve (SCP) Roles
- Patient/Study Root Query & Retrieve (SCP) Roles
- Verification Service Class (SCP) Role
- Print Management (SCP) Role
- Worklist Query (SCP) Role

A.1 IMPLEMENTATION MODEL

A.1.1 Application Data Flow Diagram



A.1.2 Functional Definition of AE's

Application Entity 1, MicroPACSMMain

Supports the following functions:

- Has access to patient demographics and pixel data in the local database.
- Responds to DICOM associations containing image and worklist query requests using the information in the local database.
- Moves IOD modules to any configured DICOM AE when requested to do so by a remote DICOM AE.
- Responds to DICOM associations containing storage requests and places the IOD in the local database.
- Responds to DICOM associations containing verification requests.
- Responds to DICOM associations containing print requests and prints items on the default local Windows printer.
- Responds to private DICOM associations to support the WEB interface.

NOTE: The Conquest Applications (not part of the server release) or other DICOM network viewers (e.g., KPacs) will use separate AE's which **MUST** be configured in ACRNEMA.MAP (use the "**Known DICOM providers**" page) to allow access of images from the DICOM server.

A.1.3 Sequencing of Real - World Activities

Image Store:

- The remote AE will initiate a DICOM association.
- The MicroPACSMMain AE will select the appropriate Abstract and Transfer Syntax's from those proposed by the remote AE.
- The remote AE will initiate a C-Store to send the IOD.
- The MicroPACSMMain AE will respond with a C-Store-RSP upon receipt of the IOD.
- The following processing occurs using the WorkList database (can be enabled/disabled using 'WorkListMode' in DICOM.INI):
 - WorkListMode=0: no processing occurs.
 - WorkListMode=1: The AccessionNumber is looked up in the local WorkList database, if it is found, any element in the DICOM object that is also present (and non-NULL) in the WorkList database, will be replaced by the value from the WorkList database. These changes are made both in the database and in the image that is stored on disk.
 - WorkListMode=2: As mode 1, but the image will be refused if the AccessionNumber is not found.
 - Note: there is no DICOM method of filling the worklist database (see the description of WorkListMode).
- The following processing (can be enabled/disabled by defining 'FixPhilips = 0/1' in DICOM.INI) of the patient ID occurs to conform patient ID's generated by a Philips scanner with NKI policy:
 - From a patient ID of 10 digits (i.e., only exactly 10 digits) and a numeric value larger than 0001000000, starting with at least 2 zeros, the first 2 or 3 leading zeros are stripped. I.e., '0123456789' is not changed, '0020101234' is replaced by '20101234', '0009901234' is replaced by '9901234', and '0000012345' is replaced by 0012345. The result is that a 10 digit ID from Philips that consists of a valid NKI patient ID with extra leading zeros is converted to a valid NKI patient ID. These changes are made both in the database and in the image that is stored on disk.

- The following processing (can be enabled/disabled by defining 'FixKodak = 0/1' in DICOM.INI) of the patient ID occurs to conform patient ID's generated by a Kodak RIS worklist with NKI policy:
 - From a patient ID of 8 digits (i.e., only exactly 8 digits) and a numeric value larger than 01000000, starting with at least 1 zero, the leading zero is stripped. I.e., '0123456789' is not changed, '09901234' is replaced by '9901234', and '00012345' is replaced by 0012345. The result is that a 8 digit ID from Kodak RIS that consists of a valid NKI patient ID of before 2000 with a superfluous leading zero, is converted to a valid NKI patient ID. These changes are made both in the database and in the image that is stored on disk.
- Trailing space are discarded from the patient ID.
- ImportConverters are called as scripts or rules to modify, delete or log images or VR's in them.
- The pixel data is NKI or JPEG compressed if this option is enabled.
- The image is stored and disk and image header data is (re-)entered in the database at all four levels (patient, study, series, and image). The following consistency checking is performed on the data entered in the database (without changing the image information that is stored):
 - Inconsistent link information (e.g., two images of the same series belong to different patients), lead to a reject to store the new image with reported failure to the sending client.
 - Filled items will not be overwritten by empty items.
 - Known sex (M or F) in the patient database will not be overwritten with any other value than M or F.
 - A known date of birth in the database will not be overwritten with an empty date or with a date on the 1st of January (which has a high probability to be wrong). When the original date of birth is empty, any value will be accepted.
 - In case of any other inconsistency, the newer values will be written in the database, and the change will be logged as a warning in serverstatus.log. Inconsistencies in the birthdate are also logged in PacsTrouble.log.
 - The (series) Modality field is appended to the Study Modality field in the database if it does not already contain this Modality.
 - The PatientName, PatientBirthDate and PatientSex items are duplicated in the study table (database rev8 and up), to allow detection of patient ID mix-ups.
- Optionally the image is processed or forwarded (compressed or uncompressed) if Modality and StationName match with values specified in dicom.ini and the optional ExportFilter test is passed (see appendix 7).
- Some logging of activity occurs.

Query/Retrieve:

- The remote AE will initiate a DICOM association.
- The MicroPACSMMain AE will select the appropriate Abstract and Transfer Syntax's from those proposed by the remote AE.
- Queries and retrieves can be inspected, modified or rejected by a script
- Queries can be forwarded to up to 10 VirtualServerFor entries. The received data will be merged with the data from the server's database and cleaned of duplicates (see appendix 7).
- Optionally the 'Number of Patient Related Studies'-like items will be computed (this executes another query for each result of the first query)

- Upon receipt of a C-Move request, the MicroPACSMMain AE will initiate an SSC/SCU association morphing to the stored IOD SOP Class to the specified and configured DICOM AE. Compressed pixel data will be decompressed or recompressed prior to transmission. Optionally a script will process the retrieved image data. A C-Move response message will be generated synchronously with the associated C-Store.
- Retrieval of data stored on one or more of the VirtualServerFor entries and not on the local server will initiate automatic transfer from the listed servers in the VirtualServerFor table to the local server, followed by a transfer to the C-MOVE destination. After the retrieval data can be optionally deleted again (see appendix 7).
- Some logging of activity occurs.

Worklist Query:

- The remote AE will initiate a DICOM association.
- The MicroPACSMMain AE will select the appropriate Abstract and Transfer Syntax's from those proposed by the remote AE.
- Queries can be inspected, modified or rejected by a script
- The MicroPACSMMain AE will query the Worklist database and respond with zero or more modality worklist items.
- Some logging of activity occurs.
- Note: there is no DICOM method of filling the worklist database. It can be filled through the web interface, by drag and dropping hl7 files or programmatically (see the description of WorkListMode).

Verification:

- The remote AE will initiate a DICOM association.
- The remote AE will initiate a C-ECHO.
- The MicroPACSMMain AE will respond with a C-ECHO-RSP.
- Some logging of activity occurs.

DICOM Print:

- The remote AE will initiate a DICOM association.
- The remote AE will create a basic film session using N-CREATE.
- The MicroPACSMMain AE will ignore the information but will respond with a N-CREATE-RSP.
- The remote AE will create a basic film box using N-CREATE.
- The MicroPACSMMain AE extracts the Image Display Format (only "STANDARD\#rows,#cols" is accepted), and the film orientation (LANDSCAPE or PORTRAIT) and passes this information to the CONQUEST user interface. All other information is ignored.
- The MicroPACSMMain AE creates the correct amount of Basic Grayscale or Color Image Box objects for the film page and transmits their UIDs to the remote AE in the N-CREATE-RSP. The UIDs contain information about the page number, number of rows and columns, and the image location on the page that will be used by the CONQUEST user assemble the printed page.
- The remote AE will use N-SET to fill each Image Box object.
- The MicroPACSMMain AE will store each incoming Image Box onto disk (in directory "printer_files" on device MAG0) and responds with N-SET-RSP. The name (UID) of the files is passed to the CONQUEST user interface.

- The CONQUEST user interface (Windows only) will queue incoming images and will asynchronously convert each DICOM file into a BMP file, load it in memory and assemble the pictures to be printed on a page. Processed DICOM files and BMP files are deleted. *Note: the basic print support in the CONQUEST user interface will not handle multiple simultaneous print requests correctly!*
- The remote AE will request printing of each film or of the complete session using an N-ACTION command for a basic film session or a basic film box.
- The MicroPACSMMain AE passes these requests onto the CONQUEST user interface and responds with an N-ACTION-RSP.
- The CONQUEST user interface (Windows only) prints the pages on the default Windows printer. The only way to configure this printer is to change its default document settings in Windows. Printing progress is shown using a simple progress bar on the server status page.
- The remote AE may query the printer status with a N-GET request on the printer object.
- The MicroPACSMMain AE will always respond with a N-GET-RSP with a “NORMAL” status and the name of the printer, which is pre-set to “Conquest dicom printer”.
- Other N-DELETE, N-SET, and N-EVENTREPORT requests are acknowledged with an adequate RSP and ignored.
- Some logging of activity occurs.

Web access:

- The remote client will request a web page from cgi-application dgate.exe
- The cgi-application will fill a page with information. Patient information is requested over a private DICOM protocol (e.g., query2 or patientlister) from the main server to fill tables. Furthermore links may be added to:
 - GIF, BMP or JPG images
 - Viewer controls
- Links to GIF/BMP/JPG images will access the cgi-application, which in turn will request them from the main server over a private DICOM protocol. The main server is responsible for converting DICOM to GIF/BMP/JPG.
- The links to the viewer controls (OCX or Java) have two purposes. First the control will be downloaded and installed in the web viewer. This requires reduced security settings (trusted site), download of Java and/or installation of the OCX control with regsrv32.exe. Then the viewer controls will request DICOM images as needed from the cgi-application, which in turn will request these from the main server over a private DICOM protocol. The main server is responsible for (de)compressing and optionally downsizing the DICOM images.

```

client      -> webserver      url      http://127.0.0.1/scripts/dgate.exe?mode=seriesviewer&series=...
webserver  -> dicomserver     query   imagelister:CONQUESTSRV1|.....
client     <- webserver <- dicomserver query results      (to build list of urls of dicom slices)

client      <- webserver      activex control http://127.0.0.1/ActiveFormProj1.ocx

Then for each slice that is required:

control     -> webserver      url      http://127.0.0.1/scripts/dgate.exe?mode=dicom&slice=.....
webserver   -> dicomserver     request  convert_to_dicom:....
control     <- webserver <- dicomserver dicom data

```

A.2 AE SPECIFICATIONS

A.2.1 AE1 Specification

This Application Entity provides Standard Conformance to the following
DICOM
v3.0 SOP Classes as an SCU:

SOP Class Name	SOP Class UID
Verification (Echo)	1.2.840.10008.1.1
* Unknown IOD Storage	* See note

NOTE: This MicroPACS will initiate outgoing DICOM C-STORE requests masquerading as any stored IOD module. The behavior of this outgoing association link will be like the DICOM defined SCU role: Storage Service Class.

This Application Entity provides Standard Conformance to the following
DICOM v3.0 SOP Classes as SCP:

SOP Class Name	SOP Class UID
Verification (Echo)	1.2.840.10008.1.1
Patient Root Query/Retrieve Info. Model -FIND	1.2.840.10008.5.1.4.1.2.1.1
Patient Root Query/Retrieve Info. Model - MOVE	1.2.840.10008.5.1.4.1.2.1.2
Study Root Query/Retrieve Info. Model -FIND	1.2.840.10008.5.1.4.1.2.2.1
Study Root Query/Retrieve Info. Model - MOVE	1.2.840.10008.5.1.4.1.2.2.2
Patient Study Only Query/Retrieve Info. Model -FIND	1.2.840.10008.5.1.4.1.2.3.1
Patient Study Only Query/Retrieve Info. Model - MOVE	1.2.840.10008.5.1.4.1.2.3.2
Basic Grayscale Print Management Meta SOP Class	1.2.840.10008.5.1.1.9
Basic Color Print Management Meta SOP Class	1.2.840.10008.5.1.1.18
Modality WorkList Query	1.2.840.10008.5.1.4.31
* Unknown IOD Storage	* See note

NOTE: This MicroPACS will accept any incoming DICOM C-STORE request sent using the DICOM defined SCP role: Storage Service Class. The dgatesop.lst file (see configuration section and dicom.ini file) can be used to selectively restrict this ability.

A.2.1.1 Association Establishment Policies

A.2.1.1.1 General

The DICOM Application Context Name (ACN) that is always proposed is:

Application Context Name	1.2.840.10008.3.1.1
---------------------------------	----------------------------

The Maximum Length PDU negotiation is included in all association establishment requests. The maximum length PDU for an association initiated by the NetMain AE is:

Maximum Length PDU	16Kbytes
---------------------------	-----------------

The SOP class Extended Negotiation is not supported and ignored.

There is no limit on the maximum number of Presentation Contexts Items that will be proposed. In this implementation, each Abstract syntax will be proposed with either a single Transfer Syntax, or with a few JPEG transfer syntaxes, depending on the configuration in *acrnema.map*.

The user info items sent by this product are:

- Maximum PDU Length
- Implementation UID
- Implementation Version

Note: Max PDU length is not configurable at run time.

A.2.1.1.2 Number of Associations

MicroPACSMMain AE will initiate one DICOM association to perform image store for each concurrently incoming C-MOVE request.

There is no artificial maximum placed on the number of simultaneous DICOM associations open at one time. It should be noted that system response time will be degraded, and this could possibly adversely effect a time-out period on other remote AE's.

The Print Management function will correctly handle multiple simultaneous associations, but the elementary print support in the CONQUEST user interface will not correctly print (i.e., images on the pages will be mixed up) when multiple print jobs are sent simultaneously.

A.2.1.1.3 Asynchronous Nature

Asynchronous mode is not supported. All operations will be performed synchronously.

A.2.1.1.4 Implementation Identifying Information

The Implementation UID allows unique identification of a set of products that share the same implementation.

The Implementation UID for this ID/Net v3.0 Implementation is:

Storage & Q/R UID	1.2.826.0.1.3680043.2.135.1066.101
------------------------------	---

A.2.1.2 Association Initiation by Real-World Activity

A.2.1.2.1 Proposed Presentation Contexts

Presentation Context Table – Proposed					
Abstract Syntax & configuration		Transfer Syntax		Role	Expanded Negotiation
*Unknown	un,as,n1..n4,uj,nj	Little Endian	1.2.840.10008.1.2	SCU	None

*Unknown	j3..j6	JPEGBaseLine1	1.2.840.10008.1.2.4.50	SCU	None
*Unknown	j3..j6	JPEGExtended2and4	1.2.840.10008.1.2.4.51	SCU	None
*Unknown	j5	JPEGSpectralNH6and8	1.2.840.10008.1.2.4.53	SCU	None
*Unknown	j6	JPEGFullNH10and12	1.2.840.10008.1.2.4.55	SCU	None
*Unknown	j2	JPEGLosslessNH14	1.2.840.10008.1.2.4.57	SCU	None
*Unknown	j1, j2	JPEGLossless	1.2.840.10008.1.2.4.70	SCU	None

Note: Due to the morphing nature of the outgoing SSC-SCU engine, the specific Abstract Syntax that is proposed depends upon the nature of the stored image. The actual proposed Transfer Syntaxes depend on the configuration in *acrnema.map* and are the same for each class of stored images.

A.2.1.2.1.2 SOP Specific Conformance Statement for Image Storage SOP Class

This implementation can perform multiple C-STORE operations over a single association.

Upon receiving a C-STORE confirmation containing a successful status, this implementation will perform the next C-STORE operation. The association will be maintained.

Upon receiving a C-STORE confirmation containing an Error, Refused or Warning status, this implementation will fail the specific IOD in question. If more images need to be sent, they will be sent in the same association.

A.2.1.2.2 Association Acceptance Policy

A.2.1.2.2.1 Real-World Activity

This AE accepts associations for the Query/Retrieve (Q/R) SOP using the Patient Root, Study Root, and Patient/Study Only Query Model.

This AE accepts associations for the Image Storage Class using any defined IOD class.

This AE accepts associations for the Verification Service Class.

This AE accepts associations for the Print Service Class.

This AE accepts associations for the WorkList Query Service Class.

A.2.1.2.2.2 Real-World Activity

This AE is indefinitely listening for Q/R, Storage Class, Verification and Print Management associations

A.2.1.2.2.3 Proposed Presentation Contexts

Presentation Context Table – Accepted					
Abstract Syntax		Transfer Syntax		Role	Expanded Negotiation
Patient Root Query/Retrieve	1.2.840.10008.5.1.4.1.2.1.1	Little Endian	1.2.840.10008.1.2	SCP	None

Info. Model – FIND					
Patient Root Query/Retrieve Info. Model – MOVE	1.2.840.10008.5.1.4.1.2.1.2	Little Endian	1.2.840.10008.1.2	SCP	None
Study Root Query/Retrieve Info. Model – FIND	1.2.840.10008.5.1.4.1.2.2.1	Little Endian	1.2.840.10008.1.2	SCP	None
Study Root Query/Retrieve Info. Model – MOVE	1.2.840.10008.5.1.4.1.2.2.2	Little Endian	1.2.840.10008.1.2	SCP	None
Patient/Study Only Query/Retrieve Info. Model – FIND	1.2.840.10008.5.1.4.1.2.3.1	Little Endian	1.2.840.10008.1.2	SCP	None
Patient/Study Only Query/Retrieve Info. Model – MOVE	1.2.840.10008.5.1.4.1.2.3.2	Little Endian	1.2.840.10008.1.2	SCP	None
Modality WorkList Query	1.2.840.10008.5.1.4.31	Little Endian	1.2.840.10008.1.2	SCP	None
Basic Grayscale Print Management Meta SOP Class	1.2.840.10008.5.1.1.9	Little Endian	1.2.840.10008.1.2	SCP	None
Basic Color Print Management Meta SOP Class	1.2.840.10008.5.1.1.18	Little Endian	1.2.840.10008.1.2	SCP	None
*Unknown	*Unknown	Little Endian*	1.2.840.10008.1.2	SCP	None
Verification	1.2.840.10008.1.1	Little Endian	1.2.840.10008.1.2	SCP	None

Note: Due to the morphing nature of the incoming SSC-SCP engine, the specific Abstract Syntax accepted will depend upon the nature of the stored image, and the dgatesop.lst configuration file (of which a default version is automatically created when installing the Conquest DICOM server).

*The server can accept many transfer syntaxes as configurable by *dgatesop.lst*.

A.2.1.2.2.4 SOP Specific Conformance for Query/Retrieve FIND SOP Class SCP

The C-FIND response status values are supported as defined in DICOM v3.0 Part 4.

All Required (R) and Unique (U) Study, Series, and Image Level Keys for the Patient Root, Study Root, and Patient/Study Only Query/Retrieve Information Model are supported. Many optional (O) Keys are supported, as described later in this document.

A.2.1.2.2.5 SOP Specific Conformance for Query/Retrieve MOVE SOP Class SCP

Prioritization of C-FIND & C-MOVE requests is all set to normal - 0.

All images requested in a single C-MOVE will be sent over a single association (the association will not be re-established for each image).

A.2.1.2.2.6 SOP Specific Conformance for “Unknown” Storage SCP

The specific Storage SCP classes accepted are programmable (by the user) at runtime, and cannot be explicitly stated here.

No optional elements are discarded.

The duration of the storage is temporary. Least recently added patients are deleted when the disk space is less than the amount specified in the “Cleanup disk space below (MB)” field in the Conquest DICOM server. This amount is run-time configurable. When the DICOM server is connected to a, e.g., jukebox archival system, the duration of storage can be made permanent.

A.2.1.2.2.7 Presentation Context Acceptance Criterion

No criterion.

A.2.1.3 Transfer Syntax Selection Policies

The server can accept most transfer syntaxes as configurable by *d gatesop.lst*. Outgoing connections can be made over uncompressed, loss-less or lossy JPEG transfer syntaxes. If so, the images are recompressed to conform to the accepted transfer syntax. The configuration is done through *acrnama.map*.

Configuration	Proposed transfer syntaxes	Name
un ¹ , as ² , n1..n4 ³ , nj ⁴ , uj ⁴	1.2.840.10008.1.2	ImplicitLittleEndian
j1	1.2.840.10008.1.2.4.70	JPEG Lossless sv1
	1.2.840.10008.1.2	ImplicitLittleEndian
j2	1.2.840.10008.1.2.4.57	JPEG Lossless sv 6
	1.2.840.10008.1.2.4.70	JPEG Lossless sv1
	1.2.840.10008.1.2	ImplicitLittleEndian
j3, j4	1.2.840.10008.1.2.4.51	JPEG extended (12 bits)
	1.2.840.10008.1.2.4.50	JPEG baseline (8 bits)
	1.2.840.10008.1.2	ImplicitLittleEndian
j5	1.2.840.10008.1.2.4.53	JPEG spectral selection
	1.2.840.10008.1.2.4.51	JPEG extended (12 bits)
	1.2.840.10008.1.2.4.50	JPEG baseline (8 bits)
	1.2.840.10008.1.2	ImplicitLittleEndian
j6	1.2.840.10008.1.2.4.55	JPEG progressive
	1.2.840.10008.1.2.4.51	JPEG extended (12 bits)
	1.2.840.10008.1.2.4.50	JPEG baseline (8 bits)
	1.2.840.10008.1.2	ImplicitLittleEndian

Note: The transfer syntaxes are listed in order of priority. I.e., if a host is configured as j1 and it accepts JPEG lossless, the image will be lossless JPEG compressed before transmission, even if it was not stored in that way.

- 1) un = uncompressed. Images will be decompressed prior to transmission.
- 2) The configuration “as” will transmit images as-is. Independent of how images are stored on disk (with JPEG or NKI compression), they will be

transmitted over an ImplicitLittleEndian connection. This behavior does not conform to the DICOM standard and for many hosts this may therefore not work. NKI clients will work, though.

3) Configurations n1..n4 will transmit images with NKI private compression, which can only be read by NKI clients.

4) nj = nki compressed, leave jpeg as is; uj = uncompressed, leave jpeg as is

A.3. COMMUNICATION PROFILES

A.3.1 Supported Communication Stacks (parts 8,9)

DICOM Upper Layer (Part 8) is supported using TCP/IP.

A.3.2 OSI Stack

OSI stack not supported.

A.3.3 TCP/IP Stack

The TCP/IP stack is inherited from the Windows/Linux operating System.

(Conquest addition): We have used the excellent Delphi TCP/IP components from François Piette (<http://www.overbyte.be>) in the CONQUEST user interface.

A.3.3.1 API

Developers can base client programs on **TEST.EXE** and **DICOMP.EXE** that are included with source code in the **DICOMLIB1415a.ZIP** release file. The actual DICOM server (with many options) is **DGATE.EXE** that is included with source code in release file **DGATE1415.ZIP** and **DICOMLIB1415.ZIP**. Source code of the Windows user interface, client DLL and web viewer OCX is *not* included.

A.3.3.2 Physical Media Support

Any Windows (Linux) supported physical media.

A.3.4 Point-to-Point Stack

A 50 pin ACR-NEMA connection is not supported.

A.4. EXTENSIONS / SPECIALIZATION / PRIVATIZATIONS

VR (0x7fdf, 0x0010) contains compressed pixel data if NKI compression is used. In the normal configuration, the server will never transmit NKI compressed data, but will compress and decompress the data on the fly. The following presentation contexts have been added to allow NKI private compressed data to be transmitted and to allow retrieval of downsized images for higher speed:

1.2.826.0.1.3680043.2.135.1066.5.1.4.1.2.1.2	PatientRootRetrieveNKI
1.2.826.0.1.3680043.2.135.1066.5.1.4.1.2.2.2	StudyRootRetrieveNKI
1.2.826.0.1.3680043.2.135.1066.5.1.4.1.2.3.2	PatientStudyOnlyRetrieveNKI

These contexts contain sub-classed versions of the standard C-MOVE commands with the following additional optional control parameters (numbers are hexadecimal):

(9999, 0100): MaxVrSize	Do not send VRs larger than this number of bytes
(9999, 0200): MaxRowsColumns	Downsize image to maximal this #rows and columns
(9999, 0201): Frame	If given, return only the selected frame of a MF object
(9999, 0300): ConsoleText	Text will be printed to server console
(9999, 0400): Silent	If sent, console does not log transaction


(9999, 0500): MaxSlices	Also used internally by GUI and WEB interface
(9999, 0600): MaxCompression	Send at most # slices irrespective of query result
(9999, 0700): Recompression	Maximum supported compression by NKI client (default 4)
	Recompress style NKI or JPEG (default none)

SECTION 3 DEFAULT QUERY/RETRIEVE INFORMATION MODEL DEFINITION


This section describes the subset of the DICOM v3.0 Patient Root, Study Root, and Patient/Study Only, Query/Retrieve Information Model Definition used by this product.

3.0 INTEROPERABILITY SCHEMA


3.0.1 PATIENT ROOT QUERY/RETRIEVE ENTITY RELATIONSHIP



3.0.2 STUDY ROOT QUERY/RETRIEVE ENTITY RELATIONSHIP



3.0.3 PATIENT/STUDY ONLY QUERY/RETRIEVE ENTITY RELATIONSHIP



3.1 ENTITY DESCRIPTIONS

See DICOM Standard Part 4

3.2 PATIENT ROOT QUERY/RETRIEVE INFORMATION OBJECT DEFINITION

3.2.1 Patient Level Keys for Patient Root Query/Retrieve Information Model

Attribute Name	Element Tag	Type	Notes
Revision: 10 (plus computed items)			
Patient Name	(0010,0010)	R	
Patient ID	(0010,0020)	U	
Patient Birth Date	(0010,0030)	O	
Patient Sex	(0010,0040)	O	Computed* - not database
Number of Patient Related Studies	(0020,1200)	O	
Number of Patient Related Series	(0020,1202)	O	Computed* - not database
Number of Patient Related Instances	(0020,1204)	O	Computed* - not database

*requires setting EnableComputedFields = 1 in dicom.ini

3.2.2 Study Level Keys for Patient Root Query/Retrieve Information Model

Attribute Name	Element Tag	Type	Notes
Revision: 17 (plus computed items)			
Study Instance UID	(0020,000D)	U	
Study Date	(0008,0020)	R	
Study Time	(0008,0030)	R	
Study ID	(0020,0010)	R	
Study Description	(0008,1030)	O	
Accession Number	(0008,0050)	O	
Referring Physician	(0009,0090)	O	
Patients Age	(0010,1010)	O	
Patients Weight	(0010,1030)	O	
Study Modality	(0008,0061)	O	Multiple entry item, automatically updated by server Computed* - not database
Number of Study Related Series	(0020,1206)	O	
Number of Study Related Instances	(0020,1208)	O	Computed* - not database

*requires setting EnableComputedFields = 1 in dicom.ini

3.2.3 Series Level Keys for Patient Root Query/Retrieve Information Model

Attribute Name	Element Tag	Type	Notes
Revision: 17 (plus computed items)			
Series Instance UID	(0020,000E)	U	
Series Number	(0020,0011)	R	
Series Date	(0008,0021)	R	

Series Time	(0008,0031)	R	
Series Description	(0008,103E)	O	
Modality	(0008,0060)	O	
Station Name	(0008,1010)	O	
Institution	(0008,0080)	O	
Patient Position	(0018,5100)	O	
Contrast Bolus Agent	(0018,0010)	O	
Manufacturer	(0008,0070)	O	
Model Name	(0008,1090)	O	
Body Part Examined	(0018,0015)	O	
Protocol Name	(0018,1030)	O	
Frame of Reference UID	(0020,0052)	O	Computed* - not database
Number of Series	(0020,1209)	O	
Related Instances			

*requires setting EnableComputedFields = 1 in dicom.ini

3.2.4 Image Level Keys for Patient Root Query/Retrieve Information Model

Attribute Name	Element Tag	Type	Notes
Revision: 13			
SOP Instance UID	(0008,0018)	U	
SOP Class UID	(0008,0016)	O	
Image Number	(0020,0013)	O	
Image Date	(0008,0023)	O	
Image Time	(0008,0033)	O	
Echo Number	(0018,0086)	O	Multiple entry item
Number Of Frames	(0028,0008)	O	
Acq Date	(0008,0022)	O	
Acq Time	(0008,0032)	O	
Receiving Coil	(0018,1240)	O	
Acq Number	(0020,0012)	O	
Slice Location	(0020,1041)	O	
Samples Per Pixel	(0028,0002)	O	
Photometric Interpret.	(0028,0004)	O	
Rows	(0028,0010)	O	
Columns	(0028,0011)	O	
Bits Stored	(0028,0101)	O	
Image Type	(0008,0008)	O	Multiple entry item
Image ID	(0054,0400)	O	

3.3 STUDY ROOT QUERY/RETRIEVE INFORMATION OBJECT DEFINITION

3.3.1 Study Level Keys for Study Root Query/Retrieve Information Model

Attribute Name	Element Tag	Type	Notes
Revision: 17 (plus computed items)			
Patient Name	(0010,0010)	O	
Patient ID	(0010,0020)	O	

Patient Birth Date	(0010,0030)	O	
Patient Sex	(0010,0040)	O	
Study Instance UID	(0020,000D)	U	
Study Date	(0008,0020)	R	
Study Time	(0008,0030)	R	
Study ID	(0020,0010)	R	
Study Description	(0008,1030)	O	
Accession Number	(0008,0050)	O	
Referring Physician	(0009,0090)	O	
Patients Age	(0010,1010)	O	
Patients Weight	(0010,1030)	O	
Study Modality	(0008,0061)	O	Multiple entry item – automatically updated by server Computed* - not database
Number of Study Related Series	(0020,1206)	O	
Number of Study Related Instances	(0020,1208)	O	Computed* - not database

*requires setting EnableComputedFields = 1 in dicom.ini

3.3.2 Series Level Keys for Study Root Query/Retrieve Information Model

See Section 3.2.3

3.3.3 Image Level Keys for Study Root Query/Retrieve Information Model

See Section 3.2.4

3.4 PATIENT/STUDY ONLY QUERY/RETRIEVE INFORMATION OBJECT DEFINITION

3.4.1 Patient Level Keys for Patient/Study Only Query/Retrieve Information Model

See Section 3.2.1

3.4.2 Study Level Keys for Patient/Study Only Query/Retrieve Information Model

See Section 3.2.2

3.5 MODALITY WORKLIST QUERY INFORMATION OBJECT DEFINITION

3.5.1 Keys for Modality Worklist Query Information Model

Attribute Name	Element Tag	Type	Notes
Revision: 17			
Accession Number	(0008,0050)	O	Primary Key
Patient ID	(0010,0020)	R	
Patient Name	(0010,0010)	R	
Patient Birth Date	(0010,0030)	O	
Patient Sex	(0010,0040)	O	
Medical Alerts	(0010,2000)	O	
Contrast Allergies	(0010,2110)	O	
Study Instance UID	(0020,000D)	O	
Requesting Physician	(0032,1032)	O	
Requested Procedure Description	(0032,1060)	O	
Requested Procedure Code Sequence	(0032,1064)	R	1 instances of this sequence required
>Modality	(0008,0060)	R	
>Requested contrast agent	(0032,1070)	O	
>Scheduled AE	(0040,0001)	R	
>Start date	(0040,0002)	R	
>Start time	(0040,0003)	R	
>Performing Physician	(0040,0006)	R	
>Scheduled Procedure Step Description	(0040,0007)	O	
>Scheduled Procedure Step ID	(0040,0009)	O	
>Scheduled Station Name	(0040,0010)	O	
>Scheduled Procedure Step Location	(0040,0011)	O	
>Premedication	(0040,0012)	O	
>Scheduled Procedure Step Comments	(0040,0400)	O	
Requested Procedure ID	(0040,1001)	O	
Requested Procedure Priority	(0040,1003)	O	
Character set	(0008,0005)	*	Returned as "ISO_IR 100" only when WorkListReturnsISO_IR_100 is set

To code this information into a database, the contents of the sequence are unfolded to the same level as the other fields. *This field will be optionally returned whether requested or not

4.1 FILES

Installation files (in DicomServer1415.zip):

windowsmanual.pdf	Documentation
<u>DicomConformance FilesLST Changes.pdf</u>	
conquestdicomserver.exe	User interface
dgate.exe	console mode version of MicroPACS system
dgate64.exe	Idem for 64 bits (automatically selected)
dgate.dic	DICOM dictionary for dgate.exe
cqdicom.dll	Conquest DICOM client DLL.
dgateserv.exe	NT service wrapper for dgate.exe
zipdll.dll	ZipMaster DLL zips log files (optional, else uses 7za.exe)
libmysql.dll	Mysql client dll for 5.0.22
libmysql.txt	Mysql license text
libpq64.dll	64 bit client DLL for postgres (hard to find)
dcmjpeg.exe	OFFIS DICOM toolkit jpeg compression utility v3.5.4
dcmjpeg.txt	description of this utility
dcmdjpeg.exe	OFFIS DICOM toolkit jpeg decompression utility v3.5.4
dcmdjpeg.txt	description of this utility
offis.txt	OFFIS copyright notice
7za.exe	7-zip command line version
<u>7za.txt</u>	<u>7-zip license text</u>
<u>sample.hl7</u>	<u>Example HL7 input file</u>
webserver\ActiveFormProj1.ocx	ActiveX web viewer
webserver\conquest.jpg	conquest logo for on web page
webserver\dicom.ini	sample web page configuration
webserver\sample.cq	sample scripted web page
<u>webserver\dgate.exe</u>	<u>same as above, here used as CGI application</u>
data\HEAD_EXP_00097038\ 0001_002000_892665661.v2	
data\HEAD_EXP_00097038\ 0001_003000_892665662.v2	

Configuration files (automatically generated):

dicom.ini	Configuration file
dicom.sql	Database table definition file
acrnema.map	System/IP map file
dgatesop.lst	SOP Class definition file
USE.....	Determines database driver to be installed

Database files (automatically generated, example for DBASEIII):

data\dbase\Dicompatients.dbf	patient database table
data\dbase\Dicomstudies.dbf	study database table
data\dbase\Dicomseries.dbf	series database table
data\dbase\Dicomimages.dbf	image database table
data\dbase\Dicomworklist.dbf	worklist database table
data\dbase\XDicompatients.dbf	extract of database table used by browser for dbaseIII
data\dbase\XDicomstudies.dbf	extract of database table used by browser for dbaseIII
data\dbase\XDicomseries.dbf	extract of database table used by browser for dbaseIII
data\dbase\XDicomimages.dbf	extract of database table used by browser for dbaseIII
data\dbase\XDicomworklist.dbf	extract of database table (not used)
data\dbase\testtable.dbf	not used
data\dbase\UIDMODS.dbf	used for changing Patient ID and anonymizing

Log files (automatically generated):

Installation.log	information from installation page
Maintenance.log	information from maintenance page
ServerStatus.log	information from server status page or service
PacsTrouble.log	relevant errors
PacsUser.log	all users who accessed the server
ConquestDicomServer.log	log about main actions and server start/stop
logs_yyyymmdd.zip	automatically zipped set of log files

Data files (automatically generated – 5678 is the servers port #):

ExportFailures5678_0	data of failed exports for later retrying
----------------------	---

CopyFailures5678 data of failed mirror copies for later retrying
 DelayedFetchForwardFailures5678 data of failed delayed forwards
 Note: The server deletes these files (or delete manual) to abort retrying

Image file (example, for FileNameSyntax parameter set to 3) :

 Dir 	PatientID	seriesUID	 series 	slice	time	counter
Data\QA_phantom\1.2.840.113619.2.22.287.1.19980710.202026_0001_0000006_9537982720005.v2						

4.2 PRODUCT INTERACTION / DESCRIPTION

- dgate.exe:** DICOM MicroPACS AE Main. This is the principal PACS application. It handles all connections (see threading model note in section 4.4 of this part). Contained in this executable are verification, storage, print, and various query and retrieve DICOM SOP classes. This executable interfaces to the PACS database via ODBC-32 v2.0, or using a built-in dBaseIII driver. In the event that disk space is low, it will optionally delete least recently entered patients. This application also contains code for installation, maintenance and archival operations that is used by the Conquest DICOM server. For these purposes a second copy of dgate.exe is started. Type “**dgate -?**” for more information. Finally, the same executable may act as CGI server application. In some rare cases, the dgate process may still be running even though the user interface has closed (after a crash or after killing it with the task manager). The user interface, when restarted, then assumes that the dgate process belongs to a service (and displays “**user interface**” in the caption), but cannot control the running process. Killing the dgate process with the task manager or rebooting will solve this problem. All source code of dgate.exe is included in **DGATE1415.ZIP** and **DICOMLIB1415.ZIP**. However, source code of the built-in JPEG decompressor is not included. To compile dgate.exe (without built-in decompressor) one can best use total.cpp (documentation included).
- dgate64.exe** Identical application for use in a 64 bits windows OS. Dgate.exe or dgate64.exe are automatically selected. Delete dgate64.exe to force use of 32 bits in a 64 bit OS.
- dgate.dic:** DICOM dictionary used by dgate.exe.
- dgameserv.exe:** Wrapper for dgate.exe to make it run as a Windows service. May be used (advanced users only) to manually (even remotely) start / stop / install / uninstall service(s). Type “**dgameserv /?**” for more information. Note that DICOM server services are named after the AE of the server. Once dgate.exe is installed as a service, the DICOM server(s) starts automatically when the computer is booted. When the user interface is started it will detect that the server is already running and connect to it. Source code is not included.
- conquestdicomserver.exe:**
This executable is the user interface and installation program and contains parts of the print server. See the installation section of this document for its functions. The database browser tries to use the Borland Database Engine. Without BDE, the server will run but with reduced filter options. Source code is not included.
- cqdicom.dll:** This is code for the Conquest DICOM client. It is used here to display the images in the database browser, convert DICOM images for printing, list the image file header and provide query, move and echo actions. The source code of this DLL is

not included but it is based on the programs “TEST.EXE” and “DICOMP.EXE” that are included with source code.

zipdll.dll: This DLL is part of the zipmaster VCL component that is used in the server to automatically zip the log files once a day or when sending a bug report. When this file is deleted, zipping uses 7za.exe. Source code is not included.

dcmjpeg.exe: jpeg compression utility from the OFFIS DICOM toolkit DCMTK version 3.5.4. This executable is called by dgate.exe to compress DICOM images in jpeg format. Copyright (C) 1994-2005, OFFIS. This software and supporting documentation were developed by Kuratorium OFFIS e.V. Healthcare Information and Communication Systems Escherweg 2 D-26121 Oldenburg, Germany. This software is made available, as is, and OFFIS makes no warranty regarding the software, its performance, its merchantability or fitness for any particular use, freedom from any computer diseases or its conformity to any specification. The entire risk as to quality and performance of the software is with the user. Copyright of the software and supporting documentation is, unless otherwise stated, owned by OFFIS, and free access is hereby granted as a license to use this software, copy this software and prepare derivative works based upon this software. However, any distribution of this software source code or supporting documentation or derivative works (source code and supporting documentation) must include the three paragraphs of this copyright notice.

dcmdjpeg.exe: jpeg decompression utility from the OFFIS package version 3.5.4. This executable is called by dgate.exe to decompress DICOM images in jpeg format if UseBuiltInDecompressor in dicom.ini is set to 0. See further dcmjpeg.exe.

Libmysql.dll: When present, provides native access to MySQL, both for GUI and the server core. Redistributed because binary compatibility is required between compiled applications and the interface DLL: i.e. this file has to be of a specific version, even if it is used to communicate with MySQL databases of other versions. Comes from <http://downloads.mysql.com/archives/mysql-5.0/mysql-noinstall-5.0.22-win32.zip>

Libmysql64.dll: provides native access to MySQL for 64 bits server core

Libpq64.dll: provides (hard to find) native access to PostGres for 64 bits server core. Comes from: <http://forum.manifold.net/forum/t49971.21>. Note: the 32-bit PostGres client DLL's are not included in the distribution and must be taken from the bin folder of your PostGres distribution.

7za.exe: 7-zip command line version: used by the server core to unzip dropped zip files with dicom files or as alternative for zipdll.dll.

Web server (place these 5 files in your web server):

Cgi-bin/Dgate.exe: exactly the same dgate.exe as in the server.

Cgi-bin/Dicom.ini: specialized ini file for server running as web(cgi) client.

Cgi-bin/sample.cq: Sample of script-based web page

Htdocs/ActiveFormProj1.ocx: Optional ActiveX web viewer, to be registered manually or downloaded from your web server and installed.

Htdocs/conquest.jpg: Icon for use on the web pages

4.3 THREADING ARCHITECTURE

The MicroPACS system was designed to run in two multithreading models. The first model is "Multithreaded", the second is "Multiprocess". The Multithreaded model can best be described as a monolithic application. Each incoming DICOM association is allocated a separate thread of execution within the same memory and address space of the master process. These threads share the same code within the single (monolithic) executable. The Multiprocess model is similar to "inet" on UNIX operating systems. There is a controlling application (conquestdicomserver.exe) which handles incoming TCP/IP connections. For each connection, a new copy of the MicroPACS main executable (dgate.exe) is loaded and executed. A separate process that runs in a separate address space from all other associations handles each DICOM association.

The multithreaded application is slightly faster than the multiprocess one; But the multiprocess one is more secure, and should be more reliable. Because each process runs in it's own address space, an association from one connection cannot corrupt or undermine (in any possible way) another simultaneous association. For this reason, the default installation of the MicroPACS was the multiprocess model.

However, extensive testing of the Conquest DICOM server showed that the multiprocess version sometimes failed to work correctly on Windows (some ODBC problem). For this reason, the multithreaded version is currently used with the Conquest DICOM server. Several fixes have increased its speed and made it very reliable.

Also, the built-in DBASEIII driver applies in-memory indexing and depends on the server process staying in memory to achieve a high speed. In the Linux version, the built-in DBASEIII driver, SQLite, PostGres and MySQL are the database drivers available.

APPENDIX 1.

Fixes, modifications and extensions of MicroPACS by Marcel van Herk and Lambert Zijp of the Conquest project:

DICOM.SQL (Database definition):

19980624	StudyNumber (StudyID in DICOM) is now 64 long Required for correct operation with SQL server
19990109	Made imagenumber 10 characters wide
19991222	Moved MODALITY to the series level (for DICOM-RT)
19990315	Added EchoNumber and NumberOfFrames in image table
20010830	Revision to 4, extended database significantly
20010416	Revision 5: Added patientID in series and images for more efficient querying
20010416	Revision 6: Added frame of reference UID in series table
20020519	Revision 7: Added ImageType in image table, StudyModality to 64 chars, AcqDate to SQL_C_DATE
20021028	Revision 8: Denormalized study table (add patient ID, name, birthdate) to show consistency problems. Revision 9 is a further de-normalized version that is used with the built-in DbaseIII driver.
20030319	Revision 10: Fixed width of ReceivingCoil: to 16 chars
20030907	Note: revisions 9, 11 and 12 refer to the ODBC-less version
20040402	Revision 13: Added ImageID to image database
20040905	Revision 14: Added WorkList database with HL7 tags
20080124	Revision 15: Added patient position to denormalized image table for built-in DBF driver');
20080124	Revision 16: Moved Stationname and InstitutionalDepartmentName to series table');
20080818	Revision 17: EchoNumber, ReqProcDescription to 64 characters; StudyModality, EchoNumber, ImageType to DT_MSTR; use Institution instead of InstitutionalDepartmentName');

DGATE.CPP (main of DGATE.EXE):

19980327:	Disable logfile for speed and save disk
19980327:	-! Enables logging to Personal pacs console; RunServer works; -p breaks
19980327:	All printf's to systemdebug
19980320:	Integrated dumppacs code here for convenience
19980320:	Fixed -p option; SaveToDisk returns filename, printed in stats
19980320:	Documented and added print of usage (-? option)
19980404:	Added test options, ODBC config option and command line specified console pipe / udp logging
19980409:	added FileCompressMode option; use local save to disk code instead of pdu member
19980409:	Return on failed GenerateFileName in SaveToDisk
19980409:	Cleaned up NKI private compression code and allow >15 bit differences
19980410:	Added run length encoding for equal pixels to compressor; fix 3-byte case

19980415: Cleaned up the messages; -! does not enable debug; do not enable accessupdates (use aroute)
 19980618: Some work on manual and database layout listing
 19980621: Added -z option: zap patient
 19980624: Comm test also produces systemdebug and long text output; added \n to some output
 19980625: SaveDicomDataObject in loadddo.cpp supports NKI private compression
 19980704: Added some test code for counting disk space and renaming device for patient
 19980705: Added CACHE devices in free store check; added FindPhysicalDevice (searches for file)
 19980709: Added archiving options: -as, -au, -ab, -ac, -ad
 19981217: Temporary use PDU.Save... code for testing DICOM objects (does not compress)
 19981218: Temp use Pdu.Load as well (no compression)
 19981228: Disabled ljz's code until it has been completed
 19990108: Reenabled ljz's code: Replace uncompressed by compressed pixeldata VR in SaveToDisk (it seemed to work anyway...)
 19990109: Removed some commented out code; added comments for alternative load and save routines. Added Regen of specified device
 19990110: Added n, for MAGn, as parameter in -as and -ab archiving options (default all). Use exit(1) on failure
 19990111: Fixed exit code on -ar option
 19990117: If the filename is *.dcm (depends on FileNameSyntax) use uncompressed chapter 10 format
 19990317: Added NKI-private stuff
 19990628: Temporary enabled debug in -!nnnn option
 19990630: Added MIRROR option; disabled debug in -!nnnn option
 19990707: Fixed MIRROR option; added MIRROR message; added check on FindPhysicalDevice result
 19990817: Added ability to spawn ExportConverters at the end of SaveToDisk
 19990827: Optimized read of slices: cache a DB to pass to GetFileName (10% faster)
 19991117: Added parameter FileCompressMode to in nki_private_compress call
 20000318: Added private command object 9999, 0300 = print to console
 Added private command object 9999, 0400 = force C-Echo to be 'silent' (no log). Display C-Move Destination; print time info about threads
 20000323: Serious fix: MainThread 'hangs' when several associations occur simultaneously, caused by compiler-optimization. Solution: DriverApp.Lock should be 'volatile'.
 20000329: On request by ljz: designed crash of server if silent VR receives 'DEAD'
 20000501: Compare dicom modality with UPPER-case ini-file setting (ExportConverters)
 20000621: Initialize TroubleLogFile and UserLogFile; log C-STORE and C-MOVE
 20000703: Logging of trouble now starts with '***'
 20000703: Exclude archival messages from trouble log; removed force dcm code
 20001104: Added WINAPI to thread routines

- 20001105: Replaced malloc by new where a mix could occur (vr->data)
Made compilable for MSC and BC and WC using some #ifdefs
Changed order of verification and store; better localized
new/delete DDO more
- 20001106: Run-time load odbcinstr routine for BC and WC, use spawn...
i/s/o _spawn...
- 20001106: Use delete [] operation for vr->Data
- 20010328: Added -av: verify mirror disk
- 20010415: Added DeleteSeries, DeleteStudy and DeleteImage routines
and -f options
- 20010416: Added -f options: -feFile = enter MAGN file into DB, -fdFile =
delete file from DB -faFile = add (also makes copy) file into
server, -f?=ask UID of file, -fu = generate UID, -
fcNEWPATID,file = modify patient ID of image file (moves
file!). NOTE: -fc is irreversible in the sense that if a portion of
a study/series is changed and changed back it winds up as a
different study/series. This occurs because the UIDs must be
changed for each image modification. This problem does not
occur when a whole series or study is changed
- 20010417: Simplified code to change uids to allow easy extension to
referenced SOPs. Check after load on common UIDs to avoid
accepting dropped non-dicom files. NOTE: ChangeUIDinDDO
should also change sequences and referenced SOPs
(0008,1155)
- 20010418: Fix in above change
- 20010418: Changed names of database fields in UIDMODS - did not work
on MsAccess
- 20010419: Added -fk option: copy image file to other patient ID (as -fc but
no delete). Added version number 1.3.9 to command line help
- 20010429: Added -fz option: zap file from server and database
- 20010430: Some work on read ahead thread: note that thread must not use
any pointer copy!
- 20010502: Made read ahead thread working; fixed thread counter; fix odbcinstr
option: strings too short
- 20020506: Fixed handle leak in read ahead thread
- 20020507: Fixed memory leak in read ahead thread; kbhit() test #ifdef
DO_LEAK_DETECTION
- 20010509: Added RenameDevice is -ae option
- 20010730: Replaced parameter argv[0] of ExportConverters to proper
value.
- 20010829: Added ExportStationName as export filter; default Export...
value set to "*"; Made export comparisons case insensitive;
added special 'forward to AE' ExportConverter; Version to
1.3.10
- 20010831: Added extended syntax for exportconverters with %f=filename,
%m=modality, %s=stationname, %b=file base name, %p=file
path; Also allows 'copy %f destination', but for windows NT
only (uses cmd.exe). Added ExportFilter option that uses an
SQL statement to filter.
- 20010901: Added a simple queue to process exportconverters
asynchronously; Create a queue for each converter; queue
mirror copy requests
- 20010902: Added %o = SOP; %n = newline; added the following hard
coded converters: append "text" to file; write "text" to file;
copy file to file; copy file to dir

20010904: Re-entered change of 20010730
 20010905: Fix: After 'SaveToDisk', do not free pDDO
 20011109: Fix: made ExportConverter stuff case insensitive
 Note: empty filter tests for empty contents - this is not the same as '*'
 20011110: Note: in release 1.3.10, the " to " in e.g., write "%f%n" to file must be lowercase
 20011115: Made " to" case insensitive; Added *** before some error messages for better logging. Removed cache db: would hang the server if SQL has gone down and up. Now use one DB per thread which is passed to the read ahead thread = fast too!
 20011207: Added extra error message when creation of datasource fails
 20020109: Disabled this code for watcom or borland (instead of run-time loading an address)
 20020314: Implemented ignore of C-CANCEL request for ADAC NM (was error before). Blocked out SQLInstallerError call; does not compile on clinical MS4.2
 20020413: Added some notes about thread safety and db's: The serverchild is not thread safe when reading and writing is done on the same association.
 20020415: Added -atDEVICE option: sanity check of images on disk; version to 1.3.11
 20020416: Made UID generator configurable through UIDPrefix in dicom.ini; made time print unsigned
 20020422: Sleazy fix of ModifyPatID: time(null) created same UID: now wait 1 s per changed file
 20020426: Generate filename no longer gives an error: is done at higher level
 20020428: Only serious error messages use *** in message
 20020428: Added FAILSAFE_STORAGE: tries to save incoming files even when DB errors occur
 20020429: Put SaveToDisk in myUnknownStorage: pass DB failures to caller; Disabled FAILSAFE_STORAGE: any storage failures should now be detected by client
 20020508: Do not rewrite image not on MAG but it is not an error (warning is generated earlier)
 20020520: Added -gSERVER,DATE option: grab images on date from remote server
 20020521: fix displaying junk filename when rewriting image not on MAG
 20020522: Fix in SetStringVR: strings must be padded with a space
 20020529: -i and -r now have mode parameter (0=normal and default, 1=simple, e.g., for DBASEIII)
 20020531: In 'QualifyOn', support case-sensitive call to 'GetACRNema', but make AE-Title uppercase after retrieving IP and port.
 20020613: Better handling of Compression ON/OFF in 'SaveToDisk'
 Fixed crash in DeleteImageFile (twice free of VR->Data)
 20020613: compress to specified mode, check (de)compress result, decompresses data before forward; added 'export compressed to AE' export; -fa has optional ,NEWPATID syntax;
 20020802: Simplified rmdir code and allow multiple subdirectories in rmdir and mkdir code. Version to 1.3.12 (unreleased)
 20020804: Use PATHSEPCHAR where possible
 20020807: Changed SaveToDisk order: only make patientdir when DB save succeeded

20020812: Added skeleton of printer support
 20020816: Added color imagebox; Save incoming print DDO as file
 20020819: UUIDs of imageboxes end on rows.cols.position for easy print handling
 20020819: Fix in delete nonexistent mirror files for changepatientUID
 Extract pixel data from sequence in ImageBox; added sleep(10) in -fk option
 20020819: Added better UID generation (but gets close to 64 chars)
 20020821: Fix printer UID generation; display page orientation and film #; shorter info
 20021016: Added (indexed) patid to exportfilter query and getfilename for speed; The option tests for rev5 db or higher; increase 64 strings to 66; Note: GrabImagesFromServer option does not yet pass patid to the query (i.e., will be slow with non-odbc driver)
 20021017: Control NeedPack from here; added -c option: set UID counter at startup. Removed Sleep from anonymize options; do not re-create UIDMODS
 20021018: Pass NoKill through GenerateFilename for interactive DGATE
 20021028: Fix query on study in PatientStudyOnlyQuery (did an image query)
 20021105: Revamped read-ahead thread logic to try fix rare crash where ratd->DDOOutPtr became NULL
 20021115: Use Generic style retrieve classes with NKIqrsop code instead of older qrsop code. Advantages: read ahead thread used, and allows print of error messages from C-MOVE. Required changes such that ratd->pcdo can be NULL.
 20021121: Disabled read-ahead thread for time being
 20021212: Also loop ServerApp.Server(Port) in threaded mode server
 20021213: Re-entered fix by Hanne Kooy: compressed forwarding had extra ;
 20021213: Re-enabled use of generic query classes with read-ahead thread; but made read-ahead thread configurable with "EnableReadAheadThread". Made grab query faster by including date - note grab is independent of FixPhilips
 20021215: Found read-ahead thread problem reported by Aaron Cann - missing Sleep in wait for slices
 20021223: Version to 1.4.1 pre-release; added in dgatefn forbidden filename chars suggest by Thomas Buerer
 20030113: Removed loop ServerApp.Server(Port): gave endless loop error messages
 20030120: Added cleanup-code when DO_LEAK_DETECTION is defined for easy leak checking
 20030205: Fix bug found by Frank-Andre Siebert: read ahead thread crashed when ID or SOP is missing. Also fix 2 other potential missing VR problems
 20030228: Fixed bug reported by Jeff Babcock: series retrieve from E-film crashed (patid not passed)
 20030424: Changed calls to obsolete PDU.Write(&DDO). In 'SaveToDisk' the call to PDU.SaveDICOMDataObject now has parameter DICOM_CHAPTER_10_EXPLICIT (which writes IMPLICIT files if not compressed)
 20030606: Fixed incremental counter when creating UUIDs or generating filenames Fix: QueryRetrieveLevel is mandatory for a QueryResponse
 20030625: Fix NGET of BasicPrinterSOPClass

20030625: Fix in above fix

20030627: Adapted for MSC4.2; Finally really fix NGET of BasicPrinterSOPClass (wrong UID used)

20030629: Added -nd, -nc, -jd and -jc options: (de)compress NKI; (de)compress JPEG (used OFFIS executables)

20030630: Started on compression for dropped, incoming, transmitted; NKI vr 0x9999,0x700=custom compression. Added 'forward compressed as xx to ...'

20030701: QualifyOn now also has compression parameter

20030703: Moved compression code to nkiqrsop; dgate -j-xx and -j*xx = test compression options. Removed "forward compressed to" because "forward compressed as .. to" is better. Note that FileCompressMode is now obsolete. KNOWN BUG: JPEG compressed images may be rewritten as V2 (when written originally as NKI) which are then not correctly read.

20030704: Made that FileCompressMode parameter still works even though is obsolete. Moved faulty delete DDO after SOPUnknownStorage.Read

20030705: Added check of Transfer Syntax next to extension for save type; ProcessDDO takes **DDO

20030706: Use dgate.dic; Attach VRType to PDU's for implicit little endian support; small fix in dump code

20030709: Printer support fix; version to 1.4.2; Added SendUpperCaseAE parameter (default 0)

20030730: Force ImplicitLittleEndian, ExplicitLittleEndian and ExplicitBigEndian objects that must be stored in Chapter10 format, to ImplicitLittleEndian.

20030815: Version to 1.4.3

20030905: Allow longer filenames

20030910: Added check on rights to write (trouble) log file and printer_files in MAG0

20030921: Allow write to any MIRROR if MAG is full; added -ff# option: delete until # MB free

20030922: Added StorageFailedErrorCode (default 0x110 = 272 decimal = failed processing)
Added ExportCallingAE and ExportCalledAE export filters (also %u=SCU, %c=calledAE in converter)

20030401: Version to 1.4.4; pass status pointer to compress routines

20040402: Delete DDOptr when SaveToDisk cannot write but does not give an error; Added "Cannot rewrite jpeg/rle image in v2 format" check; Use system DSN for ODBC (easier login)

20040406: Always use EXPLICIT syntax for jpeg, fix v2 always use DUMP

20040426: Version to 1.4.4a

20040520: Version to 1.4.4b

20040523: Added patient ID to speed GetFileName for single slice move

20040528: Set NeedPack (controls DbaseIII indexing) for regen, archive, maintenance; Version to 1.4.4c

20040528: Added built-in maintenance commands through silent VR in ECHO; pass patid in DeleteImageFile

20040530: extract (DBF only) to database like XDicomImages in same directory; Version to 1.4.5

20040601: Added deletestudy, deleteseries and packdbf maintenance commands

20040602: Fix: 'forward compressed as' always failed

20040605: packdbf maintenance command sets NeedPack to 3: forces pack

20040606: fix rewrite to not MAG (JUKEBOX) was NOT ignored

20040607: Merged fix ljz 20040602; do not allow rename and delete with empty name

20040610: Added maintenance server tasks for archival and regeneration

20040612: Added indexdbf maintenance server task

20040614: dgate command line maintenance options use NeedPack=5: non-threaded index generation. Added -am option: move(all) device data; for selected data use -amMAG0.Archiving,MAG1

20040624: Version to 1.4.5a

20040626: Pass study and series UID to getfilename; version to 1.4.5b; Fixed leak of pats array

20040713: Version to 1.4.6

20040805: Fix in C-MOVE for single file (from jlz); version to 1.4.6b

20040909: Increased length of ExportFilter (was 64, now 510)

20041020: Added mergeseries(file) and mergestudy(file) maintenance commands, silenttext to 1024

20041101: Added deletesopfromdb maintenance command; version to 1.4.7

20041103: called, e.g., AE~nj overrides IncomingCompression to nj

20041108: Added \$c test compression mode (alt-drop files with \$c as patient ID tests compression modes)

20041109: Added \$tSERVER test compressed forward; some fixes in forward compressed to (server name read wrong)
\$s tests all filename syntaxes

20041112: Added \$rN N times repeated entry test, and \$tN which enters image N time each on its own thread

20041128: Added -^file: log to file (timestamped) instead of to server console; -#file: same with debug

20041129: Added silent commands debuglog_on and log_on to set logging to UDP or file; Added silent command read_amap to re-read acrnema.map without restarting the server

20050102: Small modifications to allow compile through total.cxx

20050107: Added code to hold and retry queued forwards and mirror copies when failed: After failed export/copy, start storing entries in file ExportFailuresN (CopyFailures). If a new export/copy is requested >1 minute after last failed one, try again; if queue is empty, >100 seconds after last fail, try export/copy stored ones. Processing queued entries has priority over processing stored entries.

20050107: Version to 1.4.8; modifications for linux compile

20050108: Added server PORT# to fail files, so that multiple servers on different ports do not share files

20050109: Added configurable TCPIPTimeOut, FailHoldOff, RetryDelay and QueueSize

20050109: Adapted thread code for linux; still need to implement WaitForSingleObject

20050111: Added ctype.h (for mingw)

20050118: Linux: crudely implemented WaitForSingleObject; detach pthreads to avoid leaks; crudely implemented export converter apps

20050119: Added grabimagesfromserver, regendir and makespace server commands; dgate -- sends server commands to other running server; adapted manual

- 20050121: Small updates to manual
- 20050124: Replaced BackgroundExec with simpler system() for Linux; added query server command, e.g., dgate "--query:DICOMpatients|patientid,patientname,patientsex|patients ex='F'|%s %s %s|t.t"; Added read_ini: server command to reread dicom.ini; changes most config except: TCPPort (busy), UseBuiltInDecompressor (cached) and FileNameSyntax (cached)
- 20050130: added get_param, get_freestore, get_amap, get_sqldef that respond through echo-response; also: get_sop, get_transfer, get_application, get_localae, get_remoteae, get_dic, forward. added: dump_header (to file), convert_to_gif (to file); adapted query (to file) where file="cgi" for stdout in cgi/mime mode, file="" to send to stdout as is; most GUI commands can now pass PatientID|SOPInstanceUID instead of filename of dicom object; added put_amap, write_amap, put_sop, put_transfer, put_application, put_localae, put_remoteae, put_param. Note: get/put_param work through disk (read_ini activates), get/put_amap through memory (write_amap writes to disk), get/put_sop etc read from memory and write to mem and disk.
- 20050204: Added delete_param, delete_amap and fix cgi out (double \n)
- 20050204: most GUI commands can now pass PatientID|?*:SOPInstanceUID; added delete sop etc commands More fixes in cgi data passing VR vr() is mostly wrong; use VR *vr=new VR()
- 20050205: Allow up to 16 output fields in query:, repeat queried fields over all 16 outputs. Added counters for server status; start on display_status server command
- 20050206: More work at display_status, renamed testtable to xtesttable: default not opened. Access ObjectFile and DeviceName through query instead of with GetFileName up to 3 x faster!! Also fixes potential leak in read ahead thread: pats, series and studies not always freed. Allow up to 32 cgi query outputs, tidied dump layout, start on web interface (put dgate and ini in cgi-bin)
- 20050207: Added query2 option: limits number of output rows as asked; gui command not counted as association. Some more work for web interface
- 20050210: Adapted web interface queries such that they run on sql server
- 20050212: Removed need for thread local storage; automatically adapt dgate extension in cgi scripts depending in OS
- 20050213: Added more parameters to server configuration web page
- 20050214: Added update button to server config (updateconfig page to be implemented)
- 20050215: Fix in LoadForGUI: Drag 'n' drop of files in the server did not work anymore. Fixed dgate crash in case of failure in 'recompress()' (pDDO=NULL when OFFIS failes). Merged
- 20050327: Added rudimentary gz unzip support for dropped files (uses 7za.exe)
- 20050401: Start on Modality WorkList Support
- 20050404: List End/Start sequence db types (only supported for worklist)
- 20050411: Fix incorrect space after filename and device in C-MOVE internal query
- 20050414: Added addrecord server command: for now only option to enter worklist entries

20050603: Fix servercommand query(2) for empty where part
 20050825: Fix web interface queries for sql server (were OK for dbase)
 20050826: More work on web interface and added worklist there;
 deleterecord command
 20050827: Fixes in addrecord and query commands,
 editworklist,saveworklist,deleteworklist
 20050829: More fixes in web interface, disable caching for most/all? of it
 20050831: Allow command line length of up to 4096, allow edit all
 worklist database fields
 20050901: Removed invalid cache-control: cache; added
 WorkListMode:0= off, 1=optional, 2=compulsory
 20050902: Read db config for worklist edit page in web interface; use
 generic webpages for db edit. Added HL7Tag in DumpDD
 20050903: Added 'simple' loadhl7: server task implementation and HL7-
 >DICOM translation. Also addimagefile will enter HL7 files
 into the server, i.e., drag and drop works
 Fix some web queries for sql server with denormalized tables
 20050904: Some more tweaks to hl7 code; max query formats to 48; max
 format to 8192
 20050905: Auto split HL7 subfields and repeats without using a list
 20050907: Merged change by Hans-Peter Hellemann: fixes extension
 problem for linux web interface for some browsers
 20050908: Protect convert_to_gif when file not found
 20051121: Recompute SQLResultLength because it does not work in
 PostGres BindField
 20051123: put in #ifdef POSTGRES
 20051208: put in #if 0 (fixed in odbci.cpp); start on virtual server: will
 grab images from other server as needed in read-ahead thread:
 when in db but not on disk; for now use R.A.T also for single
 image access to avoid code duplication
 20051209: Start on virtual query: image (!) query is passed to other server,
 results populate db
 20051210: Added "vX" incomingcompression (stores dbf but not image;
 forwarding disabled). Added virtual queries on all queries and
 moves: now works as transparant file cache. Added
 VirtualServerFor0..9 configuration entries: server merges own
 data with these AE's. Added CacheVirtualData control; if set
 data not deleted after use (db kept for now)
 20051211: Fix: override query level in virtual query
 20051212: Store virtual server # in device; saved on query, used when
 retrieving, stripped when storing
 20051214: Use different sleep lenghts under linux - not all sleep(0); small
 fix in virtual server
 20051215: Implemented a linux version of Sleep using nanosleep
 20051217: Use new VR::ReAlloc method to replace data in VR; added
 quit: command
 20051218: Use ReplaceVR instead of Push in anonymize etc; also changes
 in sequences. Version to 1.4.10; show version and exe date in
 startup log. Do not start mirror copy queue unless it is needed;
 show some thread startup info. Added -b = NOTHREAD: run
 server as single process, useful for debugging and profiling.
 Fixed doc of --regendir: command
 20051219: Fixed several small leaks - as tested with Linux malloc_stats
 20051222: Started on bypass server for virtual query - not functional yet
 (cleanup required)

Removed debugVR logic: errors should now list DCO
 20051228: Fix virtual device logic for VirtualServerFor0;
 Cleanup vr's and duplicates when bypassing server for virtual
 query, seems functional
 20051229: NonDestructiveDumpDICOMObject now also list sequences;
 DebugLevel>0 lists DCO, >1 lists query DDO; fixed leaks in
 virtual query and some others
 20051230: Added --debuglevel: command, small fix in
 NonDestructiveDumpDICOMObject
 20060103: Small fix in virtual query; disabled virtual query for worklist;
 debuglevel 3 shows some query results
 20060123: Added patient/study/seriesfinder (server parameter ignored for
 now, later for virtual servers etc)
 20060125: Added serieslister (server parameter ignored for now, later for
 virtual servers etc)
 20060128: Renamed to imagelister, added serieslister
 20060131: Sort filenames from imagelister on ImageNumber (0020,0013)
 20060226: Version to 1.4.11
 20060228: Small fix in isxdigit thanks to ljz
 20060311: Use ReplaceVR in virtual query - level was sent twice (thanks
 David Lang)
 Added WEBReadOnly flag
 20060317: Support calledae and callingae in filenamesyntax - for
 virtualquery called is always MYACRNEMA
 20060324: Strip group 2 from outgoing c-stores if not compression "as" or
 "is"
 20060328: Improved forwarder, always propose Verification and use
 IsAbstractSyntaxAccepted(iUID) to test if host accepts image
 20060402: Fix hang condition when a file failed to read in the read-ahead
 thread
 20060402: Do not remove transfer syntax prior to dcmdjpeg/dcmjpeg
 (here in test recompress only)
 20060405: Tried fix for multiple moves on same assoc (thanks Andrej
 Savelov)
 20060405: Added message when IOD fails to read
 20060603: Fix crash when started as dgate -v: empty statbuf
 20060607: Finally fixed multiple moves on same assoc (thanks Andrej
 Savelov and Fred Röhner)
 20060618: Renamed dfilecopy and define ODBC_ADD_SYS_DSN if
 needed
 20060619: Set version to 1.4.12alpha1
 20060621: Added clonedb: command; transfer FULL db from other server
 to this one using virtualquery
 20060628: AddToDatabase has JustAdd parameter: skip one unnecessary
 query
 20060701: Speeded filter string handling
 20060702: Pass DB to GenerateFilename to avoid zillions of db open and
 closes
 20060704: Print number of records found in all queries
 20060708: Set version to 1.4.12alpha
 20061126: Moved servertask temporary files to MAG0/printer_files;
 protected query: and query2 against empty input
 20061126: Experimental forwarding on same association: close unused
 association after 5 seconds. Clean collected sopclasses after one
 hour of inactivity.

- Note 1: there is a problem with AReleaseRQ: do not use in this task
- Note 2: maximal 20 forwarders have a remaining association
- 20061127: Added ForwardAssociationLevel (PATIENT, SERIES, STUDY, IMAGE, SOPCLASS; default STUDY), ForwardAssociationRefreshDelay (default 3600 s), and ForwardAssociationCloseDelay (default 5 s). Limit maximum number of ExportConverters to MAXExportConverters=20 (for static arrays used in forwarders). Forwarders keep association open as long as UID at ForwardAssociationLevel does not change. Show filename in forward log; document where fixkodak should operate for virtual queries
- 20061128: Added ForwardAssociationLevel GLOBAL: use association until timeout or incompatible
Close ForwardAssociation after send when ForwardAssociationLevel is IMAGE
- 20061129: VirtualServerForN may be "server, FIXKODAK" to clean queries (add 0) and their response (remove 0)
Hardcoded filters for exportconverters (modality, called, calling, station) can now match e.g., RT*
- 20061130: Pass series and study in virtualserver outgoing c-move
- 20061213: Fixed nasty bug in query2 and TestFilter: Query without bindfield overwrites previous bound strings!
Maybe was problem causing crash on linux with query2: and problem with option -g reportedly stopping incorrectly
- 20061219: Version to 1.4.12
- 20061231: Added ForwardAssociationRelease to allow testing reconnect problem (default 0 = just hangup)
- 20070103: FixKodak blocks *xxxx wildcard virtual queries on date (not allowed in Kodak)
- 20070103: Version to 1.4.12b; start on ImportConverters e.g., <set 0008,1040 to "%V0008,0080">
- 20070104: ImportConverters %QP %QS %QE %QW; <destroy> <delete xxxx,yyyy> <save to filename>
Added %% and %i to Export and Import converters
- 20070105: <set 0008,1040 if "...">, <setifempty 0008,1040 to "...">, <setifempty 0008,1040 if "...">
Import/export converters only report when syntax OK and report when action is void
Added %Vxxxx,yyyy to export converters and %d(date/time) to import and export converters
An import/export converter can thus be used to extensively log incoming images
Added import converters: <stop>, <if "string">, <ifempty "string">, <nop> (also export)
Added general purpose variables x, y, z (read as %x, %y, %z) to import converters
Definition of number of ImportConverters now unnecessary.
Note: importconverter and exportconverter strings may be changed run-time in dicom.ini
- 20070105: Some fixes in dgate --archiving options manual; fixed dgate --restoremagflags:
- 20070107: Fix web access broken by change in odbci for dbaseIII; query must now always include spaces around =

20070113: Do not store NKI compressed data in v2 format: decompress and give error message
Recompress to NKI format now enables StripGroup2; Tested with \$c server debug command

20070117: Allow multiple rules per Export or ImportConverter separated by ; and zero or more spaces
<nop> statement prints itself on console: useful for logging anything that follows

20070117: Now maintain multiple connections per ExportConverter line (max 20x20 forwards)
Added <stop>, <silentstop>, <if> and <ifempty> to ExportConverters; but they only affect single rule (while these would cross over to the subsequent rules in ImportConverters)

20070122: Now also show free space on mirror devices

20070123: Fixed TestFilter for patientid with '

20070125: Removed <if> and added <ifnotempty>, <ifequal>, <ifnotequal>, <ifmatch>, <ifnotmatch>, <ifnumequal>, <ifnumnotequal>, <ifnumgreater>, <ifnumless> as im/exportconverters
Added %xxx[first,last] substring operator; and protect it against overrange
<ifxxx> no longer crosses over importconverters; added { } block for im/exportconverters
E.g.: ifequal "%V0008,0020[0,3]", "2004"; { forward to CONQUESTSRV3; forward to CONQUESTSRV4; } nop test
Note: 1) all (also ifxxx) statements end with ; 2) statements may begin with { or };
3) extra spaces only allowed after ;{ } and single space after ,

20070127: Fix { } in exportconverters. Release 1.4.12b to fix more or less critical odbci error

20070131: Fix in TestFilter (quotes double); Version to 1.4.12c

20070201: Added <storage MAGn> import converter: sets device to store this (new) image to (default MAG0). Fixed importconverters stop and destroy: did not break current line

20070204: Added extra format starting with # to ImageFileLister: e.g. #%s:%s prints MAG0:filename

20070206: Added create database: dgate -esapw name user password

20070207: Fix query string bug on applyworklist found by capolan1

20070207: dgate -e name root <blank> works for mysql: root is used as admin and login
Also implemented dgate -esapw name sa sapw where sapw may be empty

20070210: Added CheckDuplicates to UpdateOrAddToTable; added @ in imagefilelister: replace \ by /
Start on ocx based viewer integrated in cgi interface; used dicom over http:
Small change in gif export; added * as separator in query/2

20070211: Added WebScriptAddress (default http://server/cgi-bin/dgate), WebMAG0Address (defaults http://server/mag0) and WebServerFor (default 127.0.0.1). Fix in cgi query parser: now loads dsize and size correctly
Version to 1.4.12d

20070212: Added WebCodeBase, show version in status_display, added config of which dicom server the web server

- connects to, added [webdefaults] section, added iconsize parameter
- 20070213: Added : as format in imagefilelister: use to list pat:sopuid
Fixed sorting problem by using adapted imagefilelister for seriesviewer
Fixed default for WebCodebase; Version to 1.4.12e;
Use correct case of sql table names in cgi interface: required by mysql on linux
Unsolved: n3 does not always decompress correctly in dview.pas see p20401977:i47, changed default to n4
- 20070215: Fixed logging and added *** Association rejected message when association is rejected
- 20070304: Added <defer> exportconverter: retry later as if connection unavailable
- 20070305: Note: n3 problem fixed in dview.pas, version to 1.4.13alpha
Allow merging of up to 1000 UIDs: set SilentText to 64000 and *uids[1000] (thanks mp)
Allow named pipes for log_on and debuglog_on
- 20070307: Work on extending extract: allow e.g. SQLite -> dbaseIII
- 20070308: Made changes for big endian and Apple's DARWIN
- 20070314: Finished extract: allow e.g. SQLite -> dbaseIII in directory MAGO dbase
- 20070315: Merged DARWIN stuff; Set TCPIPTimeOut for PDU that moves images
- 20070316: Display defer import converter; Clumsily added <compression> import converter and improved <storage> import converter; Made <storage> thread safe. Failed recompress() no longer reason to fail drag and drop; add convert_to_bmp. Use | instead of , to separate patientid from file in addimagefile:
Distributed , code to each of the server commands to make it more , safe. Note: it is NOT a good idea to use a , in a flexible filenamesyntax. Added level & window to convert_to_gif and convert_to_bmp; longer log lines for dump VR
- 20070317: <prefetch> using new prefetch_queue, mayprocess and into_queue_unique, <preforward>, <preget>
- 20070324: preget now <preretrieve> and avoids looping by checking orgmessageid!=0xfbad I.e., data collected by <preretrieve> does not go through import/exportconverters. Added delayed exportconverters <forward patient>, <forward study>, <forward series> with optional compression
Removed "forward compressed to" (without as section) as is never used. Version to 1.4.13beta; delay to 10 minutes
- 20070326: Fixed leak in <forward patient> etc. preretrieve also checking orgmoveae
- 20070330: Change by Mark Pearson: read dicom.ini from same dir as exe in unix mode; merged more Darwin stuff. Also taken over bcb's fix for the finder: studymodality was asked at patient level. Also put in a more ENxxxx as command and messageid
- 20070404: Added CommaInFilenameWorkAround()
- 20070407: Use reentrant ctime_r when available; moved static SOPPatientRootQuery etc to stack to fix reentrancy problem: concurrent outgoing c-move of CT and MRI on different associations would share PDU causing sopclass not accepted on one. Also seems to reduce linux crash problems on multiple

inbound (4 or more) C-stores. Also moved CreateBasicFilmSessionRequest etc to fix potential reentrance problem for printing.

20070410: Merged CommaInFilenameWorkAround()

20070413: "extract:" will just create dbase III clone of full patient DB; added "prefetch" server command

20070415: Added Prefetcher option to dicom.ini: is set will aggressively preread queried patient or studies

20070416: Prefetcher prints more information; use windows calls in windows for faster preread

20070705: extract: uses DT_DBASEIIINOINDEX to disable indexing and packing when extracting from e.g. sqlite to dbaseiii
Note: extract: non dbaseIII goes to MAG0\dbase, dbaseIII goes to DataSource

20070706: Added <between "9", "17"> (9:00 to 16:59) or <between "17", "9"> (17:00 to 08:59) import/exportconverter

20070709: Fixed print of clone db done

20070720: Fixed problem where waiting "forward ... to " task caused high CPU load

20070901: Added dgate --checklargestmalloc:

20071027: Added ForwardCollectDelay for delayed forwarding (default 600 sec)

20071030: Fill in called and calling AE for SaveToDisk for e.g., dropped files etc. Fix %u and %c in Export and ImportConverters: called and calling AE. Log flow control Export and ImportConverters only in debug mode. Added retrying to delayed forwards or prefetches

20071102: SetDicomErrorHandler: orderly shutdown of server on serious DICOM library errors. Fixed a bug in ForwardAssociationLevel: last UID was lost when reading INI file to szTemp. Added MaximumExportRetries and MaximumDelayedFetchForwardRetries (default=0 is no maximum)

20071103: Version to 1.4.13; defer resets queue fails -> keeps on retrying

20071104: Use local as AE for imagelister in web page instead of CONQUESTSRV1; Enable remote servers (use AE instead of 'local') in finder and lister commands; Fix crash when dgate --option gets empty filename: now lists to stdout

20071114: Put --checklargestmalloc: in dgate -?

20071118: Adapted for 64 bits (use SQLLEN for BindField)

20071120: Fixed KodakFixer for empty patient ID (crashed on 64 bits only). Added [modality xx] and [date yyyyymmdd-yyyyymmdd] clauses to export [patient|study|series] to AE

20071121: Added %V*GGGG,EEEE: search VR in any sequence; version to 1.4.13a; Added [now -ddd+ddd] and [age -ddd+ddd] clauses to export [patient|study|series] to AE. No retry on remote dicom error in forward xxx to: would retry zero records response
Use study date for data, age and now clauses

20071123: Made forward command case insensitive; added forward image; added get [patient|study|series|image] from AE. The latter option makes preretrieve obsolete

20071124: Added [sop xxx] clause to [forward|get]. Reorganized exportconverter code: all converters now do % substitution; reduced code duplication. Added reading of sequence items

like in % V/300c,0060.0/0008,1155 or
% V/300c,0060/0008,1155

Real life example (must all be one line, max 512
characters):

```
ifnotequal "%m", "RTPLAN"; stop;  
nop "tests modality = RTPLAN";  
ifnotequal "% V*300a,00b2[0,1]", "A2"; stop;  
nop "test machine name = A2";  
forward to XVI_A2;  
nop "forwards the current recieved RTPLAN";  
get study modality CT from NKIPACS;  
nop "collects associated CT";  
get study modality RTSTRUCT sop V/300c,0060.0/0008,1155  
from NKIPACS;  
nop "collects associated RTSTRUCT";  
forward study modality CT imagetype *AXIAL* to XVI_A2;  
nop "forwards associated CT";  
forward study modality RTSTRUCT sop  
% V/300c,0060.0/0008,1155 to XVI_A2;  
nop "forwards associated RTSTUCT";
```

- 20071125: Fixed syntax for % V/gggg,eeee.i/*gggg,eeee (search all groups under a specified one)
- 20071126: Start on StorageCommitment (unfinished)
- 20080103: Switched to ms7 compiler; fixed forward and get date, modality, sop filters: would not supress the UIDs
- 20080107: Fixed malformed web viewer header: worked for IE but not for other browsers. Check presence of dicom.sql in web pages that need it. Deal with spaces in patient IDs in web pages
- 20080126: Check presence of dgate.dic when starting server
- 20080129: Fix KodakFixer: wrote one byte outside VR data (pr)
- 20080129: Added [imagetype xxxx] clause to [forward|get] (pr)
- 20080130: Small fix in above
- 20080205: Added experimental PadAEWithZeros flag; version to 1.4.14alpha
- 20080210: Added experimental IgnoreOutOfMemoryErrors;
Added "delete [patient|study|series|image] [date yyyymmdd-
yyyymmdd] [now -ddd+ddd] [age -ddd+ddd]
[modality mm] [sop xxxx] [imagetype xxxx]" export converter
- 20080221: Added [seriesdesc xxxxx] filter and "process
[patient|study|series|image] [by command]"
- 20080222: Small fix in imagetype filter code; process by clause not part of unique check
- 20080302: Fixed case of DICOM table names
- 20080316: Added dgate --deletestudies:date(range) and dgate --
movepatient/study/studies/series
- 20080318: Added [series xxxx] and [study xxxxx] filters; work on web
page --deleteseries/study and --moveseries/study allow
patid:uid as parameter
Web interface can now push and delete on series and study
level, but delete is disabled in readonly web interface
Version to 1.4.14beta
- 20080319: Delete in browsers fixed?; added %v(desc)desc: search VR in
given sop of same patient. Example:
% V(/300c,0060/0008,1155)/3006,0010/3006,0012/3006,0014/0

020,000e Gives referenced CT series UID in referenced structure set from forwarded RTPLAN

20080321: Fixes in browser; added graphic web setting; may be gif or bmp for now; Fix %V for non-existing items

20080322: Added dgate --anonymize that uses general scripting

20080323: Small fix in (local) for DcmMove: overwrote destination

20080404: Fixes in series and study filter (rethink naming) added value* match for in match() routine

20080618: Added extra logging in IARQ()

20080620: Only show extra logging in IARQ when assoc rejected

20080816: IARQ shows which sops are accepted; and differentiates no sop from connection terminated

20080817: Small layout fixes; <process with> import converter; show PDU length in log. Check saving of file succeeded (thanks Jeff Bellamy and Alberto Smulders)

20080819: Added experimental DT_MSTR: multi-value entry, e.g. query on 'PET' matches 'PET\CT'

20080819: added --get_ini_param (same as get_param) and get_ini_num to list parameter by index

20080819: Added get_ini to list all parameters in DICOM.INI

20080819: Added code by map but kept original get_param for old web cgi client compatibility; Version to 1.4.14

20080820: Solaris 10 fixes, and general UNIX fixes (map): configfiles may not be in current dir

20080821: Default of ForwardAssociationRelease to 1; added sleep export converter

20080823: Added study UID search to PatientStudyFinder; fixed DcmMove: would call local when remote addressed; Added rudimentary query/move web pages

20080825: query/move looks better; added "thumbs" column to local series lister; config patched to readonly; added background color and display of icon (to be placed in WebCodeBase)

20080826: One more fix in DcmMove, still called wrong server sometimes Do not use 0xfbad as message ID for DcmMove from web page; webreadonly defaults to true; CGI viewer configurable: seriesviewer, seriesviewer2, noviewer, aiviewer

20080827: Added slice number and repeat output data in ImagefileLister and SeriesUIDLister for more flexible formatting; Added flexviewer: reads code from dicom.ini in web server directory

20080831: Translate yyyy and yyyyymm to date range in finder; further only accept valid date and date ranges; Added dgate --get_amaps: lists all non wildcard entries from acrnema.map; Fixed handling of patient ID with spaces in ImageFileLister mode :: All undefined cgi modes can come from the cgi dicom.ini; added special and cgi script variables; Lines can start with -- to start dgate, with # as comment, any other passed as HTML; Added source parameter: flex pages can be read from script file; Added serversideviewer: requires javascript only, nothing to install

20080901: Fixed some leaks in printing and --commands; fixed --get_ini: formatting

20080902: Added header option for web scripts; added some CGI environment variables

20080905: Made new changes for big endian and undid some old ones.

20080908: Index in filelist format is now a string (%s), and added next string that gives index+1 (is1)
Fixed manual of --modifypatid: and --anonymize;; dicom mime to application/dicom
Added modes imagelisthttp, imagelisturls and imagelistfiles; added ? format for imagelister: gives #files

20080909: Added studyuid option to moveseries; pass it studyuid in seriesmover call from seriesfinder
Added --modifyimage:file,script (uses import converter scripting language, where you can use ' instead of ")

20080910: In modifyimage only replace ' with " conditionally; version to 1.4.14a;

20080910: Forbid patid, studuid and seruid change in modifyimage; medged bcb Mac stuff

20080913: Modified and use SetStringVR to correctly send UIDs with padded 0

20081016: Show bitness on startup

20081104: Attach dictionary to DcmMove PDU

20081105: Fixed display of bitness in web page

20081116: Adapted for very large objects (use unsigned int for length); remove extra 0 byte in HTML generator; fixed CheckLargestMalloc

20081121: Added create database for PostGres

20081123: Skip export converters for dropped, modpatid, modimage, merging

20081124: show database type on startup; Temp version to 1.4.14a1; fix many scripting crashes

20081129: start on better patient ID change: process all UIDs; fix drag/drop error introduced in 1.4.14a1

20081129: Removed double access of SOPInstanceUID in SaveToDisk; fix: do not free ddo after SaveToDisk;
added <newuids> and <newuids except > import converters; added --genuid, --changeuid and --checksum commands
Version back to 1.4.14a; modifyimage can change patient ID and study/seriesUID if newuids used as well
set can now also work in exactly one deep sequence: set gggg,eeee/gggg,eeee to "string"

20081130: Added --attachrtplantortstruct:planfile,structfile command using script; also --attachanytopatient/study/series
stop now stops one importconverter- not the chain; added <call file> and <return> statements to return from file
Added optional anonymize_script.cq: overrules fixed anonymizer;
added %A = %V but then gives CRC32 of data and %E = %V but gives new UID for given UID

20081201: added --convert_to_jpg and web page use (experimental)

20081203: If jpg graphic: list options as jpg, yes, no; fix slice number display is serversideviewer
Added frame control to convert_to_jpg etc as l/w/frame; add optional frame control to convert_to_dicom; added frame control in serversideviewer

20090203: Removed DNS reversing (you can use wildcard AE instead); work on zip loading

20090204: Finished zip loading (to be tested on linux), uses now waiting BackgroundExec

20090206: Added QueryConverter0, WorkListQueryConverter0, RetrieveConverter0: can read called (%c), calling (%u), and c-move destination for retrieve (in %s), as well as all data in data object

20090209: Made compiling under linux

20090211: Export MyDcmError; only DCM_ERROR_MEMORY is fatal

20090212: Recoded virtual server (kept old code), to provide better grouping of move requests

20090215: Added VirtualPerSeries0..9 flags: determines if virtual gets are per image (default) or per entire series

20090216: Added %Rgggg,eeee: gives restored UID for newly generated one. Prepare for RetrieveResultConverter0

20090411: Added simple wildcard matching in match(), accept *text*

20090411: Version to 1.4.15alpha

20090513: Added CompressionConverter0 .. 9: called from recompress to 's0' to 's9'; Added <fixkodak> and <unfixkodak> import converters; added <after NN> clause to <forward study> etc; Blocked out StorageCommitment

20090514: %QXgggg,eeee reads aliasfileqX.txt with lines like old<tab>new<return> to map VR to new value

20090616: Add ^/~ after % command to convert to upper/lowercase, %^ %~ %[]; fixed leak when save to sql fails

20090616 Include file stuff; fixes to Unix 7z stuff

20090618 VirtualServerPerSeries is now a limit: if set to N, more than N images go per series

20090620 Version to 1.4.15beta

20090802 Support DCM_ERROR_DEBUG (debug messages from library) that print only if debuglevel>0

20090821 Removed need to specify "delete series modality *" instead of "delete series"; Fixed "process by " command; now uses all command string upto ;

20090824 Version to 1.4.15beta1

20090921 Added extract_frames: command

20090922 Tried to fix <compression> import converter; added <reject> import converter

20090924 Restructured manual; fix crash of studyfinder without search string
Note: on vista, commands like dgate --imagelister wont give large lists (does when piping)

20090926 %t = tab in scripts; fixed failed storage error message; added RetryForwardFailed flag (default 0)

20090929 Added ImportExportDragAndDrop flag (default 0)

20090929 Version to 1.4.15

DGATE.HPP (part of DGATE.EXE):

19980705: Added CACHEDDevices and JUKEBOXDevices, FindPhysicalDevice

19990108: Added LoadImplicitLittleEndianFile and NKI PrivateCompession algorithms

19990109: Regen has extra parameter

19990317: Changed parameters of LoadImplicitLittleEndianFile

19991117: Added parameter FileCompressMode to prototype of nki_private_compress

20000629: Added TroubleLogFile and UserLogFile

20010415: Added KeepImages flag to RemoveFromPacs: clear from DB only Added SubDir parameter to regen to allow regen of one directory only

20010416: Added ChangeUID routine and RegenFile - to allow modification of images

20010429: Changed decompressor: now has extra parameter

20020529: InitializeTables now has mode parameter (0=normal, 1=simple)

20021018: GenerateFileName has NoKill option (for interactive dgate tasks)

20030120: Added prototype of FreeDeviceTables

20030701: compression parameter for amap

20030703: Added prototypes of recompression functions + ArchiveCompression

20030706: Optional filename parameter for recompress

20030706: Export VRType for implicit little endian support

20030921: Added DEVICE_TYPE_MIRROR

20040401: Added Changed and ActualMode flags to compress routines

20040626: Added study and series UID to getfilename interface

20040930: Adapted return type of SetString; added maxlen to BuildSearchString

20041013: Added MAXQUERYLENGTH

20041029: Added MergeUIDs

20041108: Added Syntax input to GenerateFileName

20050108: Adapted for linux compile

20050109: Added configurable TCPIPTimeOut

20050129: Added optional FILE to DumpVR, added CheckFreeStoreOnMIRRORDevice

20050401: Added QueryOnModalityWorkList, WorkListTableName, WorkListDB

20050404: Added DT_START/ENDSEQUENCE to code sequence in WorkList table

20050902: Made space for HL7Tag in DBEntry

20051229: Added iDepth to DumpVR

20060317: Added called and calling to GenerateFilename

20060324: Added StripGroup2 option to recompress

20060628: AddToDatabase has JustAdd parameter: skip one unnecessary query

20060702: Pass DB to GenerateFilename to avoid zillions of db open and closes

20070122: Added MIRRORDevices

20070201: Added DebugLevel

20070207: Added MakeTableString

20080818: DbaseIII check now uses DB flags, not PATHSEP in datasource name; Added DT_MSTR

20090620 Include file stuff

LOADDDO.CPP (part of DGATE.EXE):

19980409: added NKI private decompression engine VR 0x7fdf,0x0010

19980410: added run length encoding of zero differences

19980410 Fix 16 bit absolute value decode

19980415 Fix leak on decompress

19980625 Added compression in SaveDicomDataObject(C10)

19980703 Made DObjectSerialize thread save (removed statics)

19990105 Fix: SaveDICOMDataObjectC10 created VR 0x0002 0x0013 twice. Added comment in SaveDICOMDataObjectC10; CleanUp. Put the nki-routines also in dgate.hpp. Added LoadImplicitLittleEndianFile

19990317 Decompression removed from LoadImplicitLittleEndianFile; added a VR-sizelimit of that reader

19990827 NOTE: LoadImplicitLittleEndianFile allocates 100 MB and crashes when passing chapter 10 file (happens when extension is wrongly .v2)

19990830 Fixed problem above: 'LoadImplicitLittleEndianFile' uses 'PDU.LoadDICOMDataObject' in such cases.

19991117 Added parameter FileCompressMode to in nki_private_compress call

20000629 Logging of trouble now starts with '****'

20001104 Renamed _LittleEndianUID to _LittleEndianUID_space

20001105 Fixed where malloc and new were mixed (vr->data)

20001106 Use delete [] operation for vr->Data

20001128 Fix in 'Implicit length' code in LoadImplicitLittleEndian

20010429 Use faster and safer decompressor

20020412 Added class CBufferedIO for faster reading from DVD (stream functions do not seem to be caching.)

20020415 Removed diagnostic time code (did not compile on ms4.2). Made buffer size dependent on iVrSizelimit (i.e, use smaller for regen, slightly faster)

20030706 Attach VRType to PDU's for implicit little endian support

20041130 Documented crash on win2000 server in code - remains to be fixed – rare crash related to read error of DVD

20050107 Adapted for linux compile

20051219 Use ReAlloc instead of new BYTE[] to fill VR data

20070308 And little/big endian.

20081116 Adapted for very large objects (use unsigned int for length)

20090211 Safety checks in LoadImplicitLittleEndian to avoid crash on corrupted V2 file; Removed lots of dead code

20090412 Fixed for linux compile (tell does not exist)

DGATEFN.CPP (part of DGATE.EXE):

19980326: changed file name generator to ensure correct sorting of image files by external applications

19980327: Added FileNameSyntax option in dicom.ini; 0=original, 1=allow sorting by name

19980407: avoid /;<>| in filename; for Philips: allow up to 9999 series and 999999 slices

19980409: do not free passed DDOPtr on failure: crashed the lot

19980415: Error messages to operatorconsole

19980620: Check error flag from GetDevice (for out of disk message)

19981005: Added FileNameSyntax 2: filename starts with SeriesUID_

19981005: Replaced size%64 by min(size, 63) for correct truncation

19981217: FileNameSyntax 3: same as 2 but accept errors

19981220: Fixed FileNameSyntax code

19990117: FileNameSyntax 4: same as 3 but .dcm extension (forces ch10 format)

19990117: Avoid attempts to rewrite image that is not on MAG store (e.g., on CD)

19990315: Do not allow '.' in directory name. In Syntax 3 directory name is now patient ID only (better for ACRVIEW). Better unique filenames by using time + counter.

20000127: FileNameSyntax 4 now does not truncate patid, as 3 already did

20000131: FileNameSyntax 4 has patient ID only as directory name (same as 3)

20000701: Added MaxFileNameLength option: truncates from start

20010419: FileNameSyntax 5 on request of Jason Foster - uses patientname as dir

20011109: Made MAG name check case insensitive

20020416: Made filename counter 4 digits for when writing >100 files/s

20020416: Made all instances of time() unsigned

20020426: Cannot rewrite image not on MAG store is now a message without ***

20020508: The above message will not lead to a fail of GenerateFileName

20020802: Added FileNameSyntaxes 6..9; cleaned FileNameSyntax code a bit

20020804: Truncate patient ID to 32 chars for mode 6 and 8 (make sure len<255)

20021016: Pass indexed patid to GetFilename for speed

20021018: GenerateFileName has NoKill option (for interactive dgate tasks)

20021223: Added forbidden chars *, ?, " and : (comment from Thomas Buerer)

20030401: Overrule '.v2' filenames with '.dcm' when object is not ImplicitLittleEndian

20030522: Replaced 'static int counter' by 'unsigned int gl_iCounter'

20030606: Fixed incremental counter when creating UIDs or generating filenames

20030730: Overrule v2 only when not ImplicitLittleEndian, ExplicitLittleEndian ExplicitBigEndian (c.f. 20020401)

20030819: Allow longer filenames

20030921: Added DEVICE_TYPE_MIRROR TO GetDevice call

20040129: Added FileNameSyntax 10 = all files in one directory

20040301: Small fix for FileNameSyntax 10

20041108: Added Syntax input to GenerateFileName (overrides ini setting)

20050107: Adapted for linux compile

20050126: FileNameSyntax 11: StudyUID\SeriesUID\SOPUID.dcm

20050131: Changed root to 'name' for FileNameSyntax 11

20051210: Clear root output string when image already in database

20060312: FileNameSyntax 12: similar to 11 but uses Modality_StudyID as dir

20060312: Checked it:
12=name_ID\Modality_StudyID\SeriesUID\SOPUID.dcm

20060314: 12=name_ID\Modality_StudyID\SeriesID\SOPUID.dcm

20060314: new filenamesyntax, e.g.,
%name_%id%\%modality%\%studyid%\%seriesid%\%sopuid.dcm

20060317: Added calledae and callingae to GenerateFilename flexible syntax

20060325: imagenum is image number as text, fix imageid, accept all errors

20060402: Fix potential problem when patient ID not there

20060701: Speeded string handling in new filenamesyntax

20060702: Pass DB to GenerateFilename to avoid zillions of db open and

closes

20070125: Fix %modality; add %studydate and substring (year = %studydate[0,3])

20071027: Extended length of FileNameSyntz parameter to 256

20071027: Stripped spaces of called and calling in flexible filenamesyntax

20071030: Small fix in the above

20071104: Added %series: 4 digit series number

20090620 Include file stuff

20090926 Added %studydesc and %vxxxx,yyyy etc

20090927 Added Cleanup ro %vxxxx,yyyy

DEVICE.CPP (part of DGATE.EXE):

19980620: Setting MAGDeviceThreshHold to 0 causes out of disk error below 10 MB without cleanup

19980620: Implemented PanicKillOff thread here as alternative to spawning killer.exe

19980702: Started support functions for maintaining/determining amount of used space on device

19980704: NOTE: JukeBox code only TruncateFieldNames compatible for now; used mp's filecopy

19980709: Finished first version of archive options: prepare, undo, copy, compare, delete

19980721: Set default # cache and jukebox devices to 0

19990110: Made strings longer since got truncated, fixed some messages

19990110: Archive one MAG device or MAG?; fixed SQL syntax for update; speeded 0x7fffffff. Return False if SelectLRUForarchival selects no data

19990111: Reset archive flag reports to operator console; protected against illegal device#

19990113: Run up to 10 patient further to try and fill CD more exact; max patients = 10000

19990114: Added quick routine MakeListOfPatientsOnDevice and used instead of 0x7fffffff

19990117: Accept any, not only *.v2, for computing patient size, assume max file size=30 Mb

19990630: Added support for MIRROR devices (e.g., try MIRROR1 if MAG1 fails)

19990707: Fixed default MIRRORDevices (now 0)

19990708: NOTE: archiving should make use of mirror device if required as well!

19990712: Fixed that MagRampage thread was started over and over again (fixed for WIN32 only)

19990831: Fix: Several BOOL functions returned -1, which is TRUE !!

20000621: Changed layout of this update-history

20000629: Logging of trouble now starts with '***'

20001104: Fixed aDB.Close -> should be aDB.Close(); added WINAPI to MagRampage thread

20010328 Added verify mirror disk

20010329 DeleteBunchAfterBurning also deletes data on MIRROR0 if it exists; verify mirror disk keeps on going after error but does return error

20010312 Check if we already selected some patients for archiving from the device

20010509 Added RenameDevice

20010522	Do not call RestoreMagFlags if something goes in wrong in PrepareBunchForBurning
20011114	Replaced slow updates for magdevice by much faster ones. The update that now no longer has the IN part might not work for ACCESS or DBF. So: for jukebox purposes, SQL server is required
20011115	Replaced 'LIKE' by faster '=' in query strings; fixed previous fix
20020412	PanicKilloff will delete now delete 5 MB data at a time. (high water = low water + 5)
20020415	Added TestImages: sanity check of images on disk
20020416	Reversed read order for TestImages and VerifyMirrorDisk: MRU first
20020802	Allow multiple subdirectories in rmdir and mkdir code
20020804	Cleaned up a bit
20021018	GenerateFileName has NoKill option (for interactive dgate tasks); moved ALERT warning
20021020	Simplified and speeded queries for archiving using ImagePat field (requires rev5+ of db); Removed " and added [in MakeSafeString; hand-code one query for built-in dbase driver; Changed SQL construct in SelectLRUForArchival for compatibility with built-in driver
20030120	Added FreeDeviceTables
20030702	Start on ArchiveCompression; for now KB is specified - before!- compression
20030705	Replaced ProcessDDO by more correct DecompressNKI to check pixel data
20030706	Attach VRType to PDU's for implicit little endian support
20030724	Fix in GetKBUsedForPatient: missing %s in printf
20030819	Allow longer filenames
20030905	Allow longer filenames when reading device paths
20030921	Added DEVICE_TYPE_MIRROR in GetDevice; allow PanicKillOff to be called with variable threshold
20031217	Fix: Support harddisks bigger than 2 GigaByte!!! in CalcMegsOnDevice (Thanks to Clifford Sweet)
20040403	Moved ArchiveCompression to SelectLRUForArchival -> fills disks correctly
20040614	Added MoveDataToDevice
20050107	Adapted for linux compile (no threads yet, no check of disk space on device)
20050109	Added threads for linux
20050118	Detach thread after starting it to avoid leaks
20050119	GetKBUsedOnDevice is not used --> no problem to return -1 under linux
20050414	Fix CalcMegsOnDevice for relative path
20050421	Fix: MAGThreshHold is space for largest file != space for cleanup. Now set to 30 MB independent of MAGDeviceThreshHold
20050901	Fix free space check for unc paths (error counting \)
20060311	When GetDiskFreeSpaceEx fails allow storing data anyway (fix for Marius Petruc)
20061213	Fixed nasty bug in MakeListOfPatientsOnDevice: Query without bindfield overwrites previous bound strings!
20070316	Cleanup now starts at MAGDeviceThreshHold to MAGDeviceThreshHold+1000, was start on 30 to

20071027 MAGDeviceThreshHold; Allow both MAG0 and MAG0.Archiving as input for PrepareBunchForBurning
 Protect MakeListOfPatientsOnDevice on MAXPATIENTS;
 LRU selection now configurable using routine
 MakeListOfOldestPatientsOnDevice. E.g. if LRUSort =
 StudyDate, deletes or archives least recent scanned patients
 first. The default "" means that the original sort order on db
 entry date is kept
 20071031 Catch out of memory errors and return error status if so
 20071118 Adapted for 64 bits (use SQLLEN for BindField)
 20071128 Fix by kamil.krasnik of Cache device disk space test for UNIX
 Also fix Cache and Mirror for UNC paths
 20080126 Fixed bug reported by Ali: second move to MAG1 of more data
 if same patient would fail on delete. Added new logic: attempt
 to delete file from MAG0 that is not in MAG0 but is in MAG1
 is OK. Similar attempt to delete file from MAG0 that is in
 MAG0 but not in MAG1 is an error
 20080302 Fixed case of DICOM table names
 20080317 Fixed deletebunchafterburning change (Ali)
 20080604 Modified device searching order when file not found:
 JUKEBOX now also searches other JUKEBOX
 20080617 Fixed bug in above: second jukebox not accessed correctly
 20080818 DbaseIII check now uses DB flags, not PATHSEP in
 datasource name
 20081016 Fix check of max patients in
 MakeListofOldestPatientsOnDevice
 20081120 Added UseEscapeStringConstants and DoubleBackSlashToDB
 20081124 restrict PanicKillOff to 10 runs (to stop when no patients left)
 20090821 Added new FileExists function that uses stat; maybe does not
 try to mount tape or disk to early
 20090926 MakeListOfOldestPatientsOnDevice returns newest if Max<0
 SelectLRUForArchival always use new code (use KB<0 to
 select MRU); Default MakeListOfOldestPatientsOnDevice use
 AccessTime to emulate old code

DBSQL.CPP (part of DGATE.EXE):

19980321: Changed ObjectFile and DeviceName field length to 250 for
 dbf compatibility
 19980321: Added define TRUNCATEFIELDNAMES for DBF
 compatibility (apply in makefile)
 19980322: Added run-time check on DbaseIII (should also be added in
 parse.cpp somehow)
 19980325: Added TruncateFieldNames entry in dicom.ini to allow DBF
 compatibility
 19980327: Made MaxFieldLength configurable
 19980327: Set default event notification to UDP (for personal pacs)
 19980407: Added FileCompressMode config
 19980409: Check vr!=NULL in MakeSafeString, MakeSafeDate
 19990630: Remove also files from MIRROR disks
 19990707: Added UpdateOrAddToTable to refresh database contents
 without first removing
 19990707: Cache Updates; and AccessTime with ~31 to allow update
 times to be the same
 19990707: Added fix for Philips PATID; fix cleaning of MIRROR device

19990708	Added (and disabled) stress code for SQL server
19990712	Fixed FIX_PHILIPS; atoi failed sometimes because vr->data not zero terminated
19990827	Added creation of key and link indices
19991117	Added a check on ini-file value of FileCompressMode
20000621	Changed layout of this update-history. Fix: In 'SetString', type DT_UINT32 was treated as DT_UINT16 Added TroubleLogFile and UserLogFile
	When updating PatientRecord, verify the new Name and BirthDate
20000629	Logging of trouble now starts with '***'
20000701	Remove *all* trailing spaces in MakeSafeString before enters database
20000703	Merged changes: made patient change verification table and record name independent and extended to other databases as well; removed trailing before comparison; show patid on all error messages
20000705	refuse inconsistent update of link: show error on operatorconsole
20000707	fixed above addition
20001104	Replaced _rmdir by equally valid rmdir
20001106	Use delete [] operation for vr->Data
20001128	Fix: protected 'GetFileName' with a critical section.
20010415	Added KeepImages flag to RemoveFromPacs: clear from DB only
20010416	Added ChangeUID routine and UIDMODS table - to allow modification of images
20010418	Changed names of database fields in UIDMODS - did not work on msaccess
20010429	Renamed genuid routine and variables to allow compile in one big file
20010713	Reduced devicename to 32 chars to space space
20010902	Improved UpdateCache to be thread safe and made it longer, no test on image db.
20011109	Made MAG check and database field consistency check case insensitive.
20011115	Replaced 'LIKE' by faster '=' when possible
20011116	Fixed error handling of db entry. It was possible that db entry failed without any message!
20011121	Create indices on ImagePat and SeriesPat if these fields exist
20020403	Do not overrrule the PatientTable with: empty data, or birthdate xxxx0101, or sex other than MmFf.
20020409	made LastPatid non-static
20020409	Removed non-thread safe caching of LastADBE
20020409	Moved entry into UpdateCache to after succesful Update
20020412	Made NCACHE configurable and changed it from 16 to 1024 (8 MB); Set lastfield (limit of #fields) to 20 (was 16)
	Added checksum code in update cache to make it faster
20020412	Made key fields unique. Reversed writing of db's. In this case a db write fail will still result in a valid db. The db write code is not multi-user safe. A new record may be written at the same time by two processes -> fail
20020413	Set NCACHE to 256, enough for single thread regen
	Modified another non-thread safe construct
20020415	Fix display of PatientID in 'Inconsistent' error message

20020416 Made UID generator configurable through UIDPrefix in dicom.ini. Made all instances of time unsigned. Note: accesstime in the db is signed int: problem around 2038

20020418 Added TimeStamp, Flags, and Spare fields on all dbs for future use

20020430 Fix in spare fields: name was reserved in some odbc implementations

20020515 Process all db fields; enter (1) Modality into StudyModality

20020517 Modality is merged into StudyModality without size limit (enforced by sql server)

20020518 Skip missing VR's again; max nr fields to 30; fix reading of NULL fields (clear s[])

20020519 Also skip writing empty VR's (vr->Length==0); made FixPhilips configurable (default 1). Remove / from date to allow writing mm/dd/yyyy into sql server

20020522 Test on empty Modality vr

20020529 Added PRIMARY KEY to key DB fields (needed for replication)

20020529 InitializeTables now has mode parameter (0=normal, 1=simple) Do not make Index for primary keys (is done automatically)

20020609 Added compression modes 3 and 4

20020802 Simplified rmdir code and allow multiple subdirectories

20020804 Use PATHSEPCHAR where possible

20020806 Fix: cleanup entries of refused item in database

20020819 Added better UID generation

20021016 Use patid in SaveToDatabase and GetFileName query (both test for rev5 or higher of the database)

20021017 Allow set of UIDpostfix from extern (-c option of dgate) Removed creation of unused tables

20021020 Added [to MakeSafeString; removed "
Note: VR's containing ', ? give spurious inconsistency warning when rewritten

20021028 Also removed dropping of unused tables; reversed table search to image..pat in FindDBE. Made inconsistent birtdate a severe error message (added ***)

20021110 Made date range inclusive (bug reported by Aaron Cann)

20030113 Added PatientQuerySortOrder etc overrides for sorting

20030205 Fix potential empty patient ID and SOP problems in GetFilename

20030321 Extra check on vr!=NULL in SaveToDatabase

20031104 Added \\ to MakeSafeString

20040301 Do not double \\ when already doubled

20030425 Added DoubleBackSlashToDB control for \\

20040528 Pass patient ID in RemoveFromPacs and Enable KeyOnAll

20040529 Implemented faster delete from database

20040530 Pass a field to query in delete - obligatory for sql server

20040601 Removed enable KeyOnAll - added some more checks in NewDeleteFromDB

20040609 Check for DB revision for fast delete from database queries

20040610 Truncate too long VR's before putting into db; log to pacstrouble

20040623 Fix for non-DBASE datasources in 'UpdateOrAddToTable'

20040626 Added study and series UID to getfilename interface

20040713 Added FixKodak: replace pat 0nnnnnnnn with nnnnnnnn

20040722 Defaults for FixKodak and FixPhilips to 0 (!)

20040930 Added multiple UID matching: UID\UID\UID in BuildSearchString (list truncates at maximum length)
SetString now returns a char * which is newed (with lots of extra space for MakeSafeString which is done in-place) if Max length is passed 0. DICOM2SQLQuery has no max length anymore

20041003 Truncated printf's of SqlStatement

20041029 Added MergeUIDs routine

20041101 Added NewDeleteSopFromDB

20041220 Fix: in 'RemoveFromPACS', an even PatientID was not zero-terminated !!

20050109 Adapted for linux compile

20050111 Added ctype.h (for mingw)

20050205 Added counters for database activity

20050206 Allow empty DBE in ConstructVRFromSQL: used to get ObjectFile and Device in query

20050401 Added WorkListDB and WorkListTableName

20050404 Dicom types DT_START/ENDSEQUENCE are ignored during table creation/adding to table

20050414 Allow undefined worklist database;
Delete patient will delete worklist entries as well (but needs at least one image)

20050417 Delete from DB will also delete worklist as patient goes

20050826 Added mode 2 for initializetables: clear/create worklist only

20050831 Mode 0 and 1 will now not delete worklist if it contains data

20050831 VerifyIsInDBE will not return DT_START/ENDSEQUENCE

20050901 Do not call FixImage in SaveToDataBase: is done in SaveToDisk before

20051121 Enabled SQLRealSize because SQLResultLength does not work in PostGres BindField

20051123 Fixed it, and only enable it when #ifdef POSTGRES

20051204 Disabled it, fixed postgres driver instead

20051210 GetFilename returns FALSE for an image that has no filename or device set

20051212 Clear update cache when any records deleted - drastic but safe

20051216 Small fix in above

20051217 Use new VR::ReAlloc method to replace data in VR

20051218 Fix study modality when DoubleBackSlashToDB=1; changed modality search

20051228 Truncate invalid trailing spaces (>1) from patient ID. Fiximage warns to SystemDebug

20060210 Removed order: first remove spaces and then fix the patient ID because patient ID consisting of 14 spaces caused huge troubles

20060220 Check max 50 fields when update; fix Inconsistent check for DoubleBackSlashToDB

20060607 Fix character translation for entering *?%[' into sql using MakeSafeStringValue. Fix consistency check for these characters as well (thanks Robert Chrzan)

20060607 Added "not null" to "PRIMARY KEY" to satisfy Sybase (thanks Marcin Litoborski)

20060618 Added not null to UIDmods as well, unified case of DICOMWorkList table name (may be done for other tables as well) (thanks Marcin Litoborski)

20060618 Remove " added by MakeSafeStringValue prior to inconsistency check (thanks Robert Chrzan)

20060621 Increased size of s from [50][255] to [51][256] in
UpdateOrAddToTable fixes VirtualQuery crash

20060628 AddToDatabase has JustAdd parameter: skip one unnecessary
query

20060706 Replaced faulty new vr construct when doing consistency
check: faulted on Linux

20061213 Protect Clear_UpdateCache with critical section
Fixed nasty bug in NewDeleteFromDB. MergeUIDs,
NewDeleteSopFromDB: Query without bindfield overwrites
previous bound strings!

20070123 Fixed GetFileName for patientid with '
Recoded some of the inconsistency checking: now no failure on
patient ID (link) with '

20070131 Fixed GetFileName for all patientid's ;->>>>

20070201 Fixed (unused) UpdateAccessTimes for weird patient IDs

20070210 Added CheckDuplicates to UpdateOrAddToTable: used on
DicomStudies to catch inconsistent patientID
Enabled KeyOnAll on UpdateOrAddToTable: only delete exact
records (needed if inconsistent patientID)

20070308 Changed to set patient ID to 0 for anonymized patients

20070315 Merged; also noted that changed possible use of AND at start
of sql where

20071027 Also truncate too long date fields with error message; added
AllowTruncate: if sql name in comma separated list: warning
only else ***error

20071118 Adapted for 64 bits (use SQLLEN for BindField)

20080302 Fixed case of DICOM table names

20080319 Fixed typo in above change; fixed worklist delete for patients
with space in ID

20080817 Added WorkListReturnsISO_IR_100 flag (default 1)

20080818 DbaseIII check now uses DB flags, not PATHSEP in
datasource name; Added experimental DT_MSTR: multi-value
entry, e.g. query on 'PET' matches 'PET\CT' if studymodality is
given type DT_MSTR instead of DT_STR. Note: not
implemented for DBASEIII

20080819 Added warning when querying DT_MSTR field on dbase

20080902 added EnableComputedFields (default 0)

20080910 Added create Patient ID for 0 length ID (old Picker CT)

20080910 Missing patient ID is now not filled with "0" but with
PatientName + Date

20081104 Fixed crash in UpdateOrAddToTable due to missing BindField
(1, ...)

20081120 Strip all trailing spaces of modality prior to merging: some
scanners add more than 1; Added UseEscapeStringConstants

20081124 Blocked RemoveFromWorld when 0 images found for safety;
default SQLServer to "" = black hole

20090216 Added ChangeUIDBack and ChangeUIDTo

20090616 Create index for UIDMods on OldUID; protected UIDMod
functions with ChangeUIDCritical; Convert ** query field to *;
old efilm version seems to create those

20090616 Include file stuff

VRTOSQL.CPP (part of DGATE.EXE)

20000629 Logging of trouble now starts with '***'

20010330	Added a few debug printf's
20010420	Fixed memory leaks in all query levels
20020519	Clear BindField result strings before reading (NULL does not read)
20021028	Restructured queries to give lowest level of de-normalized databases. Fixed sorting on PatientName in denormalized study query
20021030	Reversed this again apart from study level because SQL server becomes very slow
20030113	Added PatientQuerySortOrder etc overrides for sorting
20030114	Added in querycolumns (even if already present); tested for SQL server, requires testing for other datasources
20030122	Remove unused entries from Tables string in queries
20040930	Started adapt such that query strings etc and not limited in length. For now: query string max 8192 (here and in odbci.cpp); sql statement max 16384 (in odbci.hpp) Enough for query with one multiple values UID of about 100 images (list truncated if too long). Added safestrcat protection of SearchString
20041003	Truncated debug prints, malloc strings at image level. Analysed string lengths; limited 'records =' debug log
20041013	Used MAXQUERYLENGTH
20050107	Removed UNIX flags: solve difference in database interface
20050206	Image query can send filename and device in 0x9999,0x800 / 0x0801
20050401	Added QueryOnModalityWorkList; - todo - put selected items into sequence 0040,0100
20050404	Take query for Scheduled Procedure Step from sequence, put results into sequence
20050414	Made sequence unfolding for worklist more generic - accepts any number of and nested N=1 sequences. This is correct behavior for query input, but limited for query results
20050417	Removed unused variable
20050831	Fixes in worklist code: is ok for all OFFIS tests except 1 (empty seq not returned) and 10 (undef non-empty seq takes one entry from higher level) - good enough for initial release?
20050901	Fix for test 10: allow undefined sequence in query
20050907	Merged change by Hans-Peter Hellemann: fix missing max() macro
20051229	Debug log show records of all queries. DumpVR only left in worklistquery and shows sequence layout
20051230	Removed 2 forgotten dumpvr's
20050103	Added debug info from testing phase inside nested sequences for modality query
20050211	Added empty required modality sequences 8,1110 and 8,1120 when not there
20050224	Fixed modality worklist query: empty result sequences were not handled correctly (Thanks Tony Tong)
20050311	Worklist change was tested OK with Agfa (thanks Frank Grogan), cleaned debug log a bit
20060607	Fix crash when coding empty sequence as last item in worklist query (thanks Francois Piette)
20061219	Small fix in layout debug log
20071118	Adapted for 64 bits (use SQLLEN for BindField)

20080817 Fixed bug found by larc: worklist sql syntax error (fields start with ,) when 1st item is sequence; Fixed bug found by Alberto Smulders: sometimes sequence level in response would not come down; The problem was that a higher levels the reported sequence level was inconsistent with the 1st level; Changed CodeSequence stop criterium and level coding for deeper levels; now works with varies sequence combination; Added WorkListReturnsISO_IR_100 flag (default 1)

20080818 DbaseIII check now uses DB flags, not PATHSEP in datasource name

20080901 Implemented 'Number of Patient Related Studies' (0x0020, 0x1200) etc

20080902 Fixed that option for VirtualServers; added EnableComputedFields

20080905 Added void* cast for deivr change

20081016 Fixed for WC compile

20081121 Fixed ISO_IR 100

DPRINTF.CPP (part of DGATE.EXE):

20000211 Removed MajorEvent and MinorEvent instances of 'Debug'.
Cosmetics. Added UserLog and TroubleLog.
Added timestamp option.
Added CriticalSection when printing to file or stdout.

20011110 Post release 1.3.10: keep log files closed while working

20021027 Avoid crash when logfile cannot be opened

20041003 Note: max 1200 chars (use %.1000s to print long strings)

20060618 Define _SH_DENYNO if needed

20070105 Added timestamp for linux users (thanks, Mark Pearson)

20070406 Use reentrant ctime_r and localtime_r when available

20070408 Protected entire .printf() with global critical section

20070712 Closed/opened critical section where recursive call to printf would hang linux version with sqlite

20071120 Use fputs instead of fprintf at end: otherwise % removed

20080821 Fix for Solaris SUNwspro compiler

20090620 Include file stuff

REGEN.CPP (part of DGATE.EXE):

19980327: put messages in one SystemDebug for UDP message layout

19980415: changed messages to OperatorConsole

19980605: Need to add regen for optical devices and cachedevices !!!!!

19981218: temp use pdu.load

19990108: Replaced PDU.Load by LoadImplicitLittleEndian in RegenToDatabase

19990109: Set HeaderOnly flag for LoadImplicitLittleEndianFile to TRUE. Added regen of CACHE and JUKEBOX devices;
NOTE: full regen imposes name restrictions on JUKEBOX and CACHE directories

19990117: Filenames with .v2 are assumed raw; added extension .dcm for chapter 10 format

19990317: Parameters of LoadImplicitLittleEndianFile have been changed

19990521: .img files react same as .dcm files

20000629: Logging of trouble now starts with '***'

20010415: Added SubDir parameter to regen to allow regen of one directory only

20010416: Added RegenFile - to allow modification of images

20011109: Made file extension checking case insensitive

20020409: Experimental multithread version.

20020413: Made NTHREADS variable and tested. Time to regen 6900 files about 3 min and 40 s.

20020415: Tested with new loadcode by ljz. Note: multithread works and has allowed fixing MT some errors in other modules. However, due to a problem in concurrent db writing (in UpdateOrAddToTable) it should not be used clinically.

20020613: Removed some warnings

20020802: Simplified regen code; traverse subdirectories recursively (allow e.g., e-film data format)

20020804: Use PATHSEPCHAR where possible

20021014: Exclude directory PRINTER_FILES during regen (contains slices without ID and such)

20030120: Removed some warnings

20030706: Attach VRType to PDU for implicit little endian support

20030819: Allow longer filenames

20040614: Do not regen CACHE devices; first regen JUKEBOX then MAG (e.g., in historical order)

20050118: Adapted for LINUX compile

20060628: AddToDatabase has JustAdd parameter

20070210: Increased maxvsize for regen v2 files from 0x400 to 0x4000 - > UIDs were sometimes not found

20070308: Ignore .DS_Store for DARWIN

PARSE.CPP (part of DGATE.EXE):

19980321: Added define TRUNCATEFIELDNAMES for DBF compatibility (apply in makefile)

19980325: Added TruncateFieldNames entry in dicom.ini to allow DBF compatibility

19980327: Added MaxFieldLength entry in dicom.ini to allow DBF compatibility

20001105: Renamed some enums and variables to allow compile in one big chunk

20010713: Renamed DT_UINTxx to DT_INTxx as temp fix for bug in LEX.CPP

20010829: Undone above change as LEX.CPP has been fixed by ljz

20050107: Added include file gpps for GetPrivateProfileString

20050401: Added WorkList Support

20050404: Added DT_START/ENDSEQUENCE to code sequence in WorkList table

20050902: Added HL7 column to be used for WorkList table

20050908: Fixed pointer error that crashed linux version

20080818: Added DT_MSTR

LEX.CPP (part of DGATE.EXE):

20000822: Created

20000823: Support cases where the input-file is empty or contains only white-space.

20010716: Fix: Allow TOKENs that are substrings of other TOKENs.

20050103	Changed include file to lower case (for linux)
20050108	Removed window.h for linux compile
20050118	GNU C++ knows BOOL etc, do not redefine
20090620	Include file stuff

NKIQRSOP.CPP (part of DGATE.EXE):

19990317	NKI-specific code moved here
19990903	Implemented NKI MaxRowColumn VR in DCO
19990906	Improved implementation of MaxRowColumn
19991022	Changed the root of NKI-made UIDs to the official one supplied by Medical Connections(UK): 1.2.826.0.1.3680043.2.135.1066.xxxxxxxxxx
19991122	Added NKI-CompressionMode 2: safer, with CRC checks
20000131	Regardless the FileCompressMode in Dicom.ini, always send images compressed (mode=2) when communicating with an NKI application.
20001105	Fixed where malloc and new were mixed (vr->data)
20001106	Use delete [] operation for vr->Data
20001106	Temporary fix of BC leak in CompressNKI and DecompressNKI
20001120	Fix bug - vr->data was reallocated without changing vr->length
20001127	Fix: Crashes happened when more than one 'ServerChildThread' was active. m_pDCO is wrongly shared by all threads !!
20010424	Plugged in faster and safer decompress
20010426	Fixed leak when connection is aborted
20010429	Interleaved CRC computation with compress code (factor 2 faster) Added GetADDO to allow read ahead within calling program
20010501	Merged ljj's change of 20010426
20010502	Added extrabytes pointer to Read and RetrieveOn
20010502	Added vr(9999,0300)=SliceLimit: send at most so many slices
20010502	Changed this vr to (9999,0500)=SliceLimit
20011219	Added extra check in case other manufacturers than NKI use VR (0x7fe0, 0x0010), such as ACUSON
20020317	Replace true by TRUE
20020415	Added error handling on ProcessDDO
20020429	fixed reporting of number of complete slices (now starts with 1) return cancel status if C_STORE failed
20020609	Added compressor modes 3 and 4
20020609	Added VR (9999,0600): MaxCompressionLevel (default 2) Note: This level (max of 4) is also used when downsizing
20020613	Exported DecompressNKI and CompressNKI
20020619	Damn! ELSCINT uses (0x7fe0, 0x0010) too (see modification on 20011219). Extra check on zero-length pixeldata
20020930	Fixed SliceLimit VR
20021016	Removed __BORLANDC__ language construct - to fix downsize with BC55
20021115	Added Generic style retrieve classes; print error messages from c-move
20030522	Added function ComputeCRC
20030605	Fix in DecompressNKI: dgate crashed when DCMTK's 'storecu.exe' wants to send an NKIcompressed image to dgate; it refuses to send the pixeldata!

20030701 QualifyOn now also has compression parameter; transfer syntax work in progress

20030703 Tested recompress functions

20030704 Disabled decompression in ProcessDDO for non-nki clients; is done by recompress. When downsizing use DecompressImage(); also supports JPEG; Removed MaybeRecompress. Recompression for NKI clients only when downsizing; otherwise as specified in acrnema.map

20030705 Moved recompression out of ProcessDDO into StandardRetrieveNKI::Read. Skip recompression to same level as incoming

20030706 Optional filename parameter for recompress (not used yet); set env for offis tools

20030706 Attach VRType to PDU's for implicit little endian support

20030709 Removed DCMDICPATH; is not needed

20030819 Allow longer filenames

20030905 Note: recompressfile; DecompressImageFile and CompressJPEGImageFile do not allow spaces in filename

20040401 Added Changed and ActualMode flags to compress routines; only give compress message if something changed

20040401 Set maxcompression to 4 for NKI send

20040403 Added own SaveDICOMDataObject as in dgate.cpp

20040406 Also copy TypeCode in DecompressNKI when converting (0x7fdf, 0x0010) to (0x7fe0, 0x0010); Make TypeCode of (0x7fdf, 0x0010) OW instead of OB, because OFFIS refuses to compress OB

20040406 Always use EXPLICIT syntax for jpeg, fix v2 always use DUMP; Use -F +ti option for dcmdjpeg for writing to v2: creates raw dump, implicit; Refuse to jpeg compress V2 files and images != 16 bits; \n is all messages; Fix error handling of CompressJpegImage

20040530 Removed unused variable

20040722 Added "nj" compression: leaves JPEG as is; else MAXNKICOMPRESSION

20041101 Added built-in JPEG and RLE decompressor

20041102 Fix problem with external JPEG compression: clear transfer syntax prior to save for OFFIS tools with DICOM_CHAPTER_10_EXPLICIT

20041103 Added k1,k2,k4,k8 compressors: downsize to 1024,512,256,128 pixels if bigger to start with

20041112 Called AE SERVER~xx in C-MOVE lets xx override outgoing compression as well (e.g., call CONQUESTSRV1~k4 to always get images downsized to 256x256)

20050102 Added NOINTJPEG flag to allow compile through total.cxx

20050103 Changed include file to lower case (for linux)

20050108 Adapted for linux compile (work in progress)

20050109 Added configurable TCPIPTimeOut

20050118 replaced thread local storage under linux with variables in object

20050119 added rudimentary support to start external (de)compressors under linux

20050121 Changed filename to lower case

20050122 Improved external jpeg support under Linux: load dictionary, wait until ready

20050130 Added To8BitMonochrome and ToGif

20050204	Small fix in ToGif for non-square images; also interpret RescaleIntercept as float
20050205	Added counters for compression activity
20050206	Optimized downsizing: do not decompress if no downsizing to occur
20050206	Note: replaced thread local storage under linux with variables in object is incorrect. Under linux, the server now can also serve one at a time. Fix for color to gif; added limited auto scaling in 16 bits to gif.
20050211	Now really removed need for thread local storage
20051210	Added "vX" compression (same as as is)
20051217	Use system() to call on offis apps in linux (now works)
20051217	Use new VR::ReAlloc method to replace data in VR; fixed 2 float warnings
20051229	Fixed several leaks in (jpeg)compression code; changed alloc for nki compression
20051230	Added +sr option to dcmjpeg: compress without changing rescaleslope/intercept This option is required for our viewers: slices must all have same rescale
20060219	Removed warning in writegif
20060222	Added extra checks (not on ID strings) to pass as NKI compressed data
20060311	dcmjpeg opts string got truncated (thanks Rainer Libowski) fixed unused CompressJPEGImageFile (wrong exe called) external decompress temporary files now in printer_files (thanks Rainer Libowski)
20060324	Added StripGroup2 option to recompress; strip group 2 from outgoing c-stores if not compression "as" or "is"
20060328	Use IsAbstractSyntaxAccepted(iUID) to test if host accepts image
20060402	Fix crash when recieving or dropping jpeg compressed color images. Consider not removing transfer syntax (0x0002, 0x0010) prior to dcmdjpeg/dcmjpeg. Would fix problem with external decoding color jpeg images
20060402	Changed IsAbstractSyntaxAccepted(iUID) test back (thanks Andrej Savelov)
20060405	That was not the problem
20060618	Tested IsAbstractSyntaxAccepted - seems to work. Removed need for min()
20060619	Do not remove transfer syntax before decompression (20060402 suggestion). Maintain original object when decompression fails, changed wording of message. Only complain about internal decompressor for jpeg
20070104	Export automatic SaveDICOMDataObject
20070113	Never delete transfer syntax (was left in CompressJpegImage, solves coding error in jpeg store). Tested with \$c server debug command
20070210	Export MaybeDownsize and check on 0 for passed size
20070307	Added several debug prints in retrieve, e.g. at bail out because connection dropped
20070308	removed #include <wait.h> from DARWIN
20070314	Send 0000,1030 (MoveOriginatorAE) and 0000,1031 (MoveOriginatorMessageID) in SS->Write as result of Move

20070315	Merged bcb DARWIN stuff; Set TCPIPTimeOut for PDU that moves images
20070316	Added (color) ToBMP for convert_to_bmp; added level and window to ToGif and ToBMP
20070407	Use ~p1..9A..Z to override C-MOVE port (adds 1..36 to port number)
20070902	WriteGif now cpp
20071027	Added quotes around filenames passed to dcmdjpeg and dcmjpeg: avoids errors with spaces in paths
20071101	Enabled JPEG compression and decompression of non-16 bit data
20071104	Added DecompressNon16BitsJpeg (default TRUE)
20071105	Restore image when dcm/djpeg failed to start
20080103	Added mode 'uj': leave jpeg as is, otherwise uncompress Added DecompressImage to recompress()
20080820	Solaris fix (do not use variable name SS)
20081116	Adapted for very large objects (use unsigned int for length)
20081201	Added JPG converter
20081203	Enabled internal decompressor for color, added frame extraction for jpeg etc; Add frame extraction control = 0x09999,0x0201
20090209	Added QueryMoveScript callback; removed unused variable
20090325	Added RetrieveResult converter, impact on performance to be tested
20090412	Changed jpeg encode_image mode to correct BGR RGB mixup
20090513	Added modes 's0' to 's9' call script CompressionConverter0 to 9
20090518	Added modes ka, kb and kc to downsize to 64, 32 and 16
20090921	Added ExtractFrames
20090927	Stop jpeg compression for PR SR and RT

NKIQRSOP.HPP (part of DGATE.EXE):

19990317	NKI-specific code
20001128	Fix: Crashes happened when more than one ServerChildThread' was active. m_pDCO was wrongly shared by all threads !!
20010429	Added GETADDO to allow optional read ahead withing calling program
20010502	Added extrabytes pointer to Read and RetrieveOn
20020415	ProcessDDO now returns status (to allow compression error check)
20020613	Added prototypes for DecompressNKI and CompressNKI
20021115	Added Generic retrieve classes
20030522	Added prototype of ComputeCRC
20030701	QualifyOn now also has compression parameter
20030702	added ExtendedPDU_Service
20030704	Changed ProcessDDO parameter to **DDO (for recompress)
20050118	replaced thread local storage under linux with variables in object
20050121	Changed filename to lower case
20050211	Removed need for thread local storage
20090209	Added QueryMoveScript callback

ODBCI.CPP (part of DGATE.EXE):

19980415	Blocked one error message
----------	---------------------------

19990628: experimental locking call
 19990628 temp defined DB_DEBUG and introduced experimental statement options
 19990707: Undefined DB_DEBUG and removed statement options
 19990827: Added CreateIndex
 20000629 Logging of trouble now starts with '****' */
 20001105 Run-time load ODBC routines for BC and WC
 20001128: Added InitializeCriticalSection in 'Open' and DeleteCriticalSection in 'Close'
 20010829: Enabled DB_DEBUG to show db errors in verbose mode
 20020412 Use SQLExecDirectWithRetry to retry in case of any error (deadlock=1205). Added CreateUniqueIndex function, and GetLastError. Ignore error from unique index to make multi-user safe.
 20020413: NOTE: A SINGLE DB MAY NOT BE USED BY MULTIPLE THREADS.
 20020417: Extended deadlock wait time to about 1 min for safety
 20021014: Added built-in dbf support for stable ODBC less-operation
 Note: requires fully de-normalized database; notes: in dbsql, first bind row not set; in vrtsql; debug query print with %s in search crashes
 20021016: Added about 1 MB of in-memory hashed index in patient ID for all tables; speed OK to 10.000 objects; pack db on server start (for speed it is wise to keep DBF files on local harddisk)
 20021017: Made NeedPack a global for control from dgate; fix base_trunc; fix in Updaterecords; fix first num field in AddRecord
 20021020: Made querymodes an array, so that each query field can be key, key% or %key% ; Use querymode also when hashing the entries (part of db entry); Fix process_escape for " and \[and also use it before dbase_write
 20021028: Set open retries shorter for normal readonly access
 20021030: Match alternative patientID fieldname such that built-in DBF queries work
 20021113: Added <= comparison in dbase_query (used for date comparison)
 20030113: Do not use () in sort order when multiple columns specified
 20030128: Added alternative field names for series
 20030321 Also handle 'write lock' for M\$Access (NativeError 1205 for sql-server equals -1102 in M\$Access). Other dbf-drivers??
 20030819 Allow longer filenames
 20031104 Added \\ to process_escape
 20030425 Added DoubleBackSlashToDB control
 20030520 Speedup by fix dbaseIII hashing, setting hashfield was wrong
 20030523 Implemented in-memory index to speed dbase queries; added IndexDBF and PackDBF settings
 20040528 Fix built-in DbaseIII for > 2 GB; index fixed at 10.000.000 records; Fix problem when spaces in patient ID in index generation
 20040528 Added ExtractRecords (dbase III only); fix update/delete for record 0
 20040530 IndexDBF gives MB extra to allocate; skip dbf files starting with X; convert normal queries in SeriesInstanceUID or StudyInstanceUID to indexed ones

20040601 Added LongQueryDBF flag: report if query took longer than LongQueryDBF ms (default 1000); Min 20 MB index during regen; allow pack on command (NeedPack=TRUE; DB.Open) Increase query buffer size to 16384 (often reread), pack buffer to 65536

20040605 Optimize speed for huge files, extract max 100000 records; made lockstart __int64; Do not lock for read in extract (is very slow for huge files); Record lock no longer on physical bytes but on rec#; attempt to speed memory index; NeedPack==3 -> force pack

20040606 Fix lock whole file; fix index patient ID database; fix in dbcreate for test

20040609 Implemented fast in-memory locking and enabled for all shared files

20040610 on dbase_create set indexcount to 0; dbase_trunc truncs indexcount

20040612 Put index creation in a thread; server runs (but does not find non yet indexed records) during indexing; implemented indexdbf command NeedPack=4

20040614 Added NeedPack=5: create non-threaded index (for archival options)

20040615 Added warning when index is full; keep indices when creating db

20040930 Added multiple value query; protect length of copy of where string

20041003 Reused very long SQLStatement string for wheres string
For lenghts see dbsql.cpp; truncated debug printf's
set cols length to 4096; malloc tmp in query at 310000;
for length calculation see dbsql.cpp

20041013 Used MAXQUERYLENGTH

20041029 Fixes in multiple query (query string truncated + mode mix problem)

20041101 DB is read only while in-memory indexing of DbaseIII active

20050102 Small modifications to allow compile through total.cxx

20050107 Export NumIndexing to tell dgate when indexing is done

20050116 Adapted for use with LINUX (built-in dbase driver only)
Notes: 1) delay poorly implemented; 2) no support for >2 GB

20050118 Detach pthreads to avoid leaks

20050119 Documented rare crash in Fill_Memory_Index

20050124 Added support for huge files under Linux (not suitable for ext2 filesystem); Allow = without spaces in query

20050205 Added counters for db activity

20050206 Small fixes to counters; allow "&" instead of " and " for CGI use

20050905 Postgres code by Piotr Filipczuk checked by mvh, will not affect other operations, but not tested yet (postgres will not compile on my linux system)

20050907 Merged change by Hans-Peter Hellemann: lseek64 not always defined, should be mapped byunistd.h

20050909 Put check for = in query below >=: date range matching failed (Thanks Paolo Marcheschi)

20050911 Removed postgres print statements

2005112 Fixed BindField for postgres - now returns actual and not reserved length

20051217 Maximum locks in dbaseIII driver from 1000 to 100 to speed up qunlock (20% regen speed)

20051218 Respond to -b = NOTHREAD: run server as single process, useful for debugging and profiling

20051219 Fixed slow leak of queryfields for built-in dbase driver

20051230 Put index of DicomWorkList on AccessionNumber

20060219 Start on native mysql driver

20060220 Some more work: get correct length in bindfield; todo: user and password

20060226 Runtime load MYSQL in WIN32

20060313 Use username and password for mysql

20060402 Start index threads with a short delay to give GUI priority to test startup

20060607 Changed escape char processing for sql values (not queries) to match dbsql.cpp change

20060618 Fix for Borland C++ builder

20060628 Moved location of disabled query logging

20060630 Speeded dbaseIII AddRecord lots and linux string handling

20060701 Added and use mysql_fetch_lengths; protect query result

20060702 Tested native mysql driver: does not like fast open/close: clonedb crashed after 4000 or so (avoided now)

20061212 Found critical error in built-in dbase driver sql parser: Adding patient with ID containing certain character sequences will immediately overwrite the whole patient database. Queries with these sequences will return too many records (less dangerous). Issue not yet really fixed but greatly reduced its likelihood

20061213 Fixed issue by replacing spaces inside strings in sql statement with non-breaking spaces. Only match on keywords and field names which include spaces; replace with normal spaces in process_escape

20070123 clear NativeError, State and Msg on db.open (e.g. for dbf that does not use them but prints)

20070126 Added missing break in non breaking space field of process_escape: failed on multiple spaces in string

20070201 DebugLevel 4 prints all sql activity\

20070203 Fixed >2GB file support in linux: use O_LARGEFILE and lseek64() - sorry Hans-Peter Hellemann

20070206 Added CreateDatabase (created db and login)

20070207 Removed creation of login from CreateDatabase for mysql and postgres

20070210 Moved debug prints to SystemDebug; removed double log in QueryDistinct for dbaseIII

20070218 Added SQLite (win32 dll version): seems to run now; very slow when sync, very fast async

20070307 Made database type flag local, added Database(type) creator

20070308 Fixed DARWIN ifs, made DARWIN/MySQL auto start.(MySQL is included with DARWIN)

20070315 Merged; changed two nested ifs that had an else that would be wrong

20070406 Use reentrant rand_r and localtime_r when available

20070507 Native mysql does not correctly return empty fields (Steini)

20070702 Fixed above fix; test version for Stephan Winter

20070703 Removed test version code; display mysql connection errors on OperatorConsole

20070705	Added DT_DBASEIIIINOINDEX: disables indexing and packing; #define USESQLITE_DLL to load DLL; otherwise use statically linked sqlite3.c; Extended max number of dbf files to 20
20070709	Fixed crash when mysql not started: format error in the error print
20070711	Some fixes to compile with sqlite under linux
20070715	Removed debug print statements for sqlite
20071027	Maybe fix postgres error handling: reset ntuples
20071030	More fixes to postgres error handling: missing returns in PrintLastError
20071115	Fixed SQL database creation for SQL server 2005
20071118	Adapted for 64 bits (use SQLLEN for BindField)
20071124	Removed dangling WHERE and ORDER in SQL server interface when passing "" instead of NULL
20081116	Adapted for 64 bits linux (avoid use of "long", in dbase code and when reading SQL_C_ULONG)
20081117	Allow compile with both POSTGRES and USEMYSQL
20081119	added run-time loading of postgres for WIN32
20081120	Added UseEscapeStringConstants for dbase (is needed only in one place because in other place the E in E'\\...' is ignored by the current code)
20081121	Implemented CreateDatabase for Postgres; also try load libmysql64.dll (for easy 64 bit deployment)
20081124	Added DT_NULL (black hole)
20081125	Fix critical section in DT_NULL
20081126	Todo: all realloc of dbase index when full; don't use threads to fill
20090202	Fixed problem of database fail open in GUI after install: XADICOMPpatients was never closed, as connected was not set when there were no databases
20090203	Fix crash on SQLite error
20090429	Added libpq64.dll
20090616	Added OldUID as hashfield: indices UIDMods table; increased default index to 10 MB
20090620	Include file stuff

ODBCI.HPP (part of DGATE.EXE)

19990827	Added CreateIndex
20001128	Added CRITICAL_SECTION member of 'Database'
20020415	Added error info, GetNativeError, SQLExecDirectWithRetry and CreateUniqueIndex
20021020	Added built-in dbf support (for stable operation without ODBC) Note: requires de-normalized database
20030120	Ignore Microsoft complaint C4200
20030321	Enlarged buffer for SqlErrorMessage (Database->Msg)
20030819	Allow longer filenames
20040528	Added ExtractRecords (dbase III only)
20040530	Added InternalQuery (for converting normal to indexed queries)
20040605	Made lockstart __int64
20040612	Made lockstart in again - now pure record#; added TotalRec, MBExtra
20041003	Statement length set to 310 kb (see dbsql.cpp for explanation)

20041013	Malloc SQLStatement instead
20050109	Adapted for linux compile
20050905	Postgres code by Piotr Filipczuk checked by mvh, will not affect other operations
20060219	Start on native mysql driver
20060220	Include all required mysql defines here
20060226	Runtime load MYSQL in WIN32
20060628	Use mysql.h proper (for datastructures) even when runtime loading (sorry for the hard include path)
20060701	Added mysql_fetch_lengths
20070206	Added CreateDatabase
20070218	Added SQLite
20070307	Made database type local, added Database(type) creator
20070705	Added DT_DBASEIIINOINDEX: disables indexing and packing; Extended max number of dbf files to 20
20071115	Static mysql use <mysql.h>
20071118	Adapted for 64 bits (use SQLLEN for BindField)
20080107	Removed double declaration of SQLLEN
20080821	Fix for SUNWsprow compiler
20081116	Adapted for 64 bits linux (avoid use of "long")
20081117	Allow compile with both POSTGRES and USEMYSQL
20081119	added run-time loading of postgres for WIN32
20081120	Finished it
20081124	Added DT_NULL
20090114	Increased MAXFIELDS to 100 for clone_xvi

AMAP.CPP (part of DGATE.EXE):

19990827:	added (limited) wildcard mapping in GetACRNema: AE, port or IP may end on '*'
20001105:	replaced m-alloc by new
20011109:	Made AE mapping case insensitive
20020524:	In function 'GetACRNema', first try case SENSITIVE then INSENSITIVE
20030701:	Added compression column (with this code is this column is not optional!)
20030703:	KNOWN BUG: number of columns may not be 3 (crashes)
20030709:	Solved above problem; rewritten parsing of Acrnema.map
20030709:	known bug: trailing spaces lead skip of next line
20030711:	Fixed trailing spaces in acrnema.map
20031118:	Fixed leak InitACRNemaAddressArray

XVGIFWR.CPP (part of DGATE.EXE):

20050129	Adapted for use in the Conquest DICOM server (see //)
20050130	Made it ansi C
20050826	Made it reentrant to avoid gif file corruption in server
20051219	Fixed leak
20070902	Made cpp
20080905	Removed malloc.h for DARWIN
20090620	Include file stuff

JPEG_ENCODER.CPP (part of DGATE.EXE):

20090215	Started on update history
----------	---------------------------

20090412 Added BGRto444(14): accepts RGB instead instead of BGR (!)

WINTYPES.HPP (part of DGATE.EXE, Linux only):

20050111 added SWORD and UWORD

NPIPE.CPP (part of DGATE.EXE, Linux only):

20050111 Blocked out sys/conf.h; compiles with linux but gives linker warning: fattach not implemented and will always fail
20051217 Return (unsigned) 0xFFFFFFFF instead of signed -1
20070308 Change things for BSD and DARWIN.
20070316 Some more fixes

NPIPE.HPP (part of DGATE.EXE, Linux only):

20070308 Added changes for BSD and DARWIN

GPPS.CPP (part of DGATE.EXE, Linux only):

20040111 Fixes: defaults now work, allow DOS files, case insensitive
20070330 Change by Mark Pearson: also allow tabs instead of spaces around =
20090620 Include file stuff

KILLER.CPP (main of KILLER.EXE, which is not part of this release of the Conquest DICOM server):

19980619: Added some doc on command line options and modes
Fixed -L option (moved db.close)
19980620: Made code suitable for external calling; copied some of it to device.cpp. Killer.exe is not needed anymore with NKI
Dgate.exe except as sleeper task because the alert task has been integrated into Dgate.exe
20030702: Adapted because of compression externals required by device.cpp
20030706: Attach VRType to PDU's for implicit little endian support
20050129: Adapted dummy for DumpVR
20071118: Adapted for 64 bits (use SQLEN for BindField)

AAAC.CXX (part of DICOM core library):

19980327: Removed evaluation of Count without initialization in ReadDynamic
20001106: Use memcpy instead of ByteCopy
20030122: Fixed initialization of AAssociateAC
20050108: Fixed for linux compile
20080203: Added experimental ConfigPadAEWithZeros
20080313: Removed some warnings

AARQ.CXX (part of DICOM core library):

20001106: Use memcpy instead of ByteCopy
20001128: Removed two warnings
20030122: Fixed initialization of AassociateRQ

20060618: Added definition of min()
20080203: Added experimental ConfigPadAEWithZeros
20080313: Removed some warnings

AARQ.HPP (part of DICOM core library):

20001106: Use memcpy instead of ByteCopy

CCTYPES.H (part of DICOM core library):

20001107: Fixed to allow compile with BC
20010705: Fixed to allow compile with MSVC 6 (see note below)
20040111 Fix for __GNUC__
20040117 Fix for linux
20070308 Added for DARWIN apple endian defs
20070902 Changed INT32 and UINT32 from long to int for ms7/ms8
compile

ENDIAN.CPD (part of DICOM core library):

20001106: removed unneeded (and sometimes uncompileable)
XE_UINTX::XE_UINTX (int x)

ENDIAN.HPD (part of DICOM core library):

20001106: removed unneeded (and sometimes uncompileable)
XE_UINTX::XE_UINTX (int x)

ENDIAN.CXX (part of DICOM core library):

20070330 Merged bcb stuff

ENDIAN.HPP (part of DICOM core library):

20090215 Started an update history

DICOM.HPP (part of DICOM core library):

20071102: Define SetDicomErrorHandler etc
20080203: Added experimental ConfigPadAEWithZeros
20090211: Added DCM_ERROR_PARSE
20090802: Added DCM_ERROR_DEBUG

RTC.HPP (part of DICOM core library):

19980331: Added prototype for writing binary RTCs

TRNSYN.CXX (part of DICOM core library):

19980409: Fixed possible transition between presence and absence
of TypeCodes in 'Dynamic_ParseRawVRIntoDCM'
19990904: Treat type UN same as OB,OW and SQ when reading Explicit
files.
20001106: Replaced == operator by strcmp

20010905: Several fixes: UCDCM should NOW be able to read ExplicitBigEndian files

20011220: Fixes in Sequence and Item delimiters

20030122 Fixed small leak in Dynamic_ParseRawVRIntoDCM

20030205 Support new datatype 'UT' (unlimited text). Thanx to William Peterson

20030424 Changed prototype of ParseDCMIntoRawVR. Fixed huge bug in sending of ExplicitLittleEndian sequences

20030627 Fix for MSC 4.2

20030725 Keep GroupLength for group 0x00 (Radworks 6.0 was choking in this)

20040406 Make TypeCode 'UN' if not known, and conversion to Explicit is wanted

20050112 Fixed huge bug in Explicit_ParseDCMIntoRawVR, causing data-loss. Thanx to Goran Peros.

20051217 Use new VR::ReAlloc method to replace data in VR

20051218 Use memcpy to enter UID (extra 0 will be available: end of string)

20051219 Use ReAlloc instead of new BYTE[] to fill VR data

20051229 Moved Push in ParseRawVRIntoDCM so that not done when VR exists

20070308 Added big endian stuff

20071031 Removed some commented out code

20071108 In Dynamic_ParseDCMIntoRawVR(), let group 0x08 behave the same as all other groups greater than 0x02.

20071118 NOTE: previous change is not in release 1.4.13

20071128 Add TypeCodes if needed using AttachedRTC->RunTimeClass

20080913 Fix in bigendian input: interpret group 0 as littleendian

20090211 Added many checks on corrupt dicom data during parsing; removed blocked out code

20090212 Fixed a problem in the check code if some (but not all) group lengths are missing

20090215 Improved formatting of lenght error message

20090620 Added <stdlib.h>

20090824 Resume parsing after invalid element length if length was not too big

RTC.CXX (part of DICOM core library):

19980330: Added an RTC memberfunction for loading the dicom library from memory (e.g. a resource).

19980331: Added function for writing binary RTCs (function was originally implemented in 'makebrtc.cxx')

19980414: Added RTC::GetGroupElement memberfunction, to retrieve the Group and Element numbers using a library keyword.

20071128 Do not remove existing TypeCode if new one is unknown

20090620 Always include stdlib.h

DEIVR.HPP, DEIVR.CXX (part of DICOM core library):

19990318 Added 'DICOMObject::DeleteVR'

20001106 Used delete [] operator for vr->Data

20010426 Fixed small leaks in 'DICOMObject::DeleteVR'

20010730 Added 'DICOMObject::ReplaceVR'

20010802 Added 'VR::GetSpecialValueCodeOfVR'

20011121	Added VR_SPECIAL_RGB_TO_MONO. Used by a conversion-tool to change ultrasound Kretz RGB images to monochrome that VariSeed (brachytherapy) understands.
20011121	Added VR_SPECIAL_RGB_TO_MONO_PLUS. Same as above, but tries to preserve colored drawings.
20051217	Added 'VR::ReAlloc'
20051217	Use malloc/free instead of new char[] and delete []
20051229	Removed unnecessary reset() in DeleteVR
20071031	Temp printf memory error messages
20071102	Send allocation errors to DicomError
20080313	Removed some warnings
20080910	Added VR::VR(UINT16 g, UINT16 e, UINT32 l, LE_UINT16*d) &VR::VR(UINT16 g, UINT16 e, UINT32 l, LE_UINT16 *d, BOOL mFlag) for big endian.
20081016	Fix for WC: new of 0 gives NULL (check Length in error message)
20090620	Added <stdlib.h>

ENDIAN.HPP (part of DICOM core library):

20090215	Started an update history
----------	---------------------------

SOCKET.CXX (part of DICOM core library):

20010426	Added 'setsockopt' in 'Listen' and 'Open' Call 'shutdown' before closing a socket
20010720	Changed 'print' to 'fprintf(stderr,...)'
20050116	Adapted for LINUX compile
20050119	Blocked out SOCKET END ERROR message
20070406	Use reentrant gethostbyname_r when available
20070415	Small fix there for windows
20090620	Added unistd.h for UNIX
20090824	Debug output of adress connecting to socket

SAFEMEM.CXX (part of DICOM core library):

20010720	Changed 'printf' to 'fprintf(stderr,...)'
----------	---

DIMSEN.CXX (part of DICOM core library):

19990415	Removed static on TranslateUIDToVR
20020822	Use instead of DIMSEN.CPP
20071118	Removed faulty overloaded 'NGetRQ::Write'
20080905	Removed (void*) cast for deivr change

DIMSEN.HPP (part of DICOM core library)

20020822	Cleanup layout
----------	----------------

DIMSEC.CXX (part of DICOM core library):

20030219	Removed MessageID and Priority from the 'write' functions of CStoreRSP, CFindRSP and CMoveRSP
20030606	Added parameter 'QueryRetrieveLevel' to CFindRSP::Write
20030811	Do not send DDO in CMoveRSP::Write (DicomEye and OFFIS do not like that).

20050129	Added Write with extra vr to CEchoRSP
20051222	Do not add query level if already exists
20070308	Made changes for big endian
20070314	Allow send of 0000,1030 (MoveOriginatorAE) and 0000,1031 (MoveOriginatorMessageID) in CStoreRQ
20070330	Merged bcb's Darwin and Endian stuff
20080203	Added experimental ConfigPadAEWithZeros
20080910	Removed big endian changes from here and moved to deivr

DIMSEC.HPP (part of DICOM core library):

20030606	Added parameter 'QueryRetrieveLevel' to CFindRSP::Write
20050129	Added Write with extra vr to CEchoRSP
20070314	Allow send of 0000,1030 (MoveOriginatorAE) and 0000,1031 (MoveOriginatorMessageID) in CStoreRQ

UNIQ.CXX (part of DICOM core library)

19990511	Fix: All routines wrongly used '%' instead of '&'
----------	---

MAKEBRTC.CXX (part of DICOM core library)

19990415	Note: requires changelog
----------	--------------------------

PDU.CXX (part of DICOM core library):

19980322	Blocked one remaining printf statement "comparing ..."
19990202	Added PDU memberfunction 'IsAbstractSyntaxAccepted'
19990415	Merged both versions
20000322	Fix in search for PresentationContext when identical AbstractSyntaxes occur (e.g. GECT-scanner). Do not break out of the inner loop in PDU_Service::InterrogateAAssociateAC.
20000322	Fix of PresentationContextID in PDV: in routines PDU_Service::Write(DICOMObject*, UID*), set PresentationContextID to TempByte, not to TempByte1.
20000911	Removed two warnings
20020316	Added GetLocalAddress and GetRemoteAddress
20030306	Fix: Huge bug in 'InterrogateAAssociateRQ'
20030424	Blocked out obsolete PDU.Write(&DDO) Some work on offering other TransferSyntaxes than ImplicitLittleEndian when running in SCU mode (Note: when running in SCP mode, 'dgatesop.lst' is used) Fix: CommandObjects are always ImplicitLittleEndian
20030627	Fix for MSC4.2; re-enabled obsolete write calls for test.cxx
20030710	Adjusted test.cxx, and disabled obsolete calls again
20080816	ValidPresContexts is now a global: how many incoming connection can handle
20090802	Added DCM_ERROR_DEBUG statements to debug failed connect

PDU.HPP (part of DICOM core library):

19990202	Added PDU memberfunction 'IsAbstractSyntaxAccepted'
20020316	Added GetLocalAddress and GetRemoteAddress
20030424	Changed prototype of ParseDCMIntoRawVR

20030627	Fix for MSC4.2
20030905	Removed spurious ;
20080816	ValidPresContexts is now public: how many incoming connection can handle
20080819	CanYouHandleTransferSyntax is now public; use BOOL not bool

FILEPDU.CPP (part of DICOM core library):

20000420	Fix in MakeChapter10: type of AffectedSOPClassUID and RequestedSOPClassUID
20030205	Fixed FileMetaInformationVersion for big-endian machines
20030424	Put the correct TransferSyntaxUID in chapter10 files
20041108	Fix strdup memory access problem (found using \$c drop file test mode)
20051229	Fixed LEAK of 68 bytes when 0002,0010 not defined
20060618	Added definition of _SH_DENYNO
20090211	Check result of Dynamic_ParseRawVRIntoDCM

BUFFER.CXX (part of DICOM core library):

20001106:	Use memcpy instead of ByteCopy
20071031:	Temp printf allocation errors
20071102:	Send allocation errors to DicomError
20081016:	Default buffer size from 1024 to 10240

VERSION.H (part of DICOM core library):

200107017	Changed ImplementationClassUID to a valid UID: the Agfa dicom validation tool protested against the original 'UID'. Changed ImplementationVersion from "0.1B/WIN32" to "1.01/WIN32"
20020416	Changed IMPLEMENTATION_VERSION_STRING to 1.3.11/WIN32
20021018	Changed IMPLEMENTATION_VERSION_STRING to 1.4.0/WIN32
20020208	changed IMPLEMENTATION_VERSION_STRING to 1.4.1/WIN32
20030424	changed IMPLEMENTATION_VERSION_STRING to 2.0.1/WIN32
20030709	changed IMPLEMENTATION_VERSION_STRING to 1.4.2/WIN32
20030815	changed IMPLEMENTATION_VERSION_STRING to 1.4.3/WIN32
20030402	changed IMPLEMENTATION_VERSION_STRING to 1.4.4/WIN32
20040530	changed IMPLEMENTATION_VERSION_STRING to 1.4.5/WIN32
20040713	changed IMPLEMENTATION_VERSION_STRING to 1.4.6/WIN32
20041101	changed IMPLEMENTATION_VERSION_STRING to 1.4.7/WIN32
20050901	changed IMPLEMENTATION_VERSION_STRING to 1.4.9/WIN32

20060103	changed IMPLEMENTATION_VERSION_STRING to 1.4.10/WIN32
20060311	changed IMPLEMENTATION_VERSION_STRING to 1.4.11/WIN32
20060708	changed IMPLEMENTATION_VERSION_STRING to 1.4.12/WIN32
20070307	changed IMPLEMENTATION_VERSION_STRING to 1.4.13/WIN32
20080831	changed IMPLEMENTATION_VERSION_STRING to 1.4.14/WIN32

FLPDU.CXX (part of DICOM core library):

20050130	Allocate 1 item longer lists to allow configuration from GUI
20050213	Fix to allow windows created file as input under linux
20060618	Added definition of _SH_DENYNO
20090802	Added DCM_ERROR_DEBUG statement to debug failed connect

FLPDU.HPP (part of DICOM core library):

20050129	Made tables public for config
20080819	Made CanYouHandleTransferSyntax public

VERIFY.CXX (part of DICOM core library):

20050129	Added ReadRequest and WriteResponse, allows extra response vr
----------	---

VERIFY.HPP (part of DICOM core library):

20050129	Added ReadRequest and WriteResponse
----------	-------------------------------------

QRSOP.CXX (part of DICOM core library):

20020429	Fixed reporting of number of complete slices (now starts with 1); return cancel status if C_STORE failed
20030606	Added parameter 'QueryRetrieveLevel' to CFindRSP::Write
20050401	Added ModalityWorkListQuery
20051222	Added pADD0 to Query::Write method - answer appended to pADD0 if set
20080820	Solaris fix (do not use variable name SS)
20090205	Added QueryMoveScript callbacks

QRSOP.HPP (part of DICOM core library):

20030606	Added member-variable 'QueryRetrieveLevel' to StandardQuery
20050401	Added ModalityWorkListQuery
20051222	Added pADD0 to Query::Write method - answer appended to pADD0 if set
20090205	Added QueryMoveScript

STORAGE.CXX (part of DICOM core library):

20020429	check status of C-STORE RSP and return FALSE if failed
20030922	Added PDU_Service to CheckObject call
20070307	Added more debug error messages to retrieve
20070314	Allow send of 0000,1030 (MoveOriginatorAE) and 0000,1031 (MoveOriginatorMessageID) in StandardStorage : Write
20070315	Blocked out printf statements

STORAGE.HPP (part of DICOM core library):

20030922	Added PDU_Service to CheckObject call
20050108	Fixed for linux compile
20070314	Allow send of 0000,1030 (MoveOriginatorAE) and 0000,1031 (MoveOriginatorMessageID) in StandardStorage : write

PRINTSOP.CXX (part of DICOM core library):

20020814	Added some comments and block-out mvh's debug code
20020816	Fix in 'AbstractPrintManagementMeta::Write'

CQSERVER.CPP (Part of conquest interface DLL):

1998xxxx	Creation. This file contains DicomServer code. A 'DicomServer' is an application that receives images, and is called a server because it 'provides' disk-space!? All code is reached by the routine 'ReceiveThread' at the end of this file. The ReceiveThread is launched by the exported function 'DcmMoveHere' in CqDicom.cxx. Communication with the mainthread is done by using global variables (sorry).
19990318	Added support for MultiFrame modalities
19990407	Swapped priority of VRs 0020-0050 and 0020-1041; now the slicelocation is preferably deduced from 0020-1041.
19990915	FillSliceInfo now also indicates whether pixeldata are 'unsigned'.
19991028	Fix (in cases that went wrong anyhow): changed 'free' to 'DllFree'.
19991029	Added 'Signed_compute' to convert unsigned short pixeldata
19991122	nki_private_decompress now supports Mode=2
20000131	Fix: Replaced an instance of free by DllFree
20000321	FillSliceInfo now also retrieves 'BitsStored'
20000405	Added CheckRangeOfCT, to Calibrated CT-values to Hounsfield + 1024, and to cut the values below 0.
20000418	Fix: crash on (INVALID !!) Siemens demo-data on RSNA 1994(CR images of RXDpat1-1994). PixelRepresentation tag was empty!
20000530	Use different pixelspacing tag for RTIMAGE
20010123	Moved code to GetSliceCoord; added static keywords
20010410	Improved communication between MainThread and ServerThread
20010411	Do not 'sleep' the ServerThread, but let it terminate
20010426	Again improved communication between MainThread and ServerThread
20010508	Replaced nki_private_decompress by a faster version
20010717	Added 'CheckRTDoseScaling'
20010720	Made Dummy::printf do nothing
20010905	Added 'CheckModalityLUT'

20020227 Support US pixelspacing (hiding in SequenceOfUltrasoundRegions)
 20020425 Added exported funtion 'ComputeCRC'
 20020609 Pasted extended decompressor from NKIQRSOP.CXX
 20020613 Moved MkTypedDicomObject to here
 20020620 Guess SliceLocation in multi-frame images.
 20021028 Support multiframe dose-grid in 'CheckRTDoseScaling', and slice-positions in 'GridFrameOffsetVector'
 NOTE: Varian multiplies and Helax divides by the DoseGridScalingFactor !!!
 20021113 Guess SliceLocation in multi-frame images (SliceThickness).
 20021213 Adjusted field-coordinates of RTIMAGE
 20030122 Support various Ultrasound pixelspacings
 20030127 FillSliceInfo now also retrieves 'PhotometricInterpretation'
 20030128 Support for 3D TimeSequences, resulting in 4D 4-space output scans
 20030213 Fixed bug in change above
 20030624 Workaround for Varian Vision 7.1 multiframe dosegrids
 Support for integer dosegrids and very small DoseGridScaling
 20030904 Improved workaround for Helax DoseGridScaling
 20041119 Added support for 4D object in slices
 20051219 Use vr->ReAlloc
 20060515 Also apply RescaleSlope and NEXT_VOXEL_DOUBLE to modality PT
 20060704 Don't apply yet...
 20060913 Work on Philips MR: get PixelSpacing and PatientPosition from deep inside sequences. Replaced GetFloatsFromKey call by GetFloatsFromVR calls
 20070404 Heavily optimized InsertSlice: first transpose then insert biggest gain (10 s) Uncompress during read gains 2 s
 20070506 Added optional prealloc data pointer to CreateOutputField
 If LargeScan (>256 MB) decompress later to save memory
 20070522 In CheckRTDoseScaling() take PLATO negative dose into account
 20070704 Fixed InsertSlice(): non-square slices went totally wrong
 20070730 Dirty fix for CMS RTDOSE
 20071127 Fixed bug in AddToOutputField (affects multiframe slicepositions)
 20080313 Removed some warnings
 20080410 Fix: In CheckRangeOfCT(), unsigned CT pixels were ill-treated.
 20080818 Added support for philips 3D US (200d, 3303)
 20081014 Fixed dose reading: broken by above change
 20090131 Exported tranpose routines for CqCreateDcm
 20090602 Added sensible Time-coordinate (AcquisitionTime) for 4D slice-based images. Works for our PET and MR scanner...

CQDICOM.CXX (part of conquest interface DLL):

19980330 Creation
 19980331 Added exported DcmMkBinaryLib
 19980414 Restricted the HeaderDump to max 4096 data, and the number of bytes on one line to 256.
 19980416 Added sequence support in HeaderDump

19980420	Fixed last written line in multiple line sequence dump. Added functions DcmFind, DcmMove and DcmMoveHere
19980526	Added DcmCreateBitmap
19980610	Changed BGR to RGB in DcmCreateBitmap. Added DcmMoveHeaderHere
19980629	Fix: DimX and DimY were reversed. Improved efficiency when loading one slice.
19980630	Fix: last change caused crashes
19980707	Removed some checks to allow non-standard Philips images. Added DcmSetProgressHook
19980708	Added DcmReplaceInHeader, which can be used for anonymization of dicom images.
19980709	Added C-CANCEL command object when a ProgressHook stops or aborts a DcmMove operation. Added support for NkiPrivateCompressed images in DcmMoveHere.
19980826	Added #pragma pack(1) in Field.h
19981105	Added DcmReadHeader
19981127	Added DcmGetLastXfms
19990108	Updated the dictionary for DICOM-RT support
19990114	Slices are sorted on coord. When duplicate coords exist, the last received slice eliminate previous ones. Included changed SOP-list by MvH
19990318	Added three xxxRetrieveNKI PresentationContextSOPs in the function DcmMoveHere
19990407	Swapped priority of VRs 0020-0050 and 0020-1041; now the slicelocation is preferably deduced from 0020-1041.
19990511	Added DcmSetLocal(char* pszLocalAE, char* pszLocalPort)
19990628	Fix: DcmCreateBitmap did not like MultiFrame dicom files
19990826	Added DcmSetFreeHook and DcmMoveFilesHere
19990906	Added DcmSetExtraParams to support (amongst others in the future) transmission of downsized Dicom images between NKI stations.
19990913	Private VRs of unknown type, will possibly be shown in the headerdump as character strings.
19990915	Fix in ParseLine of headerdump. Added support for unsigned pixeldata in DcmCreateBitmap.
19991019	Allow multiple slices with the same or without a coordinate, if this is the case for ALL slices (e.g. multiple scout-views in one series)
19991022	Changed the root of NKI-made UIDs to the official one supplied by Medical Connections(UK): 1.2.826.0.1.3680043.2.135.1066.xxxxxxxxxx
19991028	Converted unsigned short pixels to signed int pixels
19991122	Added DcmStoreFiles
20000126	Fix in WorldXfm (bug introduced on 19991019)
20000128	Fake slice-coords when a '3D volume' consists of e.g. multiple scout-views (Siemens MR produces such series). Prevents viewer-crash when loading a second volume into it.
20000321	Convert unsigned short to integer ONLY if all 16 bits of the pixeldata are used. Better contrast-stretch in DcmCreateBitmap.
20000327	Added C-ECHO command
20000405	Calibrated CT-values to Hounsfield + 1024. Cut-off below 0.
20000707	Added DcmSetCacheAddress
20000829	Added an ErrorMessage

20001128 Replaced 'Oh shit!' error message by 'Cannot find related scan'.
20010123 Added static keywords.
Moved code to GetSliceCoord; this routine checks besides tags (0x0020,0x1041) and (0x0020,0x0050) also (0x0020, 0x0032). This last tag (ImagePositionPatient) had to be used for Philips MR scanners.

20010302 Fix: improved temporary filename
20010410 Improved communication between MainThread and ServerThread. Again improved temporary filename...

20010411 Kill ServerThread only if it is not responding
20010413 Fix: always close the threadhandle
20010426 Again improved communication between MainThread and ServerThread

20010508 Adjusted call of nki_private_decompress to a faster version
20010619 Fix in GetFloatsFromKey (crashed on PatID 1234567890 NuclearMedicin testpatterns)

20010717 Adjusted DcmMoveHere for RTDose post-processing
20010802 DcmReplaceInHeader now also supports replacements inside sequences; Added export DcmVersion

20010808 Fix: SetStringVR appended a NULL byte to strings with uneven characters. This is correct for UIDs, all other strings should have a space appended.

20010824 Updated 'soplist.txt' resource to DICOM 1999 final text.
20010905 Fix: Headerdump was incomplete when a VR consists of more than one short or int; Start implementation of ModalityLUT

20011121 Replaced 'SetStringVR' by 'SetAnyTypeVR' (Used by DcmReplaceInHeader)

20011218 Added DcmWriteKretzFile: extracts a Kretz 3D file from a dicomfile

20020225 Fix for Helax-TMS: when determining XFM's and (0x20, 0x1041) and (0x20, 0x50) are both absent, use (0x20, 0x32)

20020403 Fixed bug when UIDs are 64 bytes long. Some code butifying.
20020411 Added DcmWriteVRToFile
20020502 Added cacheing properties
20020522 Replaced ad hoc field allocation code by 'AVSdata_alloc'
20020523 Do not give warning for slice-order (DCM_E_SLICEORDER)
20020609 Pass MaxCompressionMode that is set to 4
20020620 Adjustment to CalcXfm for multi-frame images.
20020814 Added two Print error-messages
20020930 Added MAXSLICES to optional extraparams
20021028 Exported GetFloatsFromKey. Try to get XFM's of multiframe objects right.

20021105 Get rid of scout-views when loading a volume (in 'SortSliceDDOs')

20021118 Fix in multiframe XFM containing 'GridFrameOffsetVector'

20030122 JPEG pixeldata support; Fixed memory leak
20030128 When SliceCoords are not provided, sort dicom-objects on imagenumber

20030130 Support for 3D private Kretz ultrasound
20030424 Changed all calls to obsolete PDU.Write(&DDO) to PDU.Write(&DDO, uid). Fix in handling of JPEG compressed images. Version to 2.0

20030519 Fix XFM's when ImagePositionPatient contradicts SliceLocation. Now the slicecoord in ImagePositionPatient is preferred (Marconi-fix).

20030523	Fix: above change frustrated coronal and sagittal MRI
20030716	Workaround for sloppy Adac NM multiframe reconstructions (@#\$%^&*)
20041116	Start on time series recognition, now return unsorted
20041117	'proper' time series (with exact N copies of each slice with given coordinate) are sorted on derived frame# (order of image#) then coords; but still returned as 3D. MATPEL and WRLDMATC know how to make 4D data out of such image data (CONQUEST does not yet). This option should read 4D CT (not tested) as well as 4D MRI/DTI (tested) as long as all frames are sent as one series.
20041119	Adjustment in CalcXfm
20041119	Added support for 4D sliced object, now sent out as 4D field
20041124	Merged fix ljz 20041119
20041201	Improved detection of 4D data, now allow fringes, e.g., if slices at certain locations occur NMMMMKL times, N slices at start and K+L slices at end are removed. In this way, both Philips and GE DTI and perfusion data (without fringes, e.g., MMMMMM) and Siemens RCCT data is supported. Note 1: Siemens writes % of cycle in 0018,0022 as 'TP100PC5576', where 100 is the %. Not used for now, 4D data is just ordered based on slice number instead, with coordinates 0, 1, .. Note 2: some localizer series are now returned as 4D as well.
20041221	Fix in 4D reader for out-of order images; first sort on image#, later in index
20050301	Fix in dubious check on 'Proper4D'
20050308	One more check on 'Proper4D': at least half of the slices should be Proper4D; Fix in last check
20050418	Fix in WriteBmp when all pixelvalues are equal
20050804	Fix in check on 'Proper4D'
20050905	Added SOP 31 for query: modality worklist query
20060531	Moved FreeOutputField to field.cpp and field.h
20060701	Added warning on order of 4D data - MessageBox needs to be replaced
20060913	Replaced GetFloatsFromKey call by GetFloatsFromVR calls
20061020	Fixed bug in GetFloatsFromVR
20061030	SortSliceDDOs crashed on MR scans from Lucas hospital
20070112	Added exported function DcmReadJpeg
20070119	Using DcmSetExtraParams SORTMODE=1, slices will be sorted on ascending coordinate, SORTMODE=2 means descending. Fixed bug in SortSliceDDOs.
20070220	Fixed bug in SetAnyTypeVR; Added an error message
20070220	Attempt to fix frame reversal - debug code temp off
20070506	prealloc data pointer during recieve to allocate large block first: allows loading larger scans
20070730	Dirty fix for CMS RTDOSE
20070902	DcmWriteVRToFile will now also write sequence item to file as raw VR dump; takes Index as extra par
20071127	Support for multiframe-objects where ImagePositionPatient is located in a DetectorInformationSequence
20080313	Fix: In SortSliceDDOs(), long ScanOptions could lead to crashes or other undesired behaviour; Removed some warnings
20080318	In CreateLastPropertiesField(), a few properties that resided deep in sequences for RTDOSE were added.
20080320	...and put in a separate function

20080717	Support of Pinnacle DOSE in CalcXfm()
20080812	Support of Varian's Eclipse DOSE in CalcXfm()
20080908	Implemented &Philips to load embedded 4D ultrasound
20081007	Compute location of philips subvolumes by length/N
20081014	Also accept QueryIni-fields that contain Header/Key/Value instead of Key/Value
20090605	Fixed crash in DcmMoveHere() when GetDDOarray() returns OK, but no data were received
20090608	Fix: Due to different AcquisitionTime the warning 'Inconsistent Slices' was given too often
20090610	Added "Upi is NOT unique: DANGER !!" error-message

CQDICOM.H (part of conquest interface DLL):

19980330	Creation
19980331	Added exported DcmMkBinaryLib
19980414	Restricted the HeaderDump to max 4096 data, and the number of bytes on one line to 256.
19980416	Added sequence support in HeaderDump
19980420	Fixed last written line in multiple line sequence dump
	Added functions DcmFind, DcmMove and DcmMoveHere
19980526	Added DcmCreateBitmap
19980610	Changed BGR to RGB in DcmCreateBitmap.
	Added DcmMoveHeaderHere
19980629	Fix: DimX and DimY were reversed.
	Improved efficiency when loading one slice.
19980630	Fix: last change caused crashes
19980707	Removed some checks to allow non-standard Philips images
	Added DcmSetProgressHook
19980708	Added DcmReplaceInHeader, which can be used for anonymization of dicom images.
19980709	Added C-CANCEL command object when a ProgressHook stops or aborts a DcmMove operation. Added support for NkiPrivateCompressed images in DcmMoveHere.
19980826	Added #pragma pack(1) in Field.h
19981105	Added DcmReadHeader
19981127	Added DcmGetLastXfms
19990108	Updated the dictionary for DICOM-RT support
19990114	Slices are sorted on coord. When duplicate coords exist, the last received slice eliminate previous ones.
	Included changed SOP-list by MvH
19981127	Added DcmTree, DcmPatientList and DcmSetLocal
19990825	Added extended patientlist export: DcmPatientList2
19990826	Added DcmMoveFilesHere
20000824	Added DcmFileGetRtStructNames and DcmFileGetRtStruct
20020425	Added DcmVersion and DcmCreateRtStructFile

CQCREATEDCM.CPP (part of conquest interface DLL):

20020417	Created. All created DICOM stuff should go in here
20020502	DcmCreateRtStructFile seems to work
20041119	Work on DcmCreateSliceFiles
20041128	Tested write new scan on grid (and properties) of existing scan: needs ScanToDicom matrix to correctly compute ImagePositionPatient; writes too many \\\\ in tags;

SliceLocation not written; Now write abs slice thickness;
 Added missing *10 in Z coordinate of ImagePositionPatient;
 Added a minus to the Z coordinate of ImagePositionPatient:
 this is a kludge that works only for scans read with CQDICOM
 without rotations in scanner. Added creation date and time in
 default series description

20041223 Added XFM parameter to DcmCreateSliceFiles
 Added DcmCreateRtPlanFileLight
 Fix: also incorporate ImageOrientationPatient,
 FrameOfReference, StudyID

20050906 Some fixes in DcmCreateSliceFiles
 Added 'DcmCreateRtPlanFileLight()'

20051018 Several fixes in DcmCreateSliceFiles:
 - Required tags KVP and PositionReferenceIndicator were
 missing - Element numbers of RescaleSlope and
 RescaleIntercept were wrong; Set all MU's to 0 in
 DcmCreateRtPlanFileLight; added OperatorsName

20060704 Increased stringbuffer in GetContouData() (crashed
 ridiculously detailed on ESTRO data)

20061018 In DcmCreateSliceFiles, don't insert sequence items.

20070220 Moved UID_ROOT to somewhere else

20070423 In DcmCreateSliceFiles, use scan or extra properties for
 ImagePositionPatient

20070510 Made GetInterpretedType() more aware of markers.

20070705 Fixed bug in DcmCreateSliceFiles()

20070726 In DcmCreateSliceFiles, don't insert sequence items of
 ExtraProperties either!

20071018 In DcmCreateRtStructFile(), the created UID is stored in a
 global for later use

20080416 DcmCreateSliceFiles() also supports 4D and non-CT data

20080603 Few adjustments in DcmCreateSliceFiles()

20080708 Made PixelSize always positive in DcmCreateSliceFiles()

20080717 The filename parameter of DcmCreateSliceFiles() may also
 contain RemoteAE;RemoteIP;RemotePort for immediate
 pushing of created slices

20080930 Fixed bug in last change

20081001 Adapted for BCB's VR() change

20081002 Moved filename containing RemoteAE;RemoteIP;RemotePort
 to separate function

20081027 In DcmCreateUID(), the last digits are now time related, and
 not the IP address of the caller (adjustment to XVI
 requirements).

20090127 Had a go in implementing xfm in DcmCreateSliceFiles
 Fixed access to ReferencingPhysician in DcmCreateSliceFiles
 Fixed read only problem of pszFileName in
 DcmCreateSliceFiles, and allow AE;IP;PORT without trailing ;

20090128 Revamped xfm in DcmCreateSliceFiles: xfm is now
 ScanToDicomPatient

20090130 Fixed it! And documented code to write as read

20090131 Created ad-hoc, dicom and siddon modes (passed in
 iNewSTudy)

20090210 In DcmCreateSliceFiles, Series and Image Date/Time can be
 set in pExtraProps when it is NOT a new Study.
 SoftwareVersion can also be set in pExtraProps.

20090513 Support private and short tags in DcmCreateSliceFiles()

20090523	Allow RTDOSE export through DcmCreateSliceFiles: expects dose always in 0.01 Gy;Max number of slices to 2000; added missing test on presence of pXfm
20090524	Reverted a line of test code
20090602	Fixed handling private tags in IsGroupElement()

CQGLOBAL.H (part of conquest interface DLL):

19990318	Some cosmetics
19990511	Added a few warnings and prototype of MoveDDOHere
19990915	Added PixelRepresentation (0028,0103) in SLICE_INFO.
19991028	Added prototype of Signed_compute()
19991122	Added errorcode of failed C-STORE-RSP
20000317	Added BitsStored (0028,0101) in SLICE_INFO.
20000405	Added CheckRangeOfCT prototypes
	Added RescaleIntercept (0028,1052) in SLICE_INFO.
	Added RescaleSlope (0028,1053) in SLICE_INFO.
20000530	Added ImagePlanePixelSpacing (3002,0011)
20000707	Added gl_ppvCache
20000710	Added prototype of CacheInitFromSelectionStrings
20000824	Added prototype of CacheSetReferencedStruct
20000828	Added prototype of Dxfrm_compute
20000829	Added an ErrorCode
20010123	Added prototype of GetSliceCoord
20010410	Added gl_hevEndReceive
20010426	Renamed gl_hevEndReceive to gl_hReceiveThreadIsListening
20010508	Changed prototype of nki_private_decompress()
20010629	Added DoseGridScaling (3004,000e) in SLICE_INFO.
20010717	Added gl_pszExtraParams
20010831	Added prototype of CheckModalityLUT
20020418	Added prototypes for cache-ing properties
20020424	Added declaration of field gl_pLastProperties
20020613	Added prototype of MkTypedDicomObject
20020814	Added two Print error-codes
20021028	Added prototype of GetFloatsFromKey
20021213	Added RtImagePosition to SLICE_INFO structure
20030122	Added prototype of DecompressJPEG
20030128	Added 'iNbTimeSequences' and szPhotometricInterpretation to the SLICE_INFO structure
20030129	Added prototype of READ_KRETZ_compute
20041119	Added support for 4D sliced object
20050203	Added prototype of CacheCleanupRtObjectFiles
20050906	Added prototype of CacheGetReferencedProperties
20060913	Added prototype of GetFloatsFromVR
20070130	Added ec DCM_E_INVALID_RTPLAN
20070220	Sdded a few prototypes and an errorcode
20070506	Added optional prealloc data pointer to CreateOutputField
20070522	Added szSoftwareVersions to SLICE_INFO structure
20080717	Added prototype of DcmStoreFiles
20081002	Added prototype of FileNameOrDicomNode
20090204	Added prototypes for transpose_Xbytes_inplace()
20090602	Added fAcquisitionTime to SLICE_INFO, for coodinates of 4th dimension
20090610	Added DCM_E_MULTIPLE_RTPLAN, used when 'UPI' is not unique

CQRTOBJECTS.CPP (part of conquest interface DLL):

19990407	Created. All DICOM RT stuff should go in here
19990404	Added RTSTRUCT
19990511	Added RTPLAN. Still under construction !!!
19990825	Some changes in RTPLAN; still under construction
20000619	Added GetStructInfo to be used by TREE
20000707	Lots of work on RTSTRUCT and RTPLAN
20000828	Structure and beams has wrong XFM when patient is prone
20000829	Added GetRtBeamFromRtImage
20010302	Fix: improved temporary filename
20010410	Again improved temporary filename...
20010619	Added some comments on RTPlan organization.
20010717	Store szReferencedFrameOfReference in STRUCT_TREE_INFO; To do: in 'CalcBeamXfms' the collimator angle is not treated right when the patient is prone.
20000824	Added DcmFileGetRtStructNames and DcmFileGetRtStructFixed two small memory leaks.
20020225	Fixed free-ing twice in 'GetRtStruct'
20020502	Removed some warnings
20020613	Moved MkTypedDicomObject to CqServer.cpp
20030122	Some work on GetRtBeamFromRtImage: still under construction due to world-wide lack of good data!!!
20030520	In GetRtStruct, fail with DCM_E_INTERNAL when there is no cached underlying scan.
20050125	Made beam field output contain short data instead of char data GetRtBeam has an optional string parameter to load a specific segment (= controlpoint); Added GetPlanInfo for TREE building purposes
20050131	Moved MkTypedDicomObject() in GetRtBeam to StoreBeamPropertiesInCache
20050201	Fix: do not delete pDDO in GetRtBeam anymore
20050202	Fix: When settings of a controlpoint do not change, they may be defined only at controlpoint 0.
20050921	Change in CalcBeamXfms for FeetFirst and Prone patient- positions (This change is already in use for two months, and has been approved by Peter Remeijer)
20070705	Gave individual contours instead of organs a unique number (solves the problem of more than one contour in a slice)
20080313	Removed some warnings
20080717	Removed empty structures from the PatientTree in GetStructInfo()

CQRTOBJECTS.H (part of conquest interface DLL):

19990407	Created
20000619	Added prototype of GetStructInfo
20000707	Added more RtObjectXXX prototypes
20000824	Added szReferencedStruct to BEAM_TREE_INFO. To be used in order to get the XFM of a beam IFF RTPlanGeometry equals 'PATIENT'. In the other case (when RTPlanGeometry equals 'TREATMENT_DEVICE'), the the XFM is defined by the 'IEC fixed coordinate system'; this case is not handled in CqDicom.
20000829	Added prototype of GetRtBeamFromRtImage

20010717 Added szReferencedFrameOfReference in
STRUCT_TREE_INFO
To do: in 'CalcBeamXfms' the collimator angle is not treated
right when the patient is prone.

CQTREE.CPP (part of conquest interface DLL):

19990504 Creation: Moved Tree and PatientList from Avs_dcm to here
19990511 Adjustments concerning DcmSetLocal
19990825 Added extended patientlist export: DcmPatientList2
19990826 Implemented DcmPatientList2
19990830 Fix: ParseSelInfo did not handle an 'extra' Key/Value pair in a
selection-string.
19990906 Improved Alias-names of Dicom Tree Interface
19991019 Besides CT and MR, the images of modalities US, DR and DS
belonging to the same series are grouped into a single volume.
19991026 Use SeriesDescription in tree if no SeriesNumber/SeriesTime
available
19991028 MultiFrame images will be treated as '.scan' instead of '.image'.
19991029 Added support for multiple multi-frame images in one series
When MovingHere only one image, the C-FIND operation is
skipped. Fix: EchoNumber was discarded when retrieving
header-info
20000126 Fix: EchoNumber was used even when value is '(empty)', only
in cases where EchoNumbers were needed in other parts of the
tree.
20000128 Fix: three memory leaks
20000426 Adjustment for difference in response of Borland ODBC and
Microsoft SQL: an empty string-field is returned as "" and " "
respectively.
20000707 Put structures in the tree under a scan
20000710 Fix: Update cache when TREE has been bypassed
20000717 Fix: XFMs of multiframe-scans were not returned
20000808: Extra check: SOPInstanceUID must be passed in selection for
RT objects;
20000823 Fix: Crash in building of TREE when the move-response of an
RT-object was OK, but no DDO was transmitted.
20000828 Fix: Structure and beams has wrong XFM when patient is
prone
20000829 Added RTIMAGE properties: 'refmeam', 'refbeamwordxfm' and
'refbeamgantryxfm'
20010420 Added support for PatientID containing '/' or '\\'.
20010619 Start implementation of RTDose objects.
20010717 When RTStructs do not reference a Series, use
ReferencedFrameOfReference if possible. Caller may use
'IMAGESONLY=1' in DcmSetExtraParams when grouping of
images into scans is not desired.
20011214 Damn! It now seems best that US images are not grouped
together anymore...
20020403 Fixed bug when UIDs are 64 bytes long. Got rid of two #defs
20020501 Added cacheing properties
20020521 When modality equals PT, combine slices to a volume.
20020613 Always use SeriesDescription in tree
20020619 Split date parts with dots; display studymodality (0008,0061) in
study alias

20020620	Merged 20020613 with 20020619. Do not split dates.
20020815	In 'ParseDicomInfo' allow also ':' as a separator
20021011	Fix: When bypassing the TREE, cache was not initialized when retrieving a single image or a multi-frame volume
20021011	Added other query modes (4..9) for DICOM_LOAD_PATIENTLIST (CreatePatientList)
20021014	Merged the two versions
20021028	Try to get XFM's of multiframe objects right.
20030128	Support for 3D TimeSequences, resulting in 4D 4-space output scans. Make check on QueryResponse case-insensitive (choked on PatientID Test vs test)
20030130	Support for 3D private Kretz ultrasound
20030213	Above change crashed when in a FIND operation there is US present, and the queried dicomserver did not supply the 'Manufacturer' key.
20030624	Support for multiframe dosegrids
20030710	Additional sorting of C-FIND result on SOPInstanceUID
20040525	Also send PatientID when query/retrieving RT objects
20050126	Made better ALIAS in TREE for RTPLAN
	Made ALIAS in TREE of a series '(empty)' if no good ALIAS can be constructed
	Implemented interface to load individual segments in a beam
	Moved DCM_PLAN and DCM_STRUCT typedefs to "CqRtObjects.h"
20050131	Check empty sequences in 'StoreBeamPropertiesInCache', and made DDO a TypedDDO
20050201	Handle possibility of retrieval of beam properties before retrieval of outline in ReadKeys()
20050203	Function GetRtDDO now caches DicomRT files. When a NEW PatientTree is constructed, these files (of a different patient) are deleted. This speeds up things enormously
20051018	Support for Corvus in FixControlPointProperties
20060103	Studydate queries on val instead of *val* (kodak could not handle it)
20060531	Added exported function 'DcmGetPlanPois'
20061018	Apply rotations to DcmGetPlanPois when the patient is not HFS
20061101	Recoded 'DcmGetPlanPois' (pretty complicated now...)
20061109	ROI and POI RTStructs from Pinnacle do NOT have exactly the same timestamp
20070112	Extra consistency check in DcmGetPlanPois
20070220	Adjusted DcmGetPlanPois so it can handle 'derived' plans
	Added DcmShiftPlanIsoc
20070419	Fix in PatientTree in presence of long RTPlanName
20070423	Added outputstring pszCreatedUID to DcmShiftPlanIsoc
20070508	Fix: date query on empty mask failed
20070522	Temporary workaround for XVI-upi-bug in DcmShiftPlanIsoc()
20070530	Added DcmGetPlanStructUIDs()
20070530	Fixed bug in DcmGetPlanPois() when more than 1 isoc defined in RTSTRUCT
20071018	Added DcmGetLastCreatedStructUID and DcmSetLastCreatedStructUID. This is a mechanism so that a newly created RTStruct can be referenced in a shifted RTPlan.

20071031	In DcmGetPlanPois(), support 'QUIRT CqDicom' structuresets too. In CreateTree(), treat a marker as a structure
20080313	Support markers; treat them as structures; In DcmGetPlanPois(), the consistency check on isoc in plan and structureset is omitted. We take the isoc from the plan.
20080318	Store RTPLAN properties also in cache, and added 'NumberOfFractionsPlanned'
20080320	In ReadKeys(), also use SOPInstanceUID for RTDOSE
20080717	Moved prototype of DcmStoreFiles to CqGlobal.h
20080818	Made to compile with MS7 (fabs on integer)
20080908	ix xfm2 for &Kretz, and implemented those for &Philips
20081002	Adjustment in the Tree for Philips ultrasound (possible 3D scan in private VR)
20081124	Fix matrix for Philips 4D US (AMC patient 0321)
20090202	Fix display of study modality in patient list (is now in dictionary)
20090610	Added safety check in DcmGetPlanPois(), DcmShiftPlanIsoc() and DcmGetPlanStructUIDs() in case our so called UPI is NOT unique

CQCACHE.CPP (part of conquest interface DLL):

20000710	Added CacheInitFromSelectionStrings
20000808	Fix in comparison of selection with cache
20000824	Added ReferencedStruct to cache (used for beams)
20000829	Also store 'image' in cache
20010717	Some work on RTDose objects
20020418	Added cache-ing of properties
20040616	In CacheInit (Called from PatientTree), keep the cache if the tree is from the same patient
20050203	Added CacheCleanupRtObjectFiles. This is done just before a PatientTree of a different patient than last patient is being constructed
20050906	Added 'CacheGetReferencedProperties()'
20050919	Increased MAX_SEL_CACHE from 200 to 2000
20061109	Increased MAX_SEL_CACHE from 2000 to 10000
20080318	RTPLAN properties are now cached too

CQPRINT.CPP (part of conquest interface DLL):

20020814	Added exported functions 'DcmPrintScan' and 'DcmPrintFile'; Altered 'PDU.AttachRTC' in 'PrintGrayScaleImages'; Tested with OFFIS and Mallinckrodt
20020816	Padded uneven string VR's with space Support of byte images. (RGB does not work yet)
20020823	DcmPrintFile accepts multiple filenames (separated by ;) and decompresses NKI data
20020825	Added DllProgress calls during print (used by server to ensure printing without losing socket data)
20051217	Use nicer method to replace compressed by uncompressed data
20080313	Removed some warnings
20080818	Made to compile with MS7

CQINI.CPP (part of conquest interface DLL):

20020814	Added exported functions 'DcmPrintScan' and 'DcmPrintFile';
20081002	Created
20081014	Fixed parsing of backslashes in KeyValueToVR
20081015	Fixed translating hex values in KeyValueToVR
20081029	When the data of a VR exceeds MAX_DATA_LENGTH, then a '*' is appended to the Key in DcmReadIniObject() The '*' is ignored (stripped) in DcmWriteIniObject()
20081106	In DcmSetField() and DcmSetString(), also accept a new VR. For now, this is only implemented when the VR is not inside a sequence.
20081111	Fixed errorhandling in above functions
20090602	Added DcmPlanIniToPrescription.

ERRCODES.H (part of dgate.exe):

20041221	Moved errorcode to here
20050901	Renamed errorcodes.h to errcodes.h

CQJPEG8.CPP (part of conquest interface DLL and dgate.exe):

CQJPEG12.CPP

CQJPEG16.CPP

20020301	Created
20030415	Better exception handling
20030417	Support for multi-frame images
20041221	Changed include files
20050215	Fixed for fragmented frames in a sequence
20050901	Renamed errorcodes.h to errcodes.h
20070112	Return Width, Height and BitDepth of the image
20071001	Output of JPEG error messages to OperatorConsole in server
20080819	Suppress large amounts of jpeg errors; added \n
20081116	Adapt for very large objects (use unsigned int lenght)

CQJPEG.CPP (part of conquest interface DLL):

20030123	Created
20030128	Start work on RLE decompression
20030415	Fix in determining RLE decompressed size\
20080313	Removed some warnings

DICOMP.CXX (sample print program)

20020816	Fix in (unfinished) main server code
20020822	Made this sample program part of code base
20080113	Fixed for MS7 compiler

TEST.CXX (sample client program)

19980322:	played around; added comments in query client
19980322:	Added command line interface for c-find
19980323:	Added command line interface for c-move
20000318:	Added optional NKI command vr's to echoclient
20020315:	Started on -fe: forwarding server; implemented echo, working on move and find
20020316:	Added cstoreclient -t; load dd.txt as dicom dictionary; -fd=diagnostic mode (logs) Added IARQ; note: cast of PDU to

dump() seems to crash sometimes. Forwarder works between QUIRT/conquest apps and conquest dicom server.

20020317: Made forwarder more general; works between EFilm and Conquest

20020811: Fixed forwarder such that it works for dicom-print
Fix: Forwarder did not work with OFFIS because OFFIS checks message command/data pdu bit 6[1] that is was not set correctly by forwarder (command/data object)

20020822: Made this sample program part of code base

20030630: Fixed crash in cast of Dump(PDU) (c.f. 20020316)
Fixed passing of cmds to Find and Move
Fixed continuous CechoServer
Removed calls to obsolete PDU.Write()

20030721: Fixed SetStringVR (pad uneven strings with a space)
C-Find and C-Move wildcards "*" seem not to be valid

20040711: Fixed forwarder: status=0xff00 loops responses; status==0 keeps association open

20040712: Added auto-returner to forwarder - functions with NKI viewers (assumes viewerAE of X%ip or XX%ip).
You need to set AE and port of return forwarder in your PACS though; see gatewayname, gatewayport, returndump and viewerport for configuration

20040713: Attempt to make it multithreaded; however return connection only starts once (supports single client only!)

20040713: Split into modes -fp: for printer; -fb: forwards and returns; -fe normal forward; -ff fixing forwards

20051217: Use new ReAlloc method to replace data in VR

20060618: Allow (and disabled) looping of c-move to test repeated c-move problem in read-ahead thread

20061127: Allow (and disabled) looping alternating c-move and c-find to test server

20070902: Fixed for ms7 and ms8

20090411: mode -fp adds more transfer syntaxes uid2..uid8 (experimental)

TOTAL.CPP (sample for making DGATE.EXE without make file)

20020822 This file compiles to TOTAL.EXE = DGATE.EXE with, e.g., BC55

20050102 Added NOINTJPEG flag: jpeg8/12/16 sources cannot be compiled at once

20050107 Changed order of compile

20050111 Added npipe.cpp and gpps.cpp for LINUX

20050118 Documented how to compile under linux and with visual c++

20050121 Changed filename to lower case

20050130 Added xvgifwr.c

20070315 bcb added DARWIN stuff

20070330 bcb added DARWIN compile example

20080820 Solaris compile example

20080910 fixed DARWIN compile example for build version of mysql

20081016 Fix link to xvgifwr.cpp; 64 bit example code

20090209 Added jpeg_encoder.cpp

20090411 Added second SUN example

DGATESERV.DPR (part of dgateserv.exe)

20000316	Created
20000326	Close handle on terminate
	Dgate runs via new SlaveProcess mechanism of Uservice

USERVICE.PAS (part of dgameserv.exe)

19990316	Fixed English of some messages
	Added account and password as optional parameters for install
19990325	Added option to start/stop/install/uninstall on remote machine
	Works fine with start / stop / uninstall
	Remote install works except for wrong exe path
	Therefore added ExeName property and command line switch
19990326	Added service option: makes it a generic installer!
	Made ServiceName and ServiceDisplayName read/write
	Added AllowSlaveProcess: command line can set slave process
	Added SlaveProcess and SlaveProcessArgs: executable to start
	Fixed arguments passing when /start is followed by more /
	Fixed ServiceName: is read as first arg in DoCmdLineStart
	Note: SlaveProcess is killed when service stops

SERVERDRIVER.PAS (part of conquestdicomserver.exe)

19980405	Created
19980407	Added dgamesop.lst file creation; max AE to 16 chars
19980407	Sorted image list on SOPINSTANC to get correct order
19980412	Added DuplicateHandle code; but still deadlocks
19980413	Threaded mode avoids TCP/IP component (seems to fix deadlock)
19980414	Restart after switching server mode does not always work;
	Fix application to threaded mode for now.
	Added compression configuration.
19980415	Some fixes for the first installation code
19980505	Made length of directory field in MAGDEVIC 250 chars
19980608	Replaced TQuirtViewer with TImage => no need to load ntpars.dll
19980614	Merged code with use FPiette tcp components
19980616	All OK with new fpiette code; actually I had to fix my own bug
19980617	Save as bitmap and dump header in popup menu
19980618	Query and Move options for CQDICOM.DLL
19980619	Added header lister; default MagDeviceThreshHold to 10 MB
19980620	MagDeviceThreshHold is now configurable
19980621	Renamed table to MagDevice; use full table names
	Nicely coded DBF/Access choice; but fixed to DBF
	Delete patient and refresh database menu options
19980622	Double click query memo to make new query
	Show on bitmap: patient is being deleted/file not found
19980623	Save bookmarks of tables; move to next record after delete
19980624	DICOM.SQL: StudyNumber (StudyID in DICOM) is now 64
	long (Microsoft SQL server does not allow truncation)
	Update bitmap after loading for fast display
	Text strings in UDP input to 1024 (for long SQL errors)
	Default password and user name to 'conquest'
	PAGETIMEOUT to 600 for better database performance
	Made DataSource name more or less configurable
	Made all port numbers more or less configurable

Installing a second server on one PC while one server is running works

19980702 Added KBUSED field in MAGDEVICE table

19980703 Some changes in static texts and hints

19980704 Found a handle leak in RunDgate; not fixed yet

19980708 Make anonymous; show progress for move

19980710 Added experimental archive option; fix stopcopying option

19980711 Fix double click query on empty form; use tray icon

19980713 Add Name of server in tooltip of tray icon; fix DiskFree

19980717 Fix crash if directory does not exist

19980721 Clicking tray icon restores window

19981219 Improved error handling display;

19981220 List header of undisplayable object in static
Read and save FileNameSyntax; default=3

19981221 Suppress display of large files (>1 MB)

19981222 Use FieldByName, added combobox selectors
Disable study navigator if only 1 available
Moved modality from the study to the series level

19981229 Changed order of TableN.close to avoid side effects

19990104 Fixed MAGDEVICE creation under SQL server
(KBused optional)

19990109 Made ImageNumber 10 bytes wide (for GE AdvantageWin)

19990110 Combobox1 is now patient filter and or selector
Added access to cache and jukebox in browser but
with limited support: up to 10 devices (one character)
Added archiving page; fixed most handle leaks

19990112 Finished first archiving page; -hide command line option
Added clear database and regen single device buttons
Clear combobox for each page select
NOTES: Archive page is configured by editing
Restore original configuration or restart to load it
Archiving allows up to 10 Jukeboxes, but only the
selected one is used for writing. Only the drive
with MAG0 is checked for disk space for automatic
archiving. Only device CACHE0 is passed correctly
to the burn program. This means: stick to 1 MAG
device and 1 CACHE device for now.

19990113 Speeded archiving by selecting MAG0 if there is only 1
Renamed entry to BurnThresholdMB, made BurnProgramList
Note: to do - keep log file of archiving operations.
- add RT objects to default sop file.

19990114 Added date and time formats for burnprograms

19990115 label format burnprograms; no write empty ini
Sync magdevice0 with DataDir; %% and %p formats

19990315 Added EchoNumber in image table - used to separate PD,T2
Completed dgatesop.lst with Philips, GE, RT
Added NumberOfFrames in image table - to find multiframe
objects

19990413 truncate QUERY request depending of level

19990510 Allow AEs starting with a digit (Siemens MRI)

19990527 Revision 3 of database layout (birthday, sex, bolus)

19990902 Added load/store of mirror devices and export converters

19990905 Switched word wrap off for memo's
Added DcmMoveFilesHere on right click of copy; but seems to
crash; Problem: if we pass DcmMoveFilesHere servers

AE/PORT saving slices from own server will fail. Now pass 'test;1234'

20000127 Hide archiving tabsheet in new install; Add NKI sops to install;

20000128 Added extra GE sop; compressmode 2; disabled movefiles here

20000316 version 1.3.5: Integrates dgate as service operation
New install does not start dgate right away

20000317 Truncate patient list if too long

20000318 '\$ RESTART' as console message kills and restarts server
'& DGATE xx' as console message runs dgate with args xx

20000323 Added query sop choices through level dropdown list

20000326 Service supported for more than one server:
servicename=AE; port passed as /process dgate.exe -!port
Removed need to enter password for SQL access
Save and restore user and password in dicom.ini
Added 'ping' option for remote check of archiving:
Deletes ConquestDICOMServer.Ping and makes
ConquestDICOMServer.response with archive status
Allow up to four servers at the same time, also as services
Note: only the first server will start correctly on boot!
(on boot, the /process parameter is not passed and the
default IP message port will be used -!1111); Presence of file
USESQLSERVER allows install on SQL server
Presence of file USEMSACCESS allows install using access db

20000328 Added tests of local server at key moments
added -noconfirmquit option; show VERSION in caption

20000402 Install service with startup at right socket
Read service socket from registry on startup

20000403 Improved socket handling; fixed space in path when not
service; space in path blocks service install.
Now recognizes installed but not running service
Number of servers on one PC is now unlimited.

20000417 Fixed MSACCESS ODBC creation

20000501 ExportModalityx should be UPPER-case

20000528 Added "force display of large image", "remove image from
database", "run external viewer" and demoviewer option
Removed '.' as workdir from runprogram etc (allow bat files ?)
Added democopy option: copy incoming to dir + CallingAE.v2

20000529 Merged two changes

20000529 Release to 1.3.6

20000616 Attempt to create NewInstallForm database selector

20000625 Added NewInstallForm database selector; default to
MSACCESS
Added Send ... To menu items in popupmenu
Removed '*' items from Dicom system selectors
Added Send Selected Images for more flexibility
Added animated display menu options

20000626 Added Send Selected Images selector window

20000701 Some adaptations of Send Selected Images;
MaxFileNameLength
TrimRight strings in query - trailing spaces depend on db

20000707 Added Edit Database by Hand menu option

20000808 Added ,0 code in timed archiving

20000915 Added ListenSocket.Addr (0,0,0,0) in multi-app mode

20001107 Added CheckBoxViewIncoming for demo display of
incoming images

20001108 Display originating server on incoming image;
Disable menus when the ViewIncoming option is selected

20001129 Added fix so that DICOM.INI may contain UNC path
Added menu choice to change ID of selected series
Version to 1.3.7

20010312 Trimmed remote IP so that hostnames can be resolved in
CqDicom.dll

20010318 Trim servername and ip;
alt-rightclick the service buttons installs service 4 times
e.g., at ports 5678, 5679, 5680 and 5681 (all with same data)
This may be used for efficiency and to limit the effect of
crashes; Version to 1.3.8

20010327 Always pass curdir to runprogramxxx and startprogram -
required because directoryview changes current directory!

20010328 Uppercase account for service; colors for archive status
Added verify mirror disk button; burn only once per time
Show date and time for archival steps; added KeepAlive
Added MirrorVerifyTime (verifies whole MAG0)
Added conquestdicomserver.log with major messages

20010405 Added comma-separated list option for patid in query page

20010406 Ctrl-dblclick adds patid to comma-separated list

20010406 All status memo's are now limited in length and save to
separate log files
Added (and disabled) simple zip code for log files per day

20010409 Do not log query page

20010409 Added Tape backup page; replace few GetCurrentDir by
CurDir

20010410 Added timeouts (10s and 5 hours) to tape backup

20010412 Separate tape backup button - some fixes

20010416 Improved anonymize and change patient ID using new dgate -f
options; Added drag and drop interface to add files to server

20010418 Changed description of forced backup set; refuse dropped
directories; Version to 1.3.9

20010418 Update maintenance memo during drag and drop

20010418 Fix: timer4 was enabled if no KeepAlive specified in dicom.ini
Hide tape backup page in new installation
Added default install button in firstinstall

20010419 Added anonymize and change patient ID for study

20010502 Added DeleteThisStudy/Series

20010830 revision 4 of database definition (extended)
Added ExportStationName in dicom.ini
Updated dgatesop.lst to conform to DICOM 1999 final text
Version to 1.3.10

20010903 Suggest .\username as account

20010904 Fix: Query was freed twice when a DicomMove failed

20011108 Added automatic zipping of log files
Make sure that tape backup and archive pages are not shown
Added save/restore of ExportFilter settings

20011109 Small fixes:
do not write empty configuration strings (empty<>default)
keep some settings with original case (see sorg)
use StrToIntDef to avoid exceptions on invalid settings
Added ZipTime as configurable

20011127 Added SeriesPat and ImagePat fields to DICOM.SQL
Surpress fail message box when using SQL server

Version to 1.3.11

20020402 Adapted controls.pas: exception handling in
finddragtarget and findvclwindow

20020409 DB rev 6: added frame of reference UID to series

20020416 Store/save UIDPrefix for in dicom.ini
When creating dicom.ini, create unique UIDPrefix:
'1.2.826.0.1.3680043.2.135.Date.Time'
Added configurable TestReadTime: regular check of MAG0

20020417 Fix: QueryResult has not necessarily 64 char
Renamed some data structures

20020422 Do not save empty UIDPrefix; fix change patid for study

20020424 Added simple weekly checks page; mail ALL failures

20020426 Fix in mail sender list; use first e-mail as 'to' address

20020428 All recipients show in to: header
Only serious error messages have *** in string
Added MailCollectTime and MailWaitTime
Avoid starting check more than once

20020510 Added CheckDicomSubmits (send mail when users forgot to
send images to the PACS)

20020513 Checks: empty time runs all day; added log header/footer
Updated CONTROLS.PAS: more exception handling
Fixed reading of weeklychecks; display CD num in header
Fix warnings and patient ID checks in CheckDicomSubmits

20020515 Added ImageType to database (rev 7)
Added find missing patients button;
allow more than one weekly check time (; separated, not
adjacent)

20020515 Fix missing pats when query empty
Added grab options to weekly checks

20020517 Changed StudyModality to 64 chars (e.g., fits :
CT\MR\PT\XA\ST\MG\MS\RTIMAGE\RTDOSE\RTSTRUCT\RTPLAN\RTRECORD)

20020518 Fix in weeklychecks tag: too many with tag 0

20020519 Fix in rev 7 db definition: AcqDate is now SQL_C_DATE
Added FixPhilips in DICOM.INI

20020520 Use DGATE.EXE for grabbing

20020522 Fix reading of entries with an '=' in e.g., dicom.ini

20020524 Fix acrnema.map problem with new install

20020529 Fixed duplicate mailing of messages, added WriteMemo
Added archive.log; extra parameter for regen for DBASEII
Removed MessageBoxes

20020609 Read and write FileCompressMode, default remains 2

20020613 Added alt-drop code: enter with new patient ID

20020819 Basic printer support; view incoming shows printer data

20020819 Process messages as files are dropped
Print incoming imageboxes on default printer

20020821 Printer accepts landscape and portrait any pictures per page
Progressbar shows printer queue activity
Note: printer queue is single user (but may be fixed, using
film#)!

20020823 Added print options in browser - print to local dicom server

20020825 Headerlister is modeless - added CTRL-A, CTRL-C, CTRL-F,
CTRL-S, F1, F3 end ESC
Printer has progress hook - required to avoid socket data loss
Selection of print page format; edited info text
Added all 1.3.11 fields to edit database by hand

20021015 Start deleting patient started delete "=ALL when no patient in list!!!!

Protect all pop-up functions for no selection

20021016 Better support for copying large #patients, even if one or more missing

Added denormalized database option (for DBF without ODBC)

Removed obsolete magdevice button

20021017 Added "" around dropped filenames; use filter instead of master-detail (requires index) for built-in dbf support

Version to 1.4.0; added dropping of directories

Added UID counter passed to dgate to avoid UID problems

20021018 Fixed browser fail and missing dbase dir after non-odbc install

Limit dbase list in browser (alternative to image) to 100 lines

20021020 Added Kill and Restart the Server weekly check (packs built-in dbf); Fix reading of database name if not default

20021021 Small fix in maintenance memo for very long strings

20021028 Also denormalized series database; default de-normalize study (rev 8); Show denormalized study entries in database editor

20021029 Fixed query keys transmittal (sent sop when not needed)

20021213 Added EnableReadAheadThread as configurable parameter

Disabled GECTStorage amd GEMRStorage in dgatesop.lst

20030113 Version to 1.4.1; Fixed keepalive option (was never enabled)

Added PatientQuerySortOrder and such

20030128 Fix update of headerlister when no image shown

Make DBF table links case insensitive

20030319 Fix: ImageDB entry 'ReceivingCoil' is 16 bytes (not 12)

20030324 Start on 1.4.2: db rev 10: made ReceivingCoil 16 wide

20030402 Merged above two changes

20030409 Handle DicomPrint error; several path fixes in tape-handling

20030613 Catch WM_QUERYENDSESSION: shutdown disables close dialog

20030628 Fix that more than one dropped directory will be loaded

20030706 Prepare for release 1.4.2; new dicom.ini; kill server

Compression column in acrnema.map

20030707 Added manufacturer to denormalized db (rev 11)

Write registry key

HKEY_LOCAL_MACHINE\SOFTWARE\NKI AVL\Conquest\Dicomserver\SERVERNAME

with values: directory=path without trailing backslash and laststarted=yyyymmdd. For use by Dicom-works only.

Note: servername changes are updated on GUI startup only.

20030708 Made JPEG compression configurable (affects dgatesop.lst)

20030709 Write version into registry

20030710 Install service as system account (no user required)

Fix attempt to mail when not wanted

----- release 1.4.2 -----

20030717 Fix problems when registry access fails

20030809 Will automatically use ADO or MDBF when BDE not installed

Set version to 1.4.3

20030810 Log used DB engine; Added partial ID matching for MDBF

Default enable uncompressed button before install

Force user to push 'Save config button'

Added some text to install and maintenance pages

Do not display images when on jukebox (use force display)

20030819 Made max drop filename length longer (256->1024)

20030905 Date of zip file is one day before if zip before 8 in the morning

Hide external viewer menu directly after install
 Optional configuration of SendUpperCaseAE added
 Removed obsolete flush button
 Do not allow install in directory with spaces in its name
 Removed faulty extra text from install page
 20030907 Fix ODBC generation for directory with spaces
 Just warn against directory with spaces
 20030909 Test write access to log files prior to startup
 20030920 Mail messages that contain 'fail' instead of 'failed'
 Added tape full warning (that will be mailed)
 Added enables for timed archival (to allow retry/timer disable)
 Changed order of burn CD message / tape backup
 Added NextSlotToUse (slot n) next to NextCDToBurn
 (JUKEBOX0.n); % in burn parameters %n = NextSlotToUse,
 %c = NextCDToBurn; Manual archive buttons control
 checkboxes as well
 20030921 CTRL-Double click "automatic archival label" starts archival
 CTRL-Double click "weekly checks time" starts check
 Added NightlyCleanThreshold parameter (clean # MB at
 01:00)
 20040401 Added ImageID to database; version to 1.4.4
 Show ImageID in database editor and browser
 20040402 Allow anonymize etc on MAG0..MAG9;
 changed datasource name (now system DSN)
 20040425 Added DoubleBackSlashToDB to dicom.ini
 20040426 Version to 1.4.4a
 20040528 Use built-in servertask commands for maintenance and browser
 20040530 Browser for built-in DBASEIII driver uses extract server
 command; Database editor to read only for built-in DBASEIII
 driver; These changes allow efficient use of in-memory index
 for dbaseIII; OK for 10⁷ images when patientID, studyUID or
 seriesUID passed in Queries; Added PackDBF and IndexDBF
 to dicom.ini; Reworded some in popup menu; wait for patient
 deletion to finish; Fix refresh for sql server
 20040601 Added LongQueryDBF flag
 20040605 Fix extract when no patients; kill server stops loop of server
 tasks; start server on activate (after windows shows)
 Pack the Database as Weekly Check Action
 20040606 Fix in formactivate; display @ startup
 20040610 use servertask to clear index and rebuild it in built-in dbase
 mode
 20040614 small fix in keep server alive; added nightlymove option
 20040615 small fix in nightlymove option; also reindex after regen device
 20040713 Added FixKodak; version to 1.4.6
 20040722 Installation defaults for FixPhilips and FixKodak are now 0
 20040804 Added *.lst to zipped log files; added bug report option
 Version to 1.4.7
 20041029 Added merge and split series options;
 Process messages during long GUI actions if possible (no DB)
 20041030 Modified GUI of merge and split, process messages
 20041101 Check for MAG storage for split/merge
 Delete from DB does not use image (for orphaned DB)
 USEDDBASEIIIWITHOUTODBC replaced by Pos('\',
 Datasource)>0 while running
 20041102 Added nj compression mode

20041108	Added warning when alt-dropping file(s) with \$.. as Patid (debug)
20041128	Fixed wording of delete messages: works on all mag devices Fixed problem in DeleteThisSeries, Anonymize, and change Patient ID: last series could not be modified/deleted
20041129	Made font size of server status window selectable; Made debug log switchable; service will continue to log to file even if user interface is closed (but with different date/time layout) Now can save and use acrnema.map without server restart Fix startup problem when disk 'c' not available
20041201	Backup fail 1..5 files temp logged as ALMOST OK -> continues
20050106	Fixed install as four services, fixed nightlymove amount Is now nightlymovethreshhold - free space: i.e., attempts to make nightlymovethreshhold MB free space Fixed nightlymove: forgot to pass '0' for MAG0 Also, try move even if select failed to avoid stall after partial failed select
20050109	Made backup of and warn when dicom.sql is overwritten Added TCPIPTimeOut, FailHoldOff, RetryDelay, QueueSize Version to 1.4.8
20050114	On startup ask to delete ExportFailures*, CopyFailures*
20050422	Added BurnTime2 (2 dvds per day) and BurnWeekend (all weekend through)
20050429	db rev 14: added worklist support
20050829	recurse directories when dropping files to ease load dicom CD
20050831	Added find modality worklist to dgatesop.lst
20050901	Added clear worklist button, version to 1.4.9, WorkListMode
20050905	Modality worklist query, auto append worklist to dicom.sql
20050907	Avoid dicom.sql message in new install, v* and s* in acrnema.map
20050912	Small changes to dicom.ini, dicom.sql, dgatesop.lst; added SQLHost. Small change to mdbf: extra refresh avoids browser failures
20051024	Version to 1.4.9a: recompiled with patched controls.pas
20051230	Version to 1.4.10 Moved clear worklist button and add pack database button Added warning when worklist is added to dicom.sql: clear worklist required Added settings: DebugLevel, CacheVirtualData, LargeFileSizeKB, VirtualServerFor# enable study controls prior to return if same (none) image shown
20060102	Update of hints
20060103	1.4.10 Release
20060201	Added K-Pacs/EZDICOM based viewer
20060312	Keep case of VirtualServerFor; Message buffers from 1024 to 8192; Open k-pacs viewer on correct series; version to 1.4.11
20060314	Added experimental native Mysql access; installs when libmysql.dll is found - uses mysql version 4.1.14
20060315	Keep case of FileNameSyntax
20060328	Updated hints and file version for release 1.4.11
20060618	Set default user for mySQL to root (thanks Chris Muller) Seems to then also work with mySQL 5.0.22, version to 1.4.12
20060707	Bug reported by Paolo Marchesi: save config loses DBF

Now only set to default when previous does not exist
 Use same zipmaster as in previous versions (zipmaster\org)

20061101 Added SeriesDescription to query page

20061129 Added control for debuglevel, and allow queries on UID
 Double click queries labels to change mode

20061130 Added new dgate parameters; consolidated debuglevel control
 and param
 Made application forms resizable and set size constraints
 Small font control works on all status pages
 Double click image to force display it

20061220 Pass Tempfile to kpacs viewer form

20070123 Added processfilter to allow browsing of patients with ' in
 patientid

20070126 Importconverters stuff and ForwardAssociationRelease in
 dicom.ini; Version to 1.4.12b

20070201 Version to 1.4.12c

20070204 Fix in generation of UIDPrefix: was not automatically
 generated on startup

20070206 ODBC buttons will also create database for SQL server

20070207 ODBC button creates database for native mysql

20070211 Native MYSQL did not create indices during install
 Fixed selection of DBF (with odbc)

20070221 Started to SQLite (not yet fully functional)

20070305 Version to 1.4.13alpha

20070316 Use | in patid instead of , in drag and drop to allow dropping
 files with a , in them while changing patientid (not backwards
 compatible)

20070415 Back to , in patid in drag and drop: ljz fixed it in dgate.exe
 Added Prefetcher flag in dicom.ini (default 0)

20070520 Fixed missing completed message in regen single device

20070705 Added BrowseThroughDBF: unified browser used for SQLite
 Works for other datasources but not configured as such
 Small fixes in completed message in several regen functions
 Fixed view/edit database second time round (enable)

20070706 Auto create mysql registry settings for native mysql
 Disallow anonymize and change to empty name
 Message on end of odbc or db creation
 Version to 1.4.13beta

20070708 Patched forms.pas for Chad Moser's crash problem.
 Added BrowseThroughDBF setting in dicom.ini
 Default 1 for SQLite, 0 for others
 Use extract: also for dbaseIII: to avoid multi-user problems
 when browsing and writing at same time

20070709 Small fix in dbf+bde browsing
 Auto register webserver\ActiveFormProj1.ocx if found
 Do not use extract: for dbaseIII: browser does not work
 while indexing

20071030 Also delete DelayedFetchForwardFailures* on startup

20071103 Added LRUSort, AllowTruncate, ForwardCollectDelay,
 MaximumExportRetries,
 MaximumDelayedFetchForwardRetries
 Version to 1.4.13

20071104 Added DecompressNon16BitsJpeg, UseBuiltInDecompressor
 Made IncomingCompression editable (double click label)
 Made FileNameSyntax editable (double click label) and

allow choice of V2 and DCM through radiobuttons

20071114 Save root password while installing for mysql with password

20071115 Disabled multi-process mode in RunInThreadedModeClick to allow multiple saves of ini file during install (for above password)

20071115 Save password and username for SQL server install as well

20071116 Longer default password for sql server 2005

20080124 Added mailer settings in dicom.ini

Disable LittleEndianExplicit on install

Added configuration for mode UJ

Database revision 16: Moved Stationname and InstitutionalDepartmentName to series table

Added extra warning when revision 16 not detected

moved Stationname and InstitutionalDepartmentName in view/edit database

Version to 1.4.13a

20080126 Automatic add backslash to read MAGDEVICES etc and give a warning message

20080322 Version to 1.4.14beta

20080322 Fix first install bug in test dicom.sql; fix send image crash in UID mode; display selected UIDs in query/move page

added PadAEWithZeros and IgnoreOutOfMemoryErrors

20080818 Database revision 17: extended size of EchoNumber and ReqProcDescription to 64; EchoNumber, StudyModality and ImageType are DT_MSTR: multiple values; use Institution (8,80) instead of InstitutionDepartmentname (8, 1040)

Added WorkListReturnsISO_IR_100

20080819 Version to 1.4.14

20080831 Default ForwardAssociationRelease to 1

20080902 mvh Added EnableComputedFields, default 0

20081104 Fixed install as four NT services: trim IP port before convert to int; Fixed save of database name to dicom.ini for mysql install

version to 1.4.14a

20081121 Added Postgres support; attempt fix MySQL support

Automatically choose the 64 bit dgate if possible

20081123 Retry server test for 4 sec after db install

20090203 Trim data read from dicom.ini to remove trailing spaces

20090205 Added MailPort option

20090411 version to 1.4.15alpha; Added PrintSquareLandscape, max converters to 19, VirtualPerSeries0..9, RetrieveResultConverter0, QueryConverter0, WorkListQueryConverter0, RetrieveConverter0

Let OCX registration fail without warning (for vista)

20090927 Added RetryForwardFailed

20090927 Optionally use 7za.exe instead of zipmaster (when zipdll.dll deleted)

Added RetryForwardFailed

20090928 Default sql password to conquest1415;

20090929 Added ImportExportDragAndDrop flag (default 0)

20090929 Version to 1.4.15

SERVERABOUT.PAS (part of conquestdicomserver.exe)

19980405 Created

19980618 Added reference to Fpiette; use form also as file lister

19980624	Removed line about backdoor
19980721	Removed line about Mark Oskin going away
19990527	Release to 1.3.3
20000128	Release to 1.3.4
20000316	Release to 1.3.5
20000529	Release to 1.3.6
20001129	Release to 1.3.7
20010318	Release to 1.3.8
20010318	Release to 1.3.9; fixed dbaseIII text
20010830	Release to 1.3.10;
20011127	Release to 1.3.11;
20020816	Release to 1.3.12;
20020825	Made Lambert's e-mail address more prominent
20021018	Version to 1.4.0; added release date
20021020	Update release date
20021028	Update release date
20021215	Update release date
20030113	Version to 1.4.1; release date
20030128	new release date
20030303	new release date
20030710	Version to 1.4.2; release date
20030809	Version to 1.4.3
20030810	Added reference to offis, zipmaster, and mitec
20030922	Release date
20040402	Version to 1.4.4
20040406	Release date
20040426	Version to 1.4.4a; Release date
20040615	Version to 1.4.5; Release date
20040722	Version to 1.4.6; Release date
20040805	Version to 1.4.7; Release date
20041129	Release date
20050106	Version to 1.4.7a; Release date
20050109	Version to 1.4.8; Release date
20050303	Release date
20050912	Version to 1.4.9; Release date; worklist info
20051024	Version to 1.4.9a; Release date
20060103	Version to 1.4.10; Release date
20060314	Version to 1.4.11; Release date; new acknowledgements
20060402	Changed fpiette's website; Release date
20060708	Version to 1.4.12alpha; Release date
20061222	Version to 1.4.12; release date
20070126	Version to 1.4.12b; release date
20070201	Version to 1.4.12c; release date
20070706	Version to 1.4.13beta; release date; sqlite reference
20071116	Version to 1.4.13; release date
20080322	Version to 1.4.14beta; release date
20080831	version to 1.4.14; release date
20081121	version to 1.4.14a; release date
20090411	version to 1.4.15alpha
20090927	version to 1.4.15

SENDSELECTED.PAS (part of conquestdicomserver.exe)

HEADERLISTER.PAS (part of conquestdicomserver.exe)

20020825: added keyboard interface (see serverdriver.pas)

EDITDATABASEFORM.PAS (part of conquestdicomserver.exe)

ABOUTNEW.PAS (part of conquestdicomserver.exe)

20000625	Added NewInstallForm database selector; default to MS ACCESS
20010418	Changed text; added default install button
20010830	Version to 1.3.10
20011127	Version to 1.3.11
20020816	Version to 1.3.12
20021016	Added DBF without ODBC
20021017	Version to 1.4.0
20021018	Default to USEDATABASEIIIWITHOUTODBC
20030324	Version to 1.4.2
20030810	Version to 1.4.3 - removed ODBC DATABASEIII choice
20040102	Version to 1.4.4
20040426	Version to 1.4.4a
20040530	Version to 1.4.5
20040713	Version to 1.4.6
20041029	Version to 1.4.7
20050106	Version to 1.4.7a
20050901	Version to 1.4.9
20051024	Version to 1.4.9a
20051230	Version to 1.4.10
20060313	Added experimental native Mysql install when libmysql.dll is found
20060618	Version to 1.4.12
20070126	Version to 1.4.12b
20070201	Version to 1.4.12c
20070305	Version to 1.4.13alpha
20070305	Added experimental (not fully functional) native SQLite install when sqlite3.dll is found
20070706	Version to 1.4.13beta; sqlite always enabled (driver linked in)
20071103	Version to 1.4.13
20080322	Version to 1.4.14beta
20080819	version to 1.4.14
20081121	Added postgres; mysql unconditional; version to 1.4.14a
20090411	version to 1.4.15alpha
20090927	version to 1.4.15

DVIEW.PAS (k-pacs viewer part of conquestdicomserver.exe)

20000625	Added NewInstallForm database selector; default to MS
20060116	Adapted for Delphi 5 compatibility Do not use TFormatSettings; Do not use DelimitedText
20060116	Included NKI decompression (without CRC check)
20060117	Reset NKICompress flag if normal pixel data found
20060117	Fixed AddDelimitedText; fixed for multiframe data
20060117	Fix NKI compression when DCMloadMultipleFiles is true
20060117	Fix Get_ZDimension when DCMloadMultipleFiles is true
20060117	Accept conquest .V2 files as dicom in DCMloadMultipleFiles
20060120	DcmFilename now accepts multiple filenames separated by "**"

20060120	Added new dcmTool kSlice to stack through an image
20060120	New global boolean gNoOffsetList to bypass gOffsetList array
20060121	Reimplemented tiled display (mosaic), set with procedure DCMSetMosaic
20060123	Restored layout to allow windiff, lossy jpeg now gives correct error
20060126	Added support of value representation "UT"
20060126	Improved scaling of text overlay and measurements
20060129	Added option to save image in RAW format
20060129	New OnMouseEnter and OnMouseLeave events and custom cursors for several gTool's
20060129	Added overlay text color option
20060129	Fixed JPEG bug in multifile mode
20060130	Changed mosaic slice# place
20060130	Fixed nki_private_decompress: error for large pixel values (>32768)
20060131	Fixed reading of ELSCINT and ACUSON images that use NKI private tag 7fdf:0010
20060201	Improved real-time image zooming through bypassing the SetDimension procedure
20060202	Fixed display of slice numbers in empty fields in multview mode, fixed mosaic mode for multiframe dicom images
20060204	Enabled saving to TIFF using W. Krug's Bmp2Tiff unit
20060205	Added Tool kShutter
20060223	Changed rescale method to rescale buffer directly after reading pixeldata
20060223	Reverse NKI test: if nki compression mode >4 it is not made by NKI
20060304	Fixed NKI compression of 8-bit and color images; todo: 1966 and some PT images level&window wrong
20060420	Added orientation indicators to text overlay
20060421	Implementation of TdcmOverlay record to describe custom overlay
20060425	Added TRuler class to show spacing
20060502	Implementation of basic VOI_LUT support. Currently only 16bit VOI LUTs are supported.
20060607	Merged changes mvh 20060223 and 20060304
20060608	Need CONQUEST define to enable NKI compression, fix crash in TdView.AdjustOrientChars
20060609	Fixed VOI Lut crash when encoded explicit
20060611	Added PixelPaddingValue and PixelRepresentation to DicomData and fixed an unwanted pixel value correction if pixel padding is out of SS range
20060618	Merged again; added 20060223 and 20060304 changes back in
20060712	fixed wrong orientation label display when ImageOrientation and ImageOrientationPatient string is available
20060728	Added support for non-square Pixel Aspect Ration
20060801	Bitmap overlay support implemented
20060830	3D Cursor function implemented using open source vector math units
20061107	?
20061220	Made compileable again in conquest: stripped html support in conquest mode
20061220	Found endless recursion on double click: IFNDEF conquered
20061222	Tried to restore layout

20070204	Added (dumb) access to http: files
20070216	Important bug fix: allow switch to implicitVR: I found a NKI compressed image with VR length 03544C = 'L', 'T', 3 and LittleEndianImplicit --> length was seen as LT code causing reader to go out of sync see: { mvh 20070216 }
20070216	Fix that magnifier would never return its cursor by setting Screen.Cursor to default when changing modes
20070305	Put downloaded dicom file in TempPath, document download code: note not safe when using multiple controls side by side.

UVIEWER.PAS (wraps k-pacs viewer in conquestdicomserver.exe)

20060130	Replaced Japanese fonts (never create forms on a japanese laptop ;->>>)
20060304	Set limit to 2000 studies
20060312	Slice with + and -: keep other keys for series browser Added OpenSeries; disallow hor scrollbar in stringgrid
20060618	Removed unused variable; moved slice controls into toolbar
20061220	Replaced viewertemp.\$\$\$ by passed tempfile
20061222	Added some logic for better control of zoom and l&w
20070305	Made mosaic global
20071103	Use DLL way of accessing server to avoid 'server not running' error
20080108	Fixed hard-coded IP port 5678 for K-PACS viewer
20080901	Added flip left-right button; OCX define

UViewerActiveFormImpl1.PAS (wraps k-pacs viewer in activeX control)

20070305	Created update history
----------	------------------------

SQLITE.PAS (TDataset control for GUI access to SQLITE3)

20070221	Adapted for SQLite3, but not yet fully functional
20070305	Created update history